

**Project Done on Behalf of
Sasol Technology (Pty) Ltd**

**Atmospheric Impact Report:
Sasol Secunda Facility**

Report Number: 13STL01SC

Report Version: 2.0

Date: September 2014

Authors:

**L Burger
R von Gruenewaldt
T Bird**

Airshed Planning Professionals (Pty) Ltd

PO Box 5260
Halfway House
1685

Tel: +27 (11) 805 1940
Fax: +27 (11) 805 7010
e-mail: mail@airshed.co.za



Preface

Sasol's operations at the Secunda Facility (Synfuels) are required to comply with the Minimum Emissions Standards, which came into effect in terms of Section 21 of the National Environment Management: Air Quality Act (Act No 39 of 2004) on 1 April 2010. The Minimum Emission Standards were subsequently amended and the amendments were promulgated on 22 November 2013 (Government Gazette No. 37054), replacing the 2010 regulations. These standards require the operations to comply with standards for "existing plant" by 1 April 2015, and for "new plant" by 1 April 2020. Sasol intends submitting an application for postponement from the compliance timeframes in support of the submissions and to fulfil the requirements for these applications stipulated in the Air Quality Act and the Minimum Emissions Standards, an Atmospheric Impact Report (AIR) is required to substantiate the motivations for the postponement.

The facility in Secunda, Sasol Synfuels, produces synthesis gas (syngas) from coal by gasifying the coal at a temperature of 1300°C, using two types of reactors (circulating fluidised bed and Sasol Advanced Synthol™ reactors). The syngas is subsequently converted to produce components for making synthetic fuels as well as a number of downstream chemicals. Gas water and tar oil streams emanating from the gasification process are refined to produce ammonia and various grades of coke respectively.

Whilst the main air pollutants from the Secunda operations include sulfur dioxide (SO₂), nitric oxide (NO) and nitrogen dioxide (NO₂) – collectively known as NO_x, other pollutants to consider include particulate matter (PM), volatile organic compounds (VOCs), ammonia (NH₃), hydrochloric acid (HCl), hydrogen fluoride (HF), dioxins/furans and metals.

Airshed Planning Professionals (Pty) Ltd (hereafter referred to as Airshed) was appointed by Sasol to provide independent and competent services for the compilation of an Atmospheric Impact Report as set out in the Regulations Prescribing the Format of the Atmospheric Impact Report (Government Gazette No. 36904, 11 October 2013) and detailing the results of the dispersion model runs. The tasks to be undertaken consist of:

- 1) Review of emissions inventory for the identified point sources and identification of any gaps in the emissions inventory. It is preferable that gaps be estimated using an agreed emission estimation technique.
- 2) Prepare meteorological input files for use in one or more dispersion model to cover the applicable Sasol sites. Sasol will provide surface meteorological data and ambient air quality data from the Sasol ambient air quality monitoring stations. Surface meteorological data for three years, as required by the draft Dispersion Modelling Guidelines for Level 3 Assessments (Government Gazette No 35981 published 14 December 2012), is available for ambient air quality monitoring stations situated in both Sasolburg and Secunda.
- 3) Preparation of one or more dispersion model set up with Sasol's emissions inventory capable of running various scenarios for each of the point sources as specified by Sasol, in conjunction with Sasol Technology's Research and Development Department. The intent is to model delta impacts of the various emission scenarios against an acceptable measured airshed baseline.
- 4) Airshed will validate the dispersion model based on a fractional bias approach.
- 5) It is anticipated that each point source identified above will require 3 scenarios per component per point source to be modelled, in order to establish the delta impacts against the DEA-approved baselines. i.e.:
 - a. Baseline – modelling is conducted based on the current inventory and impacts
 - b. Compliance scenarios – modelling must be conducted based on compliance to the legislative requirement as stipulated within the Listed Activities and Minimum Emissions Standards (for both existing plant and new plant standards).

- c. Alternative Emission Limits – the emission reductions as proposed by Sasol, where applicable and different from the baseline and / or compliance emission scenarios.
- 6) Comparison of dispersion modelling results with the National Ambient Air Quality Standards (NAAQS).
- 7) A report detailing the methodology used and model setup was compiled for purposes of a peer review. This report, together with the peer review report and comments from Airshed on the findings, is included as an annexure to this AIR.
- 8) Interactions with the Environmental Assessment Practitioner (EAP) to provide all necessary inputs into the EAP's compilation of documentation in support of Sasol's applications. Airshed will attend all Public Participation meetings scheduled by the EAP to address any queries pertaining to the dispersion model.

The Atmospheric Impact Report (AIR) was prepared in alignment the Regulations Regarding Air Dispersion Modelling following a 'fit for purpose' code of practice (Section 1.2; Government Gazette No. 37804 vol. 589; 11 July 2014). This approach aimed to present sufficient and pertinent information to assist stakeholders to assess the impacts associated with Sasol's applications for postponement of MES compliance timeframes.

Updates made to the AIR following conclusion of the public comment period

The following types of updates have been made to this document following the conclusion of the public comment period:

- updates that address stakeholder comments or queries or provide expanded explanations of key concepts;
- references to changes in regulations, for example the Regulations regarding Air Dispersion Modelling which were promulgated in July 2014; and,
- update cross-references; for example between the AIR and the motivation report.

A detailed list of changes is provided in Table B-1.

Table of Contents

| | | |
|-------|--|----|
| 1 | Enterprise Details | 1 |
| 1.1 | Enterprise Details | 1 |
| 1.2 | Location and Extent of the Plant..... | 2 |
| 1.3 | Atmospheric Emission Licence and other Authorisations..... | 2 |
| 2 | Nature of the Process..... | 3 |
| 2.1 | Listed Activities | 3 |
| 2.2 | Process Description..... | 3 |
| 2.2.1 | Utilities | 4 |
| 2.2.2 | Gas Production | 4 |
| 2.2.3 | Gas Circuit | 5 |
| 2.2.4 | Refining..... | 6 |
| 2.2.5 | Tar, Phenosolvan and Sulfur | 8 |
| 2.2.6 | Water and Ash | 11 |
| 2.3 | Unit Processes | 12 |
| 3 | Technical Information | 24 |
| 3.1 | Raw Materials Used and Production Rates..... | 24 |
| 3.2 | Appliances and Abatement Equipment Control Technology | 25 |
| 4 | Atmospheric Emissions | 26 |
| 4.1 | Point Source Parameters | 26 |
| 4.2 | Point Source Maximum Emission Rates during Normal Operating Conditions | 26 |
| 4.3 | Point Source Maximum Emission Rates during Start-up, Maintenance and/or Shut-down..... | 32 |
| 4.4 | Fugitive Emissions..... | 33 |
| 4.4.1 | Fugitive VOC emissions | 33 |
| 4.4.2 | Dustfall monitoring | 33 |
| 4.5 | Emergency Incidents | 33 |
| 5 | Impact of Enterprise on the Receiving Environment | 35 |
| 5.1 | Analysis of Emissions' Impact on Human Health | 35 |
| 5.1.1 | Study Methodology | 35 |
| 5.1.2 | Legal Requirements..... | 42 |
| 5.1.3 | Regulations regarding Air Dispersion Modelling..... | 44 |
| 5.1.4 | Atmospheric Dispersion Processes | 46 |
| 5.1.5 | Atmospheric Dispersion Potential..... | 51 |
| 5.1.6 | Model Performance | 78 |

| | | |
|-------|--|-----|
| 5.1.7 | Scenario Emission Inventory | 101 |
| 5.1.8 | Model Results | 107 |
| 5.1.9 | Uncertainty of Modelled Results | 149 |
| 5.2 | Analysis of Emissions' Impact on the Environment | 149 |
| 6 | Complaints | 151 |
| 7 | Current or planned air quality management interventions..... | 152 |
| 8 | Compliance and Enforcement Actions | 153 |
| 9 | Additional Information..... | 154 |
| 10 | Annexure A(i) | 157 |
| 11 | Annexure A(ii)..... | 158 |
| 12 | Annexure B(i) | 159 |
| 13 | Annexure B(ii)..... | 160 |
| 14 | References | 161 |
| | APPENDIX A: Competencies for Performing Air Dispersion Modelling | 164 |
| | APPENDIX B: Comparison of Study Approach with the Regulations Prescribing The Format Of The Atmospheric Impact Report and the Regulations Regarding Air Dispersion Modelling (Gazette No 37804 published 11 July 2014) | 166 |
| | APPENDIX C: Raw Materials, Abatement Equipment and Atmospheric Emissions at Sasol Secunda | 171 |
| | APPENDIX D: CALMET Model Control Options | 200 |
| | APPENDIX E: CALPUFF Model Control Options | 201 |
| | APPENDIX F: The NO ₂ /NO _x Conversion Ratios for NO ₂ Formation..... | 204 |
| | APPENDIX G: Time Series Plots for the Measured Ambient Air Quality in the Study Area | 208 |
| | APPENDIX H: Predicted Baseline and Observed Air Concentrations | 214 |
| | APPENDIX I: Daily and Annual Ambient Concentrations | 217 |
| | Sulfur dioxide (SO ₂) | 217 |
| | Nitrogen dioxide (NO ₂)..... | 229 |
| | Particulate matter (PM) | 234 |
| | APPENDIX J: Management of Uncertainties | 240 |
| | Dispersion Model Uncertainties | 240 |
| | Validation of Predictions..... | 241 |
| | Scenario Simulations | 241 |
| | Ambient Monitoring Uncertainty | 241 |
| | Upper Air Meteorological Data | 242 |
| | Emission Inventory Uncertainty..... | 243 |
| | APPENDIX K: Guidance Note on treatment of uncertainties | 245 |

List of Tables

| | |
|--|-----|
| Table 1-1: Enterprise details | 1 |
| Table 1-2: Contact details of responsible person..... | 1 |
| Table 1-3: Location and extent of the plant..... | 2 |
| Table 2-1: Listed activities | 3 |
| Table 2-2: List of unit processes considered listed activities under NEMAQA | 12 |
| Table 2-3: Unit processes at Sasol Secunda..... | 13 |
| Table 3-1: Raw materials used in listed activities seeking postponements | 24 |
| Table 3-2: Appliances and abatement equipment control technology | 25 |
| Table 4-1: Point source parameters..... | 27 |
| Table 4-2: Point source emission rates during normal operating conditions | 28 |
| Table 5-1: Summary description of CALPUFF/CALMET model suite with versions used in the investigation | 42 |
| Table 5-2: National Ambient Air Quality Standards | 43 |
| Table 5-3: Definition of vegetation cover for different developments (US EPA 2005) | 48 |
| Table 5-4: Meteorological parameters provided for the Sasol monitoring stations in the vicinity of Secunda | 51 |
| Table 5-5: Monthly temperature summary (2010 - 2012) | 55 |
| Table 5-6: Summary of the ambient measurements at Bosjesspruit for the period 2010-2012 (units: $\mu\text{g}/\text{m}^3$)..... | 59 |
| Table 5-7: Summary of the ambient measurements at Secunda Club for the period 2010-2012 (units: $\mu\text{g}/\text{m}^3$)..... | 59 |
| Table 5-8: Summary of the ambient measurements at Langverwacht for the period 2010-2012 (units: $\mu\text{g}/\text{m}^3$)..... | 61 |
| Table 5-9: Comparison of predicted and observed SO_2 concentrations at Bosjesspruit monitoring station in Secunda | 94 |
| Table 5-10: Comparison of predicted and observed SO_2 concentrations at Secunda Club monitoring station in Secunda | 94 |
| Table 5-11: Comparison of predicted and observed SO_2 concentrations at Langverwacht monitoring station in Secunda | 95 |
| Table 5-12: Estimated SO_2 background concentrations for Bosjesspruit, Secunda Club and Langverwacht | 95 |
| Table 5-13: Comparison of predicted and observed NO_2 concentrations at Bosjesspruit monitoring station in Secunda..... | 97 |
| Table 5-14: Comparison of predicted and observed NO_2 concentrations at Secunda Club monitoring station in Secunda..... | 97 |
| Table 5-15: Comparison of predicted and observed NO_2 concentrations at Langverwacht monitoring station in Secunda | 97 |
| Table 5-16: Estimated NO_2 background concentrations for Bosjesspruit, Secunda Club and Langverwacht | 98 |
| Table 5-17: Comparison of predicted and observed H_2S concentrations at Bosjesspruit monitoring station in Secunda | 99 |
| Table 5-18: Comparison of predicted and observed H_2S concentrations at Secunda Club monitoring station in Secunda | 99 |
| Table 5-19: Comparison of predicted and observed H_2S concentrations at Langverwacht monitoring station in Secunda .. | 100 |
| Table 5-20: Estimated H_2S background concentrations for Bosjesspruit, Secunda Club and Langverwacht | 100 |
| Table 5-21: Source parameters per scenario provided for Sasol Secunda facility | 101 |
| Table 5-22: Source emissions per scenario provided for Sasol Secunda facility | 104 |
| Table 5-23: Receptors identified for assessment of impact as a result of Secunda operations | 108 |
| Table 5-24: Estimated background concentrations of SO_2 , NO_2 and PM_{10} for use in predicted concentration changes between scenarios | 109 |
| Table 5-25: Predicted 99th percentile daily PM_{10} and total PM concentration at identified receptors for Synfuels Steam Stations | 128 |
| Table 5-26: Most stringent health-effect screening level identified for all non-criteria pollutants assessed..... | 131 |
| Table 5-27: Screening of non-criteria pollutants against health effect screening levels | 132 |
| Table 5-28: Predicted hourly ambient concentrations ($\mu\text{g}/\text{m}^3$) of metal pollutants emitted from the Sasol Synfuels Facility Incinerators (a)..... | 133 |
| Table 5-29: Predicted annual ambient concentrations ($\mu\text{g}/\text{m}^3$) of metal pollutants emitted from the Sasol Secunda Facility Incinerators (a)..... | 137 |

| | |
|---|-----|
| Table A-1: Competencies for Performing Air Dispersion Modelling | 164 |
| Table B-1: Comparison of Regulations for the AIR with study approach | 166 |
| Table B-2: Comparison of Regulations regarding Air Dispersion Modelling with study approach | 168 |
| Table C1-1: Raw materials used at Sasol Secunda | 171 |
| Table C1-2: All appliances and abatement equipment used on unit processes at the Sasol Secunda complex..... | 177 |
| Table C2-3: Point source parameters | 178 |
| Table C2-4: Tank sources for the Sasol Oil business unit | 186 |
| Table C2-5: Point source emission rates during normal operating conditions | 189 |
| Table D-1: CALMET model control options | 200 |
| Table E-1: CALPUFF model control options | 201 |
| Table F-1: NO ₂ /NO _x conversation ratios for NO ₂ formation..... | 206 |
| Table H-1: Predicted and observed SO ₂ concentration statistics | 214 |
| Table H-2: Predicted and observed NO ₂ concentration statistics | 215 |
| Table H-3: Predicted and observed H ₂ S concentration statistics | 216 |
| Table K-1: Likelihood scale..... | 246 |

List of Figures

| | |
|---|----|
| Figure 5-1: The basic study methodology followed for the assessment | 38 |
| Figure 5-2: Schematic displaying how the dispersion modelling scenarios are presented, for each receptor point in the modelling domain | 40 |
| Figure 5-3: Plume buoyancy | 47 |
| Figure 5-4: Period, day- and night-time wind rose for Langverwacht for the period 2010 - 2012 | 52 |
| Figure 5-5: Period, day- and night-time wind rose for Bosjesspruit for the period 2010 - 2012 | 53 |
| Figure 5-6: Period, day- and night-time wind rose for Secunda Club for the period 2010 - 2012 | 53 |
| Figure 5-7: Period, day- and night-time wind rose for an extracted CALMET point at Secunda Club for the period 2010 - 2012 | 54 |
| Figure 5-8: Monthly average temperature profile for Langverwacht (2010 – 2012) | 55 |
| Figure 5-9: Monthly average temperature profile for Bosjesspruit (2010 – 2012) | 56 |
| Figure 5-10: Monthly average temperature profile for Secunda Club (2010 – 2012) | 56 |
| Figure 5-11: Diurnal atmospheric stability (extracted from CALMET at the Secunda Club monitoring point) | 58 |
| Figure 5-12: Observed hourly average SO ₂ concentrations at Bosjesspruit | 62 |
| Figure 5-13: Observed daily average SO ₂ concentrations at Bosjesspruit | 63 |
| Figure 5-14: Observed hourly average SO ₂ concentrations at Secunda Club | 63 |
| Figure 5-15: Observed daily average SO ₂ concentrations at Secunda Club | 64 |
| Figure 5-16: Observed hourly average SO ₂ concentrations at Langverwacht | 64 |
| Figure 5-17: Observed daily average SO ₂ concentrations at Langverwacht | 65 |
| Figure 5-18: Observed hourly average NO ₂ concentrations at Bosjesspruit | 66 |
| Figure 5-19: Observed hourly average NO ₂ concentrations at Secunda Club | 66 |
| Figure 5-20: Observed hourly average NO ₂ concentrations at Langverwacht | 67 |
| Figure 5-21: Observed daily average PM ₁₀ concentrations at Secunda Club | 68 |
| Figure 5-22: Observed daily average PM ₁₀ concentrations at Langverwacht | 68 |
| Figure 5-23: Time series plot of observed SO ₂ and NO ₂ concentrations at Bosjesspruit (shaded area indicates 95 th percentile confidence interval) | 70 |
| Figure 5-24: Time series plot of normalised observed H ₂ S concentrations at Bosjesspruit (shaded area indicates 95 th percentile confidence interval) | 71 |
| Figure 5-25: Time series plot of normalised observed SO ₂ and NO ₂ concentrations at Secunda Club (shaded area indicates 95 th percentile confidence interval) | 72 |
| Figure 5-26: Time series plot of normalised observed H ₂ S concentrations at Secunda Club (shaded area indicates 95 th percentile confidence interval) | 73 |
| Figure 5-27: Time series plot of normalised observed PM ₁₀ concentrations at Secunda Club (shaded area indicates 95 th percentile confidence interval) | 74 |
| Figure 5-28: Time series plot of normalised observed benzene concentrations at Secunda Club (shaded area indicates 95 th percentile confidence interval) | 74 |
| Figure 5-29: Time series plot of normalised observed SO ₂ and NO ₂ concentrations at Langverwacht (shaded area indicates 95 th percentile confidence interval) | 75 |
| Figure 5-30: Time series plot of normalised observed H ₂ S concentrations at Langverwacht (shaded area indicates 95 th percentile confidence interval) | 76 |
| Figure 5-31: Time series plot of normalised observed PM ₁₀ concentrations at Langverwacht (shaded area indicates 95 th percentile confidence interval) | 77 |

| | |
|---|-----|
| Figure 5-32: Time series plot of normalised observed benzene concentrations at Langverwacht (shaded area indicates 95 th percentile confidence interval) | 77 |
| Figure 5-33: Polar plot of hourly median NO ₂ concentration observations at Bosjesspruit for 2010 to 2012 | 80 |
| Figure 5-34: Polar plot of hourly median SO ₂ concentration observations at Bosjesspruit for 2010 to 2012..... | 81 |
| Figure 5-35: Polar plot of hourly median H ₂ S concentration observations at Bosjesspruit for 2010 to 2012..... | 82 |
| Figure 5-36: Polar plot of hourly median NO ₂ concentration observations at Secunda Club for 2010 to 2012 | 83 |
| Figure 5-37: Polar plot of hourly median SO ₂ concentration observations at Secunda Club for 2010 to 2012 | 84 |
| Figure 5-38: Polar plot of hourly median PM ₁₀ concentration observations at Secunda Club for 2010 to 2012 | 85 |
| Figure 5-39: Polar plot of hourly median H ₂ S concentration observations at Secunda Club for 2010 to 2012..... | 86 |
| Figure 5-40: Polar plot of hourly median benzene concentration observations at Secunda Club for 2010 to 2012 | 87 |
| Figure 5-41: Polar plot of hourly median NO ₂ concentration observations at Langverwacht for 2010 to 2012 | 88 |
| Figure 5-42: Polar plot of hourly median SO ₂ concentration observations at Langverwacht for 2010 to 2012..... | 89 |
| Figure 5-43: Polar plot of hourly median PM ₁₀ concentration observations at Langverwacht for 2010 to 2012 | 90 |
| Figure 5-44: Polar plot of hourly median H ₂ S concentration observations at Langverwacht for 2010 to 2012..... | 91 |
| Figure 5-45: Polar plot of hourly median benzene concentration observations at Langverwacht for 2010 to 2012 | 92 |
| Figure 5-46: Fractional bias of means and standard deviation for SO ₂ | 96 |
| Figure 5-47: Fractional bias of means and standard deviation for NO ₂ | 98 |
| Figure 5-48: Fractional bias of means and standard deviation for H ₂ S | 101 |
| Figure 5-49: Receptors identified for assessment of impact as a result of Secunda operations | 107 |
| Figure 5-50: Predicted 99 th percentile hourly SO ₂ concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 110 |
| Figure 5-51: Predicted 99 th percentile hourly SO ₂ concentration at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 111 |
| Figure 5-52: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1) | 111 |
| Figure 5-53: Predicted 99 th percentile hourly SO ₂ concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 112 |
| Figure 5-54: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Sunfuels Biosludge Incinerators (change calculated using Equation 1)..... | 113 |
| Figure 5-55: Predicted 99 th percentile hourly SO ₂ concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 113 |
| Figure 5-56: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (change calculated using Equation 1) | 114 |
| Figure 5-57: Predicted 99 th percentile hourly SO ₂ concentration at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 114 |
| Figure 5-58: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (change calculated using Equation 1) | 115 |
| Figure 5-59: Predicted 99 th percentile SO ₂ concentrations as a result of Baseline emissions from the Steam Stations | 115 |
| Figure 5-60: Predicted 99 th percentile SO ₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations | 116 |
| Figure 5-61: Predicted 99 th percentile hourly NO ₂ concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 117 |
| Figure 5-62: Predicted 99 th percentile hourly NO ₂ concentration at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 117 |
| Figure 5-63: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at identified receptors for Synfuels Steam Stations (change calculated using Equation 1) | 118 |

| | |
|--|-----|
| Figure 5-64: Predicted 99 th percentile NO ₂ concentrations as a result of Baseline emissions from the Steam Stations | 118 |
| Figure 5-65: Predicted 99 th percentile NO ₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations | 119 |
| Figure 5-66: Predicted 99 th percentile hourly NO ₂ concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 119 |
| Figure 5-67: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1) | 120 |
| Figure 5-68: Predicted 99 th percentile hourly NO ₂ concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 120 |
| Figure 5-69: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1) | 121 |
| Figure 5-70: Predicted 99 th percentile daily PM concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 122 |
| Figure 5-71: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1) | 122 |
| Figure 5-72: Predicted 99 th percentile daily PM concentrations as a result of Baseline emissions from the Steam Stations | 123 |
| Figure 5-73: Predicted 99 th percentile daily PM concentrations as a result of Alternative Emission Limit emissions from the Steam Stations | 123 |
| Figure 5-74: Predicted 99 th percentile daily PM concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 124 |
| Figure 5-75: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (change calculated using Equation 1) | 124 |
| Figure 5-76: Predicted 99 th percentile daily PM concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 125 |
| Figure 5-77: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (change calculated using Equation 1) | 125 |
| Figure 5-78: Predicted 99 th percentile daily PM concentrations at identified receptors for Synfuels SCC (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 126 |
| Figure 5-79: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels SCC (change calculated using Equation 1) | 127 |
| Figure 5-80: Predicted 99 th percentile daily PM ₁₀ concentrations as a result of Baseline Emission Limit emissions from the Catalytic Cracker | 127 |
| Figure 5-81: Predicted 99 th percentile daily PM ₁₀ concentrations as a result of Alternative Emission Limit emissions from the Catalytic Cracker | 128 |
| Figure 5-82: Predicted annual average TVOC concentrations at identified receptors for Synfuels Rectisol (relative to the annual NAAQS for benzene) | 129 |
| Figure 5-83: Predicted annual average TVOC concentrations at identified receptors for Synfuels Rectisol (relative to the annual NAAQS for benzene) (Based on Figure 82 with the y-axis rescaled for visibility) | 130 |
| Figure 5-84: Predicted 99.9 th percentile daily H ₂ S concentrations at identified receptors for Synfuels Sulfur Recover Plant compared against WHO (2000) guideline (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 141 |
| Figure 5-85: Theoretical change in H ₂ S concentrations between scenarios and the airshed baseline at the identified receptors for the Synfuels Sulfur Recovery Plant (change calculated using Equation 1) | 142 |
| Figure 5-86: Predicted 99 th percentile daily H ₂ S concentrations as a result of Baseline emissions from the Sulfur Recovery Plant | 142 |

| | |
|--|-----|
| Figure 5-87: Predicted 99 th percentile daily H ₂ S concentrations as a result of Alternative Emission Limit emissions from the Sulfur Recovery Plant | 143 |
| Figure 5-88: Predicted 99.9 th percentile H ₂ S concentrations at identified receptors for Synfuels Sulfur Recovery Plant compared against Haahtele <i>et al.</i> (1992) guideline (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 144 |
| Figure 5-89: Theoretical change in H ₂ S concentrations between scenarios and the airshed baseline at the identified receptors for Sulfur Recovery Plant (change calculated using Equation 1)..... | 144 |
| Figure 5-90: Predicted 99 th percentile 4-hourly H ₂ S concentrations as a result of Baseline emissions from the Sulfur Recovery Plant..... | 145 |
| Figure 5-91: Predicted 99 th percentile 4-hourly H ₂ S concentrations as a result of Alternative Emission Limit emissions from the Sulfur Recovery Plant | 145 |
| Figure 5-92: Predicted hourly acid mist (SO ₃ and H ₂ SO ₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant..... | 146 |
| Figure 5-93: Predicted hourly acid mist (SO ₃ and H ₂ SO ₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (in relation to the ASTDR (1999) hourly guideline) (Based on Figure 92 with y-axis rescaled for clarity) | 147 |
| Figure 5-94: Predicted annual acid mist (SO ₃ and H ₂ SO ₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant..... | 148 |
| Figure 5-95: Predicted annual acid mist (SO ₃ and H ₂ SO ₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (in relation to the OEHHA (2008) chronic REL) | 148 |
| Figure C3-1: Dustfall rates at Site 5 (Game Park) between May 2012 and Apr 2013 | 196 |
| Figure C3-2: Dustfall rates at Site 6 (Halwe Pan Dam) between May 2012 and Apr 2013 | 197 |
| Figure C3-3: Dustfall rates at Site 7 (RESM 3) between May 2012 and Apr 2013 | 197 |
| Figure C3-4: Dustfall rates at Site 8 (Langverwacht) between May 2012 and Apr 2013 | 198 |
| Figure C3-5: Dustfall rates at Site 9 (RESM 9) between May 2012 and Apr 2013 | 198 |
| Figure C3-6: Dustfall rates at Site 10 (Pump Station) between May 2012 and Apr 2013..... | 199 |
| Figure C3-7: Dustfall rates at Site 11 (SCS) between May 2012 and Apr 2013 | 199 |
| Figure F-1: Comparison of observed with predicted NO ₂ concentrations (Long Island, NY) using the derived short-term NO ₂ /NO _x ratios (Scire and Borissova, 2011)..... | 204 |
| Figure F-2: Comparison of observed with predicted NO ₂ concentrations (Chicago, IL) using the derived short-term NO ₂ /NO _x ratios (Scire and Borissova, 2011)..... | 205 |
| Figure F-3: Observed versus predicted NO ₂ concentrations (Bahrain) using the derived short-term NO ₂ /NO _x ratios (Scire and Borissova, 2011) | 205 |
| Figure F-4: NO ₂ /NO _x conversation ratios for Secunda monitoring stations..... | 207 |
| Figure G-1: Summary of meteorological data received for Bosjesspruit (2010-2012)..... | 208 |
| Figure G2: Summary of ambient data received for Bosjesspruit (2010-2012)..... | 209 |
| Figure G-3: Summary of meteorological data received for Secunda Club (2010-2012)..... | 210 |
| Figure G-4: Summary of ambient data received for Secunda Club (2010-2012)..... | 211 |
| Figure G-5: Summary of daily PM data received for Secunda Club (2010-2012)..... | 211 |
| Figure G-6: Summary of meteorological data received for Langverwacht (2010-2012) | 212 |
| Figure G-7: Summary of ambient data received for Langverwacht (2010-2012)..... | 213 |
| Figure G-8: Summary of daily PM data received for Langverwacht (2010-2012)..... | 213 |
| Figure I-1: Predicted 99 th percentile daily SO ₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 217 |
| Figure I-2: Predicted 99 th percentile daily SO ₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 218 |

| | |
|---|-----|
| Figure I-3: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1) | 218 |
| Figure I-4: Predicted 99 th percentile daily SO ₂ concentrations as a result of Baseline emissions from the Steam Stations.. | 219 |
| Figure I-5: Predicted 99 th percentile daily SO ₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations..... | 219 |
| Figure I-6: Predicted 99 th percentile daily SO ₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 220 |
| Figure I-7: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (change calculated using Equation 1) | 220 |
| Figure I-8: Predicted 99 th percentile daily SO ₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 221 |
| Figure I-9: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1) | 221 |
| Figure I-10: Predicted 99 th percentile daily SO ₂ concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 222 |
| Figure I-11: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (calculated using Equation 1) | 222 |
| Figure I-12: Predicted annual SO ₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 223 |
| Figure I-13: Predicted annual SO ₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 224 |
| Figure I-14: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (calculated using Equation 1) | 224 |
| Figure I-15: Predicted annual SO ₂ concentrations as a result of Baseline emissions from the Steam Stations..... | 225 |
| Figure I-16: Predicted annual SO ₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations | 225 |
| Figure I-17: Predicted annual SO ₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 226 |
| Figure I-18: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1) | 226 |
| Figure I-19: Predicted annual SO ₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 227 |
| Figure I-20: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1) | 227 |
| Figure I-21: Predicted annual SO ₂ concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 228 |
| Figure I-22: Theoretical change in SO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (calculated using Equation 1) | 228 |
| Figure I-23: Predicted annual NO ₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 229 |
| Figure I-24: Predicted annual NO ₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49)..... | 230 |
| Figure I-25: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Secunda Steam Stations (calculated using Equation 1)..... | 230 |
| Figure I-26: Predicted annual NO ₂ concentrations as a result of Baseline emissions from the Steam Stations | 231 |

| | |
|--|-----|
| Figure I-27: Predicted annual NO ₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations | 231 |
| Figure I-28: Predicted annual NO ₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 232 |
| Figure I-29: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1) | 232 |
| Figure I-30: Predicted annual NO ₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 233 |
| Figure I-31: Theoretical change in NO ₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1) | 233 |
| Figure I-32: Predicted annual PM concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 234 |
| Figure I-33: Predicted annual PM concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 235 |
| Figure I-34: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (calculated using Equation 1) | 235 |
| Figure I-35: Predicted annual NO ₂ concentrations as a result of Baseline emissions from the Steam Stations | 236 |
| Figure I-36: Predicted annual NO ₂ concentrations as a result of Alternative Emission Limits emissions from the Steam Stations | 236 |
| Figure I-37: Predicted annual PM concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 237 |
| Figure I-38: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1) | 237 |
| Figure I-39: Predicted annual PM concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 238 |
| Figure I-40: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1) | 238 |
| Figure I-41: Predicted PM concentrations at identified receptors for Synfuels SCC (receptor code names as detailed in Table 5-23, where locations are shown in Figure 49) | 239 |
| Figure I-42: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels SCC (calculated using Equation 1) | 239 |
| Figure K-1: A depiction of evidence and agreement statements and their relationship to confidence. Confidence increases towards the top-right corner as suggested by the increasing strength of shading. Generally, evidence is most robust when there are multiple, consistent independent lines of high-quality evidence. | 245 |

List of Abbreviations

| | |
|------------------------|---|
| AQA | Air quality act |
| APCS | Air pollution control systems |
| ARM | Ambient Ratio Method |
| As | Arsenic |
| ASG | Atmospheric Studies Group |
| Cd | Cadmium |
| Co | Cobalt |
| CO | Carbon monoxide |
| CO₂ | Carbon dioxide |
| Cr | Chromium |
| Cu | Copper |
| DEA | Department of Environmental Affairs |
| ESP | Electro static precipitator |
| g | Gram |
| g/s | Gram per second |
| FDG | Flue-gas desulfurisation |
| HCl | Hydrogen chloride |
| Hg | Mercury |
| HNO₃ | Nitric acid |
| HF | Hydrogen fluoride |
| IPCC | Intergovernmental Panel on Climate Change |
| LMO | Monin-Obukhov length |
| m | Meter |
| m² | Meter squared |
| m³ | Meter cubed |
| MIBK | Methyl isobutyl ketone |
| m/s | Meters per second |
| Mn | Manganese |
| NAAQ Limit | National Ambient Air Quality Limit concentration |
| NAAQS | National Ambient Air Quality Standards (as a combination of the NAAQ Limit and the allowable frequency of exceedance) |
| NEMAQA | National Environmental Management Air Quality Act |
| NH₃ | Ammonia |
| Ni | Nickel |
| NO | Nitrogen oxide |
| NO₂ | Nitrogen dioxide |
| NO_x | Oxides of nitrogen |
| O₃ | Ozone |
| OLM | Ozone Limiting Method |
| PBL | Planetary boundary layer |
| Pb | Lead |
| PM | Particulate matter |
| PM₁₀ | Particulate matter with diameter of less than 10 µm |

| | |
|-------------------------|--|
| PM_{2.5} | Particulate matter with diameter of less than 2.5 µm |
| REL | Reference Exposure Limit |
| Sb | Antimony |
| SO₂ | Sulfur dioxide |
| SO₃ | Sulfur trioxide |
| SS1 | Steam station 1 |
| SS2 | Steam station 2 |
| TI | Thalium |
| US EPA | United States Environmental Protection Agency |
| USGS | United States Geological Survey |
| V | Vanadium |
| VOC | Volatile organic concentrations |
| µ | micro |
| °C | Degrees celcius |

Glossary

| | |
|-------------------------------------|---|
| Advection | Transport of pollutants by the wind |
| Airshed | An area, bounded by topographical features, within which airborne contaminants can be retained for an extended period |
| Algorithm | A mathematical process or set of rules used for calculation or problem-solving, which is usually undertaken by a computer |
| Alternative Emission Limit | Ceiling or maximum emission limit requested by Sasol, with which it commits to comply |
| Assessment of environmental effects | A piece of expert advice submitted to regulators to support a claim that adverse effects will or will not occur as a result of an action, and usually developed in accordance with section 88 of the Resource Management Act 1991 |
| Atmospheric chemistry | The chemical changes that gases and particulates undergo after they are discharged from a source |
| Atmospheric dispersion model | A mathematical representation of the physics governing the dispersion of pollutants in the atmosphere |
| Atmospheric stability | A measure of the propensity for vertical motion in the atmosphere |
| Building wakes | Strong turbulence and downward mixing caused by a negative pressure zone on the lee side of a building |
| Calm / stagnation | A period when wind speeds of less than 0.5 m/s persist |
| Cartesian grid | A co-ordinate system whose axes are straight lines intersecting at right angles |
| Causality | The relationship between cause and effect |
| Complex terrain | Terrain that contains features that cause deviations in direction and turbulence from larger-scale wind flows |
| Configuring a model | Setting the parameters within a model to perform the desired task |
| Convection | Vertical movement of air generated by surface heating |
| Convective boundary layer | The layer of the atmosphere containing convective air movements |
| Data assimilation | The use of observations to improve model results – commonly carried out in meteorological modelling |
| Default setting | The standard (sometimes recommended) operating value of a model parameter |
| Diagnostic wind model (DWM) | A model that extrapolates a limited amount of current wind data to a 3-D grid for the current time. It is the ‘now’ aspect, and makes the model ‘diagnostic’. |
| Diffusion | Clean air mixing with contaminated air through the process of molecular motion. Diffusion is a very slow process compared to turbulent mixing. |
| Dispersion | The lowering of the concentration of pollutants by the combined processes of advection and diffusion |
| Dispersion coefficients | Variables that describe the lateral and vertical spread of a plume or a puff |
| Dry deposition | Removal of pollutants by deposition on the surface. Many different processes (including gravity) cause this effect. |
| Sasol Synfuels | Sasol Chemical Industries (Pty) Limited operating through its Secunda Synfuels Operations, formerly Sasol Synfuels (Pty) Limited. To avoid unnecessary confusion, the name “Sasol Synfuels” has been retained in this report. |

Atmospheric Impact Report

1 ENTERPRISE DETAILS

1.1 Enterprise Details

The details of Secunda Complex operations are summarised in Table 1-1. The contact details of the responsible person, the emission control officer, are provided in Table 1-2.

Table 1-1: Enterprise details

| | |
|--|--|
| Enterprise Name | Sasol Synfuels (Pty) Ltd |
| Trading as | Sasol Synfuels |
| Type of Enterprise | 1979/002735/07 |
| Company Registration Number | Synfuels Road Sasol Synfuels Secunda 2302 |
| Registered Address | Private Bag X1000 Secunda 2302 |
| Telephone Number (General) | 017 610 2627 |
| Fax Number (General) | |
| Company Website | www.sasol.com |
| Industry Type/Nature of Trade | Petrochemical industry |
| Land Use Zoning as per Town Planning Scheme | Industrial |
| Land Use Rights if Outside Town Planning Scheme | n/a |

Table 1-2: Contact details of responsible person

| | |
|--|--|
| Responsible Person Name: | Estelle Marais |
| Responsible Person Post: | Senior Manager SHE: Environment – Air quality and greenhouse gas |
| Telephone Number: | 017 610 2895 |
| Cell Phone Number: | 079 509 9011 |
| Fax Number: | 017 610 4090 |
| E-mail Address: | Estelle.marais@sasol.com |
| After Hours Contact Details: | 079 509 9011 |
| Name of VP SHE Secunda Synfuels Operations: | Simon van Renssen |

1.2 Location and Extent of the Plant

Table 1-3: Location and extent of the plant

| | |
|--|---|
| Physical Address of the Plant | Synfuels Road Sasol Synfuels Secunda, 2302 |
| Description of Site (Where no Street Address) | Highveld Ridge Mpumalanga |
| Coordinates of Approximate Centre of Operations | The geographical co-ordinates have been excluded for security reasons but will be made available to the DEA under confidentiality arrangements. |
| Extent | 24.05 km ² |
| Elevation Above Sea Level | 1 597m |
| Province | Mpumalanga |
| Metropolitan/District Municipality | Gert Sibande District Municipality |
| Local Municipality | Govan Mbeki Local Municipality |
| Designated Priority Area | Highveld Priority Area |

1.3 Atmospheric Emission Licence and other Authorisations

The following licences related to air quality management are applicable:

- Atmospheric Emission License:
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd 0016/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd operating through its Secunda Synfuels Operations
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd 0018/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd through its Secunda Chemical Operations (LOC)
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd Sasol Oil/0019/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd Sasol Oil
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd 0017/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd through the Secunda Chemical Operations (Solvents) (not affected)
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd Sasol Nitro 0020/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd Sasol Chemical Operations (Nitro) – not affected
 - Licence no. Govan Mbeki/Sasol Chemical Industries (Pty) Ltd 0021/2014/F01 27 March 2014 issued to Sasol Chemical Industries (Pty) Ltd through Secunda Chemical Operations (Polymers) (not affected)
- Other: None

2 NATURE OF THE PROCESS

2.1 Listed Activities

A summary of listed activities currently undertaken at Secunda Complex is provided in Table 2-1.

Table 2-1: Listed activities

| Category of Listed Activity | Sub-category of the Listed Activity | Listed Activity name | Description of the Listed Activity |
|-----------------------------|-------------------------------------|--|---|
| 1 | 1.1 | Solid Fuel Combustion installations | Solid fuels combustion installations used primarily for steam raising or electricity generation |
| | 1.4 | Gas Combustion Installations | Gas combustion (including gas turbines burning natural gas) used primarily for steam raising or electricity generation |
| 2 | 2.1 | Combustion installation | Combustion installation not used primarily for steam raising or electricity generation (furnaces and heaters) |
| | 2.2 | Catalytic cracking | Refinery catalytic cracking units |
| 3 | 3.3 | Tar processes | Processes in which tar, creosote or any other product of distillation of tar is distilled or is heated in any manufacturing process |
| | 3.6 | Synthetic gas production and clean up | The production and clean-up of a gaseous stream derived from coal gasification and includes gasification, separation and clean-up of a raw gas stream through a process that involves sulfur removal and Rectisol as well as the stripping of a liquid tar stream derived from the gasification process |
| 4 | 4.2 | Combustion installation | Combustion installation not used primarily for steam raising and electricity generation (except drying) |
| | 4.7 | Electric Arc Furnaces | Electric arc furnaces in the steel making industry |
| 5 | 5.1 | Storage and handling of ore and coal | Storage and handling of ore and coal not situated on the premises of a mine or works as defined in the Mines Health and Safety Act 29/1996 |
| 6 | 6 | Organic Chemical Industry | The production or use in production of organic chemicals not specified elsewhere including acetylene, acetic, maleic or phthalic anhydride or their acids, carbon disulphide, pyridine, formaldehyde, acetaldehyde, acrolein and its derivatives, amines and synthetic rubber. |
| 7 | 7.1 | Production and or use in manufacturing of ammonia, fluorine, fluorine compounds, chlorine and hydrogen cyanide | Production and or use in manufacturing of ammonia, fluorine, fluorine compounds, chlorine and hydrogen cyanide and chlorine gas (excluding metallurgical processes related activities regulated under category 4) |
| | 7.2 | Production of acids | Production, bulk handling and or use of Sulfuric acid in concentration exceeding 10 % |
| 8 | 8.1 | Thermal treatment of General and Hazardous Waste | Facilities where general and hazardous waste are treated by the application of heat |
| | 8.3 | Burning Grounds | |

2.2 Process Description

A description on the process units operating at Sasol Synfuels complex is provided below. Further information is contained in the motivation reports.

2.2.1 Utilities

2.2.1.1 Steam Plant

Steam is used in various processes throughout the factory and for generating electricity. The Steam plant generates steam from 17 boilers using fine coal and boiler feed water. Electricity is generated by means of 10 steam driven turbine generators.

Steam Plant (Unit 43 /243) supplies process steam for the Gasification process, as well as drive steam for the turbines at Synthol and Oxygen East. Make-up steam is let down to satisfy deficits on the MP and LP factory steam headers. The balance of the steam produced is used to generate electricity.

U43 and 243 both have eight Babcock boilers, while U243 has a ninth boiler built by ICAL. Electricity is generated in turbo-generator sets rated at 60MWe. There are 6 and 4 turbo-generators at both Unit 43 and Unit 243 respectively, resulting in combined generation capacity of 600MWe.

The operating philosophy of steam plant is such that the steam header pressure control is done by manipulating the boilers and turbo generator load.

2.2.1.2 Gas Turbines

Two gas turbines provide additional electricity generating capacity. Natural gas from Mozambique and Methane Rich Gas (MRG) from Cold Separation (Gas Circuit) are used as the feed streams.

The open cycle gas turbine (OCGT) power plant consists of 2 x GE PG9171 (E) gas turbine generators and associated plant. The nominal output from each gas turbine is approximately 104MW. The gas turbines utilise natural gas as fuel. The exhaust gas from the gas turbines is used to generate high pressure steam in Heat Recovery Steam Generator (HRSG). Each gas turbine have its own boiler (HRSG) with supporting boiler feed water pre-conditioning equipment as well as own blow down equipment. Each HRSG is at 163t/h MCR 40 bar (g) steam production.

There are two gas turbine (GT) trains which are operated independently in parallel. Each GT train has a maximum operating generation capacity of 104 MW during summer months and 110 – 118 MW during winter months. The GTs has a design generation capacity of 118 MW. The Gas Turbines supply electricity into the Eskom grid.

2.2.2 Gas Production

2.2.2.1 Coal processing

Coal is conveyed from Sasol Coal Supply (SCS) to Coal Processing (Unit 01 / 201) where it gets screened. The coarse fraction (oversize material) is conveyed to Coal Distribution (Unit 02 / 202) from where it is transferred via conveyer belts to tripper cars to fill the different bunkers of the gasifiers. The smaller fraction (undersized material) is transferred by means of gravity for dewatering purposes. The oversized material from the screens is transferred to a centrifuge where further dewatering takes place. The undersized material from the screens are transferred in a slurry launder to the thickener system where flocculent is added to aid in the settling of the coal particles. The underflow of the thickeners is pumped to the filter section where the slurry is dewatered by means of vacuum filtration. The filter cake is removed from the filter cloth with the aid of a compressed air cycle. The filter cake and centrifuge product combine to be used as feed to the Steam Plant (Unit 43 / 243).

2.2.2.2 *Gasification and Raw Gas Cooling*

84 Sasol® FBDB™ gasifiers (42 gasifiers at each unit, 10 and 210), are used to gasify coarse coal using high pressure superheated steam and oxygen. The Sasol® FBDB™ gasifier is a commercially proven process for the conversion of coal feedstock into synthesis gas. In this process, the following streams are formed:

- Raw gas which is transferred to Raw Gas Cooling and then to Rectisol for further purification
- Ash as a waste stream that is processed by the Inside Ash
- Gas Liquor (a water stream) is transferred to Gas Liquor Separation to separate tars, oils and solids from the aqueous phase.

Wet gasification coal (the coarse fraction) is sent to the coal storage at the top of each gasifier. Coal is loaded to each gasifier using batch operated coal locks. Inside the gasifiers, coal reacts with steam and oxygen mixture producing crude (raw) gas containing hydrogen, carbon dioxide, carbon monoxide, methane, steam, as well as small concentrations of hydrocarbons, tars, oils, phenols, ammonia and many more.

Hot gas leaving the gasifiers is quenched to remove solids and heavy tars and then cooled in heat exchangers at Raw Gas Cooling (units 11 & 211) before it is sent to Rectisol for further purification.

During gasification process, mineral matter contained in coal is oxidised and ash is produced. The ash is intermittently removed from the bottom of the gasifier via an automatically operated ash lock hopper, quenched with water and sent to Inside Ash unit for processing and disposal.

The gas liquor containing dissolved oil, phenols, tar acids, organic acids and ammonia, is worked-up in the Gas Liquor Separation, Phenosolvan, Ammonia Recovery and biological Water Recovery effluent treatment plants, before it is used as make-up water to the process cooling towers.

2.2.2.3 *Rectisol*

The main function of Rectisol is to remove acid gases, such as CO₂ and H₂S, together with other impurities from the raw gas produced by Gasification. The resulting cleaned gas, called pure gas, is the feedstock to the Synthol plant.

The CO₂ and H₂S-containing off gas streams are routed to Sulfur plant and Wet Sulfuric Acid for further processing.

2.2.3 *Gas Circuit*

2.2.3.1 *Benfield*

Tail Gas from Synthol (gas synthesis section) passes through a knock-out drum and a filter coalescer to remove any liquid droplets from the feed gas. The gas is then heated by heat exchange with hot potassium carbonate solution and enters the absorber column. CO₂ is absorbed from the gas stream into the potassium carbonate absorption medium. The cleaned gas then passes through a knock-out drum into the DEA system, which acts as a CO₂ removal polishing unit. The sweetened gas then passes through a cryogenic separation unit called Cold Separation.

The rich (loaded with CO₂) potassium carbonate solution is regenerated by flashing the solution and by reboil in the regeneration column. The CO₂ and steam mixture is released to atmosphere and the lean potassium carbonate is re-circulated to the absorber column. A similar recycle and regeneration process is used in the DEA system. The CO₂ and steam stripped from the DEA solution, joins the carbonate regeneration column and is released to atmosphere. Condensate is added to both regeneration columns (carbonate and DEA) to make up for the water lost to atmosphere.

2.2.3.2 *Catalyst Manufacturing and Catalyst Reduction*

The Synthol (SAS) reactors are based on high temperature Fischer – Tropsch technology and uses catalyst. The catalyst is manufactured at the Catalyst Manufacturing units.

The catalyst manufacturing units are exactly similar except that the East unit has two rotary kilns and two electric arc furnaces compared to only one of each piece of equipment at the West unit. Both units have only one ball mill circuit.

The required raw material is fed to the rotary kiln. The objective of the kiln is to burn off oily contaminants evaporate moisture and to produce the required catalyst.

2.2.4 *Refining*

2.2.4.1 *Tar distillation units (UNIT 14/214)*

The purpose of this unit is to fractionate crude tar, originating from Gasification, into different fractions, which is then used as feed for downstream units. These fractions (from low to high boiling point) include light naphtha, heavy naphtha, medium creosote, heavy creosote, residue oil and pitch.

2.2.4.2 *Unit 27A*

The purpose of Unit 27A is to remove the neutral oils contained in the HNO-DTA (high neutral oil depitched tar acids) feed, producing LNO-DTA (low neutral oil depitched tar acids). Unit 27A is the final processing step in the Tar Acid Value Chain (TAVC) on the Secunda site. The LNO-DTA consists mainly of phenols, cresols and xylenols) that are extracted from the gas liquor stream at Phenosolvan into crude tar acids (CTA), from where the majority of pitch is removed in the Primary Depitchers where the distillate product HNO-DTA is sent to Unit 27A.

2.2.4.3 *Unit 74*

The CTA feed stream to the Primary Depitcher at Phenosolvan is split into the side draw, HNO-DTA stream going to Unit 27A and the phenolic pitch bottoms stream that is fed to Unit 74. A secondary depitcher recovers the remaining PCX's from the phenolic pitch stream.

2.2.4.4 *Coal tar Naphtha hydrogenation (Unit 15/215)*

The purpose of this unit is to hydro treat a combined feed of Rectisol naphtha, light naphtha and heavy naphtha from Unit 14/214 to remove phenolic and nitrogen compounds. Olefin saturation and sulfur removal also takes place to produce a product acceptable for utilisation in the petrol pool. The liquid product is fed to a H₂S stripper where the sour water is removed from the product stream. The final product goes to storage to be used as blending component in petrol.

2.2.4.5 *Creosote hydrogenation unit (Unit 228)*

The purpose of this unit is to hydrotreat heavy tar derived cuts to produce creosote, naphtha and diesel. The plant receives medium creosote, heavy creosote and residue oil from units 14/214. The unit also receives MTP, FFC, coker gas oil and waxy oil transfer material from unit 39 and this is fed to the unit as a percentage of the U2/14's feed streams. The one product stream containing high naphthene and aromatic content is routed to the platformer, while the other stream (creosote diesel) is a final diesel blending component.

2.2.4.6 *Naphtha hydrotreater, platformer and CCR (Unit 30/230 and Unit 31/231)*

The naphtha hydrotreater is a catalytic refining process used to saturate olefins and remove oxygenates. The feed for the naphtha hydrotreater is naphtha cut originating from Synthol light oil, distillate naphtha from the distillate hydrotreater (Unit 35/235) and creosote naphtha from U228. After the hydrotreating reactors a high concentration hydrogen gas stream,

hydrogen sulphide (produced) rich gas stream and sour water (produces and added) is separated from the hydrocarbon stream at various points. The hydrocarbon stream is separated into an IP and platformer feed stream.

Platforming is a catalytic refining process employing a selected catalyst to convert low quality naphtha into an aromatic rich, high octane product while also yielding a LPG stream. The LPG stream is routed to U32/232 or to a petrol component tank depending on season. The hydrocarbon stream is routed to the petrol component tanks.

During a normal operating cycle, platforming catalyst deactivates due to excessive carbon build-up. The catalyst is continuously removed from the platforming reactors and sent to the CCR unit, where the carbon is burnt off the catalyst restoring the activity of the catalyst.

2.2.4.7 Catalytic distillation hydrotreater (Unit 78)

The U78 CD Hydro Unit is designed to individually hydro-isomerizes C5 and C6+ hydrocarbons for octane enhancement, and produce a diene-free C5 feedstock to the Skeletal Isomerization unit (U90) and eventually the TAME unit.

The C5 CDHydro product from the column's bottoms is routed to the Skeletal Isomerization unit, and eventually to the CDTame unit for TAME (tertiary amyl methyl ether) production. The C5 product can also be routed either to storage, directly to U79 or in combination of the mentioned scenarios.

2.2.4.8 CDTame unit (Unit 79)

The CDTame Unit 79 converts a C5 product from the C5 CDHydro column via the Skeletal Isomerization Unit 90, to produce TAME. This C5 stream from U90 is fed to U79 reactors to recover TAME product.

2.2.4.9 C5 Isomerisation (Unit 90)

The C5 Skeletal Isomerisation Unit (Unit 90) produces branched chained iso-amylenes from the C5 olefinic feed from the C5 CD-Hydro Unit (Unit 78) which are required as feed to the CD-TAME Unit (Unit 79).

The C5 olefinic feed is sent to a reactor from where the heavy ends of C6 and higher are sent to the C6 storage facilities in Tank Farm and the light ends are sent to the Catalytic Polymerisation Unit (Unit 32). The bottoms product from the Debutaniser column is the C5 iso-amylene product that is sent to Unit 79.

2.2.4.10 Vacuum distillation (Unit 34/234)

The vacuum distillation unit (U34/234) separates the decanted oil (DO) stream from Synthol as well as the heavy components produced in U2/29. The products from this unit are light vacuum gas oil and heavy gas oil for unit 235 Diesel Hydrotreaters and a minimum amount of heavy fuel oil for U39 Carbo Tar.

2.2.4.11 Distillate hydrotreater (U35/235)

The purpose of this unit is hydrotreating. The plant receives heavy components from SLO and the lighter components from the vacuum distillation units (2/34). The hydrocarbon stream is separated into a naphtha, light diesel and a heavy stream. The naphtha stream is sent to the naphtha hydrotreaters (2/30), the distillate selective cracker (35DSC) and the light diesel is sent to the diesel component tanks.

2.2.4.12 *Distillate selective cracker (U35)*

The DSC unit consist of two main sections- the cracking/dewaxing reactor reaction and the fractionation section. The main function of the reactor is to crack the heavy feed material into diesel range boiling material and to isomerize n-paraffin into iso-paraffin. The DSC fractionation section main purpose is to separate reactor effluent material into very light gasoline boiling range material, a heavy diesel cut and a fuel oil cut.

2.2.4.13 *Light oil fractionation (Unit 29/229)*

The purpose of this unit is to perform the primary fractionation for the Refinery facilities. The feed to the unit is stabilised light oil (SLO) from Synthol. The unit produces a light C5/C6 stream for CD Hydro unit (U78), a naphtha product that feeds Octene and the Naphtha Hydro-treatment units (U2/30), a distillate stream that feeds Safol and Diesel Hydrotreaters (U2/35), a heavy product that feeds the vacuum distillation unit (U2/34).

2.2.4.14 *Polymer hydrotreater (Unit 33/233)*

The purpose of this unit is to convert olefins to the corresponding paraffins. The feed to the unit comes from U2/32. The hydrocarbon stream is separated into petrol and diesel component stream.

2.2.4.15 *Catalytic polymerisation and LPG recovery (Unit 32 / 232)*

The purpose of this unit is to produce motor fuels namely petrol, diesel and jet fuel from a stream of C3/C4. Saturated C3's and C4's are sold as LPG.

2.2.4.16 *Sasol Catalytic Converter (Unit 293)*

The SCC Super flex™ Process is a Fluidized Catalytic Cracking (FCC) process, similar in configuration to a refinery FCC unit. Low molecular weight olefins and paraffins are converted to ethylene and propylene in a reactor. High octane gasoline is also produced. The feed to the plant is C6/C7 from Tank Farm.

2.2.5 *Tar, Phenosolvan and Sulfur*

2.2.5.1 *Gas Liquor Separation*

The purpose of the gas liquor separation unit is to separate various gaseous, liquid and solid components from the gas liquor streams. Dissolved gases are removed from the gas liquor by expansion to almost atmospheric pressure. The different liquids and solids are separated in separators by means of physical methods based on settling time and different densities.

Separation takes place by gravity at controlled temperatures and atmospheric pressure. The feed to the gas liquor separation unit originates from the cooling and washing of the raw gas from coal gasification. The raw gas contains large amounts of water vapours (steam, carbonization water and coal moistures) and by-products from carbonization such as tar, oil, naphtha, phenols, chlorine, fluorine and fatty acids. It also contains dissolved gases (mostly NH₃, CO₂, and H₂) and small amounts of combustible gases and coal dust as well as inorganic salts.

Feed streams originate in:

- Gasification (unit 10/210);
- Gas cooling (unit 11/211);
- Rectisol (unit 12/212);
- Phenosolvan (unit 16/216);
- Coal Tar Filtration (CTF) (on the Western site only);
- Refinery Unit 14 and 74;

- Carbo Tar.

2.2.5.2 *Phenosolvan*

The Phenosolvan (Unit 16 / 216) and Ammonia Recovery (Unit 17 / 217) plants are mainly water purification plants with the purpose to remove impurities such as suspended solids and oil as well as to recover pitch, phenols, organic waste, carbon dioxide (CO₂), hydrogen sulphide (H₂S) and ammonia (NH₃) from the gas liquor before pumping the stripped gas liquor to Water Recovery (Unit 52 / 252) for re-use in the Synfuels factory as cooling water. Only phenols and ammonia are marketable products.

Unit 16 / 216 serves the purpose for gas liquor filtration, phenol and pitch extraction, solvent recovery and depitching of crude tar acids to produce depitched tar acids (DTA). Unit 17 / 217 serves the purpose for solvent recovery, acid gas removal, organic contaminants removal, ammonia recovery as well as purification and liquefaction of ammonia.

2.2.5.3 *Sulfur Recovery*

The plants receive the feed-gas from Rectisol for the absorption and conversion of H₂S prior to routing the H₂S lean gas to the stack. The off-gas from Sulfur plant is combined with the off-gas from Rectisol before being routed to the stack. The H₂S in the feed-gas from Rectisol is absorbed into the sulpholin liquor by means of venturi absorbers.

From the absorbers the liquor with absorbed H₂S goes into the reaction tanks where elemental sulfur is produced. In the reaction tanks vanadium (V) is an active oxidizing agent that oxidizes HS⁻ to elemental Sulfur. During this process vanadium is reduced to inactive vanadium (IV), which needs to be re-activated. The slurry from the reaction tanks is sent to two oxidizers arranged in series.

The sulfur slurry in the oxidizers is separated from the liquor by means of weirs in the last oxidizer. The Sulfur slurry from the last oxidizer falls directly into three (3) slurry tanks. From the slurry tanks, the slurry is pumped to decanters for the removal of the entrained liquor. The liquor is routed back to the process via the balance tank. The Sulfur rich cake from the decanters is re-pulped using wash condensate before it is pumped to the sulfur separator.

In the separator, the liquid sulfur is separated from water and sent down to the sulfur pit. From the pit, the liquid sulfur is transported by road trucks to the granulation plant for filtering and formation of sulfur granules.

During the conversion of HS⁻ to elemental sulfur and the re-oxidation of vanadium, salts such as NaSCN, NaHCO₃ and Na₂SO₄ are formed. A bleed stream from the discharge side of the circulation pump is routed to the sulphate plant to produce Sodium Sulphate as a by-product, thereby reducing the salt concentration of the circulation liquid.

2.2.5.4 *Wet Sulfuric Acid Plant*

The feed gas to Wet Sulfuric Acid (WSA) is sourced from Rectisol east (phase 3 and phase 4), which are routed to a knock out drum (per phase). The outlets of the knockout drums combine before Phenosolvan off gas joins the feed header into the WSA combustor where the feed gas is burned with fuel gas and hot air to form SO₂ containing process gas.

After combustion the process gas is cooled in a waste heat boiler. The formed process gas, after being cooled down, leaves the waste heat boiler and dilution air is introduced to ensure sufficient oxygen content before entering a NO_x converter. In the NO_x converter the nitrogen oxides are removed from the process gas. The reduction of the nitrogen oxides is carried out by the injection of ammonia into the process gas and subsequently passing the gas mixture over a catalyst where the nitrogen oxides react with the ammonia and are converted to nitrogen and water vapour.

From the NO_x converter the process gas is further processed in the SO₂ converter. The SO₂ in the process gas is oxidized catalytically. The SO₂ gas reacts with O₂ to form SO₃ gas. The formed SO₃ gas reacts with the water vapour present in the process gas through exothermic hydration reaction, resulting in the formation of the sulfuric acid gas (H₂SO₄).

The process gas then enters the Wet Sulfuric Acid (WSA) condenser where it is further cooled by means of air in a glass tube heat exchanger, and the remaining part of the hydration reaction and the condensation of sulfuric acid take place. The produced sulfuric acid has a concentration of 96.5 wt%, with a maximum acid mist content of 20 ppm (by volume) when leaving the top of the WSA condenser. The hot sulfuric acid product will leave the bottom of the WSA condenser.

Normally, if no special precautions are taken, condensations of sulfuric acid vapour will result in a mist of very small acid droplets. These very small droplets cannot be separated from the process gas in the WSA condenser. Thus to overcome this problem four mist control units are installed. The cleaned gas leaves the top of the WSA condenser. Even though all four mist control units are well in operation, the clean gas will contain a small amount of remaining acid mist which is reduced by the Wet Electrostatic Precipitator (WESP). The WESP consists of an empty column scrubber part, where the cleaned gas sprayed with weak acid and the precipitator part where the mist particles form a liquid film on the vertical collecting electrodes due to the strong electric field. The liquid film then runs down the electrodes to the scrubber sump and the cleaned gas proceeds to the stack where it's lead to the atmosphere.

2.2.5.5 Carbo Tar and Coal Tar Filtration

2.2.5.5.1 Coker (Unit 39)

The Delayed Coker Plant receives the so called bottom of the barrel products from upstream units to produce coke. The plant mainly operates in three different modes to produce three different types of coke. These modes are the normal MTP (medium temperature pitch) mode, WO (Waxy Oil) mode and the hybrid mode, which is a 70:30% blend between MTP and FCC (fluidised catalytic cracker) slurry.

Reactions and Catalyst

The Coker Plant produces green coke using a delayed coking process, which involves thermal cracking of the feedstock (pitch, waxy oil or FCC slurry) at elevated temperatures and long residence time at specific conditions. The basic reaction that takes place is: HC + Impurities = C + Impurities + Vapour (H₂O & Volatile material)

2.2.5.5.2 Calciner (Unit 75)

The coke calcining unit, (U75) receives green Coke from the Delayed Coker plant (U39) and thermally upgrades the green coke to produce calcined Coke. U39 processes three basic types of feed: Waxy Oil, Medium Temperature Pitch (MTP) and Hybrid (70%-30% MTP-FCC slurry blend) green coke. From these feed stocks, U39 produce seven different grades of green coke, of which five are calcined and sent to the market.

2.2.5.5.3 Coal Tar Filtration (Unit 96)

At Unit 096 tar is received from the Gas Liquor Separation units (Unit 13 and 213). Solids and water is removed from the tar. The solids get removed by means of decanters and filters while water gets removed by means of a force feed evaporator. The solids get trucked to the Mixing plant were it is mixed with fine coal and fed to the boilers. The final tar product is pumped to tank farm as feed for the Tar distillation units (Unit 14 and Unit 214).

2.2.5.5.4 Feed Preparation (Unit 86)

The purpose of the Feed Preparation Plant (U86) is to clean-up heavy residue streams from tanks and dams containing solids and water; the feed streams can vary depending on availability. The plant consists of two Trains; Train 1 processes Waxy Oil (WO) related product, which is obtained from the American Petroleum Institute (API) dams; and Train 2 processes the crude tar from various sources and also serves as a Coal Tar Filtration (CTF) contingency.

Train 1 can also be utilised to process tar when there is very high tank levels from Tank Farm (256TK 1401/2). Through the series of processes, water and solids are removed from the contaminated feed streams and made available to customers such as heating fuels and Tar Distillation Units (U(2)14).

2.2.5.5.5 Calciner (Unit 76)

This unit is a storage facility for final products from the calciner Unit 075 and distribution via rail and road trucks of different sizes, quantities and products.

2.2.6 Water and Ash

2.2.6.1 Multi hearth sludge incinerator

Waste activated sludge is burned in 4 twelve bed multi hearth type incinerators (2 per unit). Each incinerator has two burner chambers designed such that each chamber can be supplied with fuel gas. Combustion and cooling air is also introduced to the incinerator. Thickened waste activated sludge is fed into the incinerators. Off-gas, slurry and ash exit the incinerator.

2.2.6.2 HOW Incinerator

The purpose of the HOW incinerator is to burn concentrated high organic waste (HOW) and gas fumes from Phenosolvan and Ammonia recovery (U17/217).

The interior of the incinerator consists of a horizontal combustion chamber that has been lined with fireproof bricks out of a kind of ceramic that is extremely heatproof. The burner is a combination burner for optional or simultaneous combustion of fuel gas and HOW and is mounted to the front of the combustion chamber. The product is atomized with steam in the burner. Fuel gas serves as the pilot flame to ignite the HOW. For this reason the fuel gas flame must be kept burning permanently. Oxygen is required for combustion. In this case, a controlled quantity of air is provided to the burner called primary air (combustion air). Warm air containing combustion gases is let out to the atmosphere through the chimney.

2.2.6.3 Sewage Incinerator

The purpose of the domestic sewage plant is to treat all sewage from Secunda town and ablution facilities from Sasol Secunda site, upgrading it to render it suitable to discharge to the river. The process can be divided into sections

- Inlet works (primary treatment section)
- Biological Section (secondary treatment section)
- Polishing section (tertiary treatment section)

Untreated sewage enters the inlet works where screening and removal of grit takes place. The flow then moves to the biological section where the removal of soluble and particulate organic material is removed from raw sewage. The last section (polishing section) is where further removal of suspended solids takes place, as well as and the sanitation of effluent before the effluent is released to the river. The function of the sewage incinerator is to burn waste screenings from the primary treatment section. The products are ash and combustion gases.

2.2.6.4 Thermal Oxidizer

In order to prevent atmospheric pollution from the storage tanks and vessels that contain VOC's, it gets vented to a thermal oxidizer. It consists of a piping/ducting system to draw vapours from the following tanks:

- Oily Waste Tanks (TK2005/11/12)
- Phenolic Waste Tanks (TK2002/4)
- Organic Waste Tanks (TK2006)
- Flare knock out water (TK2003)
- Quarantine Waste Tank (TK2016)
- Recovered oil Tank (TK2009)
- APS storage tank (TK2512)
- Hydrocarbon Equalization Tank (TK2501)
- API Separator (TK2505)
- Recovered Oil Tank (TK2510)
- DAF Separator (DAF 2501)
- Area 10 Loading Arms (ME 1010/1011/1013)

2.3 Unit Processes

Unit process considered listed activities under the National Environmental Management Air Quality Act (NEMAQA) are summarised in Table 2-2.

Table 2-2: List of unit processes considered listed activities under NEMAQA

| Name of the Unit Process | Unit Process Function | Batch or Continuous Process | Listed Activity Sub-category |
|--------------------------|--|-----------------------------|------------------------------|
| Steam Plant | Produces steam for process units | Continuous | 1.1 |
| Gasification | Gasification of coal | Continuous | 3.6 |
| Gas cooling | Cooling of the gasification products, separation of the condensable products of gasification | Continuous | 3.6 |
| Tar Value Chain | Separation of the gasification tar stream | Continuous | 3.3 |
| Rectisol | Cleaning of the Gasification gas | Continuous | 3.6 |
| Phenosolvan | Processing of the Gasification water stream | Continuous | 3.6 |
| Sulfur Processing | Removal of H ₂ S from gas exiting the factory | Continuous | 3.6 |
| Wet Sulfuric acid | Removal of H ₂ S from gas exiting the factory, production of sulfuric acid | Continuous | 7.2 |
| Refinery | Production of synthetic fuels and products | Continuous | 2 |
| Solvents | Processing of chemicals | Continuous | 6 |
| Incineration | Incineration of waste products | Continuous | 8.1 |

For completeness, all unit processes for the Sasol Secunda complex are listed in Table 2-3.

Table 2-3: Unit processes at Sasol Secunda

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--------------------------------------|---|-----------------------------|
| Utilities | | |
| Coal milling process | There are 4 mills per boiler. The mill grinds the course coal to fine coal, which is known as pulverized fuel (PF). Primary air dries the coal and then transports the PF into the boiler furnace for combustion. | Continuous |
| De-aeration process | The feed water de-aerators make use of low pressure steam to heat up the feed water as well as to remove the oxygen from the feed water. Oxygen causes corrosion inside the boiler tubes if it is present. Chemical dosing into the de-aerator discharge line also helps to remove the oxygen. | Continuous |
| Combustion process | The PF is combusted in the 17 boilers and the hot flue gases are used to heat up the water in the water wall tubes. The hot flue gases containing ash and other gases are used to heat up the primary air while being extracted from the boiler furnace via the induced draught fans. The heated water is separated in the steam-water drum and reintroduced into the boiler to be superheated before supplied to the factory as superheated steam. | Continuous |
| Flashing process | Blow down from the steam/water and mud drum as well as drains are flashed in the blow down vessel to 4bar steam. | Continuous |
| Ash capture and handling process | The flue gas contains fly ash and coarse ash. The fly ash is separated from the flue gas using electrostatic precipitators. The ash which is not captured by the electrostatic precipitators is sent up the stack. The coarse ash falls from the furnace section into drag chains. Both the coarse and fly ash is mixed with water and pumped to the ash system. | Continuous |
| Electricity generation process | Excess superheated steam not used in the process is used to generate electricity in turbo-generators. There are 10 turbo generators with a capacity of 60MW. | Continuous |
| Burner oil for start-up process | Burner oil is used during start up and shutdown of boilers. Burner oil is also used when coal milling is stopped for maintenance. | Intermittent |
| Gas turbine | Power generation by burning natural gas | Continuous |
| Heat Recovery Steam Generator (HRSG) | Steam is generated using the hot off gas from the gas turbines. The steam generation includes a boiler, economisers, evaporators, and superheaters. Superheated steam is generated from this process at 425°C and 4300kPag with a maximum flow of 163t/h per boiler. | Continuous |
| Gas Production | | |
| <u>Coal Processing</u> | | |
| Separation | Separation of fine and course coal | Continuous |
| <u>Gasification</u> | | |
| Gasification and Raw Gas Cooling | Sasol® FBDB™ Gasification Process | Continuous |
| <u>Rectisol</u> | | |
| Absorption | Washes the raw gas in order to remove CO ₂ , H ₂ S, BTEX's and other organic and inorganic compounds | Continuous |
| Regeneration | Purification of wash medium | Continuous |
| Gas Circuit | | |
| <u>Benfield</u> | | |
| Benfield | The purpose of the Benfield Process is to remove Carbon Dioxide from the tail gas entering the Cold Separation thereby preventing freeze blockages. | Continuous |
| <u>Catalyst preparation</u> | | |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|--|--|
| Catalyst Manufacturing | Manufacturing of catalyst for the Synthol process. | Continuous (Arc furnace is semi-batch process) |
| Catalyst Reduction | The purpose of this system is to activate the catalyst before it is fed to the reactors. | Batch |
| Refinery | | |
| <i>Generic Refinery Unit Processes</i> | | |
| Tank | The feed tank serves as feed reserve tank. This is for a holdup for the polymerisation of the mixed feed components and for the separation of entering water. | Continuous |
| Vaporiser | The vaporizer separates the light ends from the heavy ends. Saturated high pressure (HP) steam is used to vapourise the feed. | Continuous |
| Distillation column | The purpose of the columns is to purify hydrocarbon streams as well as separation of the hydrocarbon streams into various components. | Continuous |
| CD Hydro Hydrogenation Columns | To hydrotreat and separate hydrocarbons. | Continuous |
| Separation and collection drums | It's used to separate streams into lighter and heavier components. | Continuous |
| Hydrotreating reactors | The reactors are used to saturate olefins and oxygenates. To remove nitrogen and sulfide components as well as removing other impurities in the presence of hydrogen. | Continuous |
| Platforming reactors | The reactors convert low quality naphtha into an aromatic rich, high octane product. | Continuous |
| U90-Skeletal isomerisation reactor | The purpose of the skeletal isomerization unit is to convert the C5 feed from the CD-Hydro unit to isoamylenes as feed to the CD-TAME unit | Continuous |
| Catalytic polymerisation | The purpose of this unit is to produce motor fuels namely petrol, diesel and jet fuel from a stream of C3/C4. | Continuous |
| Heat exchangers | There are a large number of heat exchangers that is used to heat up, cool down, vaporise and condense the hydrocarbon streams. There is a combination of product, product exchangers (two process exchangers exchanging energy) as well as product utility exchangers. | Continuous |
| Air coolers | The air coolers are used to cool down and condense hydrocarbon streams | Continuous |
| Ejectors | The equipment is used to generate a negative gauge pressure (vacuum). There are a number of plants in the refinery that utilises vacuum conditions for the separation of hydrocarbon streams | Continuous |
| Compressors | The compressors are used to increase and or maintain the high operating pressures of the refinery processes. There are reciprocal, centrifugal and turbine compressors used in the refinery environment | Continuous |
| Pumps | The pumps used in the refinery are centrifugal, multi stage and positive displacement pumps | Continuous |
| Electrical heaters | The electrically heater is normally not in operation. The heater is primarily provided for catalyst regeneration and is also used to heat up the main reactor for start-up. | Start-up and as required |
| Heaters | The heaters are used to heat up hydrocarbon and gas streams | Continuous |
| Superflex Catalytic Cracker | Low molecular weight olefins and paraffins are converted to ethylene and propylene in a reactor. High octane gasoline is also produced. | Continuous |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|---|-----------------------------|
| Catalyst Fines system and Waste Heat Boiler | The purpose of the unit is to recover catalyst fines from the flue gas. The waste heat boiler cools the flue gas against boiler feed water to produce high pressure steam. | Continuous |
| <u>Gas Clean-up equipment</u> | | |
| Reactors | The purpose of the unit is to remove oxygen, acid gasses and moisture from the process gas. | Continuous |
| DEA and Caustic sections | | |
| Gas Dryers | | |
| Liquid Dryers | The purpose of the unit is to remove water from the C3 stream. | Continuous |
| Propylene Refrigerant system | The propylene refrigeration system is a closed-loop system providing three levels of refrigeration, -39°C, -22°C and 4°C. | Continuous |
| <u>Tar distillation units</u> | | |
| Water Stripper (14VL101/201; 214VL101/201) | The crude tar that is fed to the stripper is heated in a number of heat exchangers. This feed is then stripped of water in VL101. The overhead vapours of the stripper are then condensed and the water free crude tar is sent to VL102. | Continuous |
| Distillation Column (14VL102/202; 214VL102/202) | This column is operated at atmospheric pressure and superheated stripping steam is fed to the bottom section to control the temperature. The distillation tower is heated up by the tar furnace 14HT-101. The overhead vapours being mainly water and light naphtha are condensed. In the distillation tower 14VL-102 heavy naphtha, medium creosote and heavy creosote are recovered as side streams of the tower. | Continuous |
| Reflux Drum (14DM102/202; 214DM102/202) | The condensed vapours of both VL101 and VL102 are fed to this drum where the water is separated from the light naphtha. The water overflows into the sewer, the hydrocarbons are partly sent as reflux to 14 VL101 and 14 VL102, and partly routed as light naphtha product to the tank. | Continuous |
| Flash Drum (14DM104/204; 214DM104/204) | The net bottom product of the distillation tower is withdrawn from the tar furnace (14HT-101) circulation stream and sent to the flash drum 14DM-104. In this drum, operating under vacuum, separation between pitch and residue oil is achieved by one stage flash evaporation. | Continuous |
| Heavy Creosote Process Vessel (14DM106/206; 214DM106/206) | This vessel stores heavy creosote which is a side draw from VL102 before it is pumped to tank farm. | Continuous |
| Medium Creosote Process Vessel (14DM107/207; 214DM107/207) | This vessel stores medium creosote which is a side draw from VL102 before it is pumped to tank farm. | Continuous |
| Heavy Naphtha Process Vessel (14DM108/208; 214DM108/208) | This vessel stores heavy naphtha which is a side draw from VL102 before it is pumped to tank farm. | Continuous |
| Pitch Drum (14DM109/209; 214DM109/209) | The bottoms product of 14DM104 is pitch, which passes via a barometric pipe to pitch cooler 14 ES114 and to the pitch drum 14DM109, from where it is pumped to Carbo Tar, unit 39 or Tank Farm. | Continuous |
| Residue oil Drum (14DM110/210; 214DM110/210) | The top product of the flash drum 14DM104 is residue oil, which is condensed in 14ES115, a steam producing heat exchanger, and then travels via 14DM111 along a barometric pipe to the residue oil drum 14DM110 from where it is pumped by 14PC108 to battery limit. | Continuous |
| Heaters (14HT101/201; 214HT101/201) | This furnace is used to heat a high circulating bottoms product from 14VL102 and thus control the temperature of the column. | Continuous |
| <u>Unit 27A</u> | | |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|--|-----------------------------|
| Neutral oil stripper (27VL101) | The purpose of this stripper is to remove the neutral oils contained in the HNO-DTA (high neutral oil depitched tar acids) feed, producing LNO-DTA (low neutral oil depitched tar acids). | Continuous |
| Flash Drum (27DM103) | This drum flashes the neutral oil from the water and the neutral oil rich stream goes to 27DM1 and the water rich stream is recycled back to the column. | Continuous |
| Separator Drum (27DM1) | The stream from 27DM103 that is rich in neutral oil is cooled and sent to 27DM1 for separation. | Continuous |
| <u>Unit 74</u> | | |
| Vacuum Distillation (74VL101) | This is a secondary depitcher column that flashes phenolic pitch and fractionate the stream to recover as much phenolic material possible in the side draw, without entraining catechol or any heavy ends. The column operates under a vacuum. The depitched tar acids are drawn off from the top of the column and are the product and the pitch at the bottom is sent to unit 14/214 and CarboTar. | Continuous |
| <u>Coal tar naphtha hydrogenation</u> | | |
| Feed Tank (15TK-101) | The feed tank serves as feed reserve tank. This is for a holdup for the polymerisation of the mixed feed components and for the separation of entering water. | Continuous |
| Vaporizer (15EX-101) | The vaporizer separates the light ends (Naphtha) from the heavy ends (residue oil). Saturated HP steam is used to vaporise the feed. | Continuous |
| Residue Stripper (15VL-101) | The purpose of the residue stripper is to strip the remaining low boiling components by means of super-heated recycle gas. | Continuous |
| Residue Oil Collection Drum (15DM-102) | Residue oil from the residue stripper is collected in the residue oil collect drum and is continuously pumped to tank farm. | Continuous |
| Pre-reactor (15RE-101) | The bottom of the pre-reactor accommodates a separator, which retains any entrained liquid droplets, before the hydrocarbon vapor mixture enters the pre-reactor. The pre-reactor is filled with catalyst. | Continuous |
| Main Reactor (15RE-102) | Recycle gas and a hydrocarbon vapour mixture passes through the main reactor. A quench stream of cold recycle gas is used between the two main reactor beds to prevent H ₂ S from reacting back to mercaptans or thiophenes and to prevent severe hydrogenation. | Continuous |
| HP separator (15DM-106) | Separates the raffinate from the gas. | Continuous |
| Medium Pressure Naphtha Water Separator (15DM-107) | The medium pressure naphtha water separator is a three phase separator, firstly to separate the gas liquid mixture and secondly to separate the organic aqueous liquid mixture. The gas/raffinate and condensate are separated under gravity, due to their density difference. The water and product is separated by a gooseneck. The entrained injection and reaction water separated is discharged from the bottom of the separator's water compartment directly to unit 16/216 as waste water, or to the oily water sewer during upset conditions | Continuous |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|---|---|-----------------------------|
| H ₂ S Stripper (15VL-102) | The hydrogenated naphtha product is stripped of water, H ₂ S, NH ₃ and other dissolved gases. | Continuous |
| <u>Naphtha hydrotreater, platformer and CCR</u> | | |
| Naphtha reactors System | Saturation of olefins | Continuous |
| NHT Charge Heater | Heating of NHT reactor feed | Continuous |
| Separation drums | Hydrogen, uncondensed hydrocarbon gases and water are separated from the condensed reactor products. | Continuous |
| Stripper System | Removing of light ends (H ₂ S and water) | Continuous |
| Stripper Reboiler (Fired Heater) | Heating Stripper bottoms | Continuous |
| Splitter System | Splits between C ₅₊ and C ₅₋ | Continuous |
| Splitter Reboiler (Fired Heater) | Heating Splitter bottoms | Continuous |
| Platformer Charge Heater | Heating Platformer reactor feed | Continuous |
| Platforming Reactors | Produces aromatics from paraffins and naphthenes | Continuous |
| Continuous Catalyst regeneration system | Regenerates Platformer catalyst on continuous basis | Continuous |
| Product Separator | H ₂ is separated from the condensed Platformer product | Continuous |
| Debutanizer | Removes C ₄₋ from final product | Continuous |
| Debutanizer Reboiler (Fired Heater) | Heating Debutanizer bottoms | Continuous |
| <u>Catalytic distillation hydrotreater</u> | | |
| 78VL-101 (Depentaniser) | Splits a liquid feed stream into C ₅ and C ₆₊ streams. The C ₆₊ stream is sent to the Alpha Olefin plants for Hexene extraction. The C ₅ stream is sent to 78VL-102 (CD Hydro Column) | Continuous |
| 78VL-102 (CD Hydro Column) | Hydro-treats the C ₅ hydrocarbons to produce a diene-free feed to U90. | Continuous |
| <u>CD Tame</u> | | |
| 79RE-101 (Primary reactor) | 79RE-101 (Primary reactor) – The first reaction between isoamylenes and methanol takes place in this reactor. | Continuous |
| 79RE-103 (Secondary reactor) | The second reaction between isoamylenes and methanol takes place in this reactor. | Continuous |
| 79VL-101 (CD TAME Column) | The last phase of reaction takes place in this column. This column also serves to separate the TAME product from the unreacted reactants. | Continuous |
| 79VL-102 (Methanol Extraction Column) | Uses a water stream to extract methanol from the C ₅ Hydrocarbons. The C ₅ hydrocarbons are sent to storage, and the methanol-water stream is sent to 79VL-103. | Continuous |
| 79VL-103 (Methanol recovery column) | The water-methanol stream from 79VL-101 is split into methanol and water streams. The methanol is recycled to the front end of the process, and the water is recycled to 79VL-102 where it is used to extract the methanol. | Continuous |
| <u>C5 Isomerisation</u> | | |
| U90-Skeletal isomerisation unit | The purpose of the skeletal isomerization unit is to convert the C ₅ feed from the CD-Hydro unit to isoamylenes as feed to the CD-TAME unit | Continuous |
| <u>Vacuum distillation</u> | | |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|---|-----------------------------|
| Vacuum Distillation | The aim is to fractionate high boiling point hydrocarbons at low temperatures by lowering the pressure to ± 2.5 kPag using Decanted Oil from U20 and the heaviest fraction from U29 is fractionated to a Heavy and Light Gas Oil and Waxy Oil. | Continuous |
| <i>Distillate hydrotreater</i> | | |
| Distillation | The fractionation of the feed oil material into components of similar boiling range. | Continuous |
| Light diesel stripping | Separation of diesel (medium cut material) range boiling material from the feed stream using distillation. | Continuous |
| Naphtha stripping | Separation of naphtha (light material) range boiling material from the feed stream using distillation. | Continuous |
| Hydrogenation | The conversion of oxygenates and olefins into paraffins . | Continuous |
| Catalyst Sulfiding | This is to regulate catalyst activity | Continuous |
| Water removal | Removal of water from the feed oil stream in a drum operated such that water settles in the drum's water boot. | Continuous |
| High temperature Separation | Separate a feed stream into a liquid and vapour streams in a drum at a high temperature. | Continuous |
| Low Temperature separation | Separate a feed stream into a liquid and gas streams in a drum at a low temperature. | Continuous |
| Hydrogen recycle | To reuse the hydrogen rich off gases leaving the cold separation drum. | Continuous |
| Heating | This is to preheat feed streams and cool down product streams. | Continuous |
| <i>Distillate selective cracker</i> | | |
| Cracking reaction system | To selectively crack high-pour point components (predominately paraffins) | Continuous |
| Distillation | Fractionation of the heavy oil material | Continuous |
| Vacuum distillation | Separate the heavy distillate material mainly heavy diesel. | Continuous |
| Heating and Cooling | Preheat feed material and cool down product streams | Continuous |
| Water removal | Separate entrained water from feed stream | Continuous |
| Hot Temperature separation | Separate reactor product stream into a liquid and vapour stream. | Continuous |
| Hydrogen recycle | Recycle the off gas rich stream separate from the reactor liquid stream | Continuous |
| Catalyst sulfiding | To regulate the catalyst activity | Continuous |
| <i>Light Oil Fractionation</i> | | |
| Atmospheric Distillation | The purpose of the unit is to fractionate the Stabilized Light Oil into different fractions of molecules used in downstream processes. The different fractions are C5/C6 to the CD Tame unit, Naphtha to Octene (and U30NHT), Light Diesel to Safol (and U35DHT) and a Heavy fraction to U34. | Continuous |
| <i>Polymer Hydrotreater</i> | | |
| Polymer Hydrotreater | The purpose of the unit is to hydrotreat the polymer produced in the catalytic polymerisation unit to a paraffinic petrol and diesel/jet fuel fractions. | Continuous |
| <i>Catalytic polymerisation and LPG recovery</i> | | |
| Catalytic polymerisation | The purpose of this unit is to produce motor fuels namely petrol, diesel and jet fuel from a stream of C3/C4 . | Continuous |
| LPG recovery | The purpose of this section is to recover unreacted paraffinic C3 and C4 material for LPG production. | Continuous |
| <i>Sasol Catalytic Converter</i> | | |
| Pre-heat furnace | The purpose of this section is to vaporise the low molecule olefin and paraffin feed | Continuous |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|---|-----------------------------|
| Superflex Catalytic Cracker | Low molecular weight olefins and paraffins are converted to ethylene and propylene in a reactor. High octane gasoline is also produced. | Continuous |
| Quench Column and Strippers Towers | The purpose of this unit is to remove heavy oil and separate the process gas from the gasoline phase. | Continuous |
| C4 and C5 CD Hydro Hydrogenation Columns | The purpose of this unit is to saturate olefins. | Continuous |
| Catalyst Fines system and Waste Heat Boiler | The purpose of the unit is to recover catalyst fines from the flue gas. The waste heat boiler cools the flue gas against boiler feed water to produced high pressure steam. | Continuous |
| Process Gas Compression (KC2501 – PGC) | The purpose of the unit is to compress the process gas. | Continuous |
| <u>Gas Clean-up equipment</u> | | |
| Reactors | The purpose of the unit is to remove oxygen, acid gasses and moisture from the process gas. | Continuous |
| DEA and Caustic sections | | |
| Gas Dryers | | |
| SCC De-Propanizer (VL4001) | The purpose of the unit is to separate C4 molecules from the process gas. | Continuous |
| Chill Train, De-Methanizer and Cold Box | The purpose of the unit is to cool down the process gas and remove methane. | Continuous |
| C2 System which can be divided into the De-Ethanizer and C2 Splitter | The purpose of the unit is to separate C3 molecules from C2 molecules and to separate the C2 molecules into ethane and ethylene. | Continuous |
| PPU 5 which comprises of the FT De-Propanizer and C3 Splitter | The purpose of the unit is to separate C3 from C4 molecules and to separate the C3 molecules into propane and propylene. | Continuous |
| Liquid Dryers | The purpose of the unit is to remove water from the C3 stream. | Continuous |
| Propylene Refrigerant system | The propylene refrigeration system is a closed-loop system providing three levels of refrigeration, -39°C, -22°C and 4°C. | Continuous |
| Tar, Phenosolvan and Sulphur (TPS) | | |
| <u>Gas Liquor Separation</u> | | |
| Gas Liquor Separation | The purpose of the gas liquor separation unit is to separate various gaseous, liquid and solid components from the gas liquor streams. Dissolved gases are removed from the gas liquor by expansion to almost atmospheric pressure. The different liquids and solids are separated in separators by means of physical methods based on settling time and different densities. | Continuous |
| <u>Phenosolvan</u> | | |
| Water Purification | The purpose of this system is to filter out any oil, tar and suspended solids. | Continuous |
| The extraction process | The purpose of the extraction system is to remove phenols from gas liquor by mixing gas liquor with di-isopropyl-ether (DIPE) to extract the phenols. | Continuous |
| DIPE recovery and Phenol production | The DIPE and phenols are then separated through several distillation processes. | Continuous |
| Ammonia Recovery (Unit17) | Recovering of ammonia from the gas liquor. The raffinate from Unit 16 / 216, with about 1% DIPE, is first sent to the de-acidifier to remove acid gases. | Continuous |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|------------------------|---|--|
| Acid Gas Scrubber | The purpose of this system is to remove final traces of CO ₂ from the ammonia. | Continuous |
| Fractionation system | The ammonia leaving the Acid Gas Scrubber overhead is firstly compressed prior to the fraction process to improve ammonia recovery. The distillate product of the fractionator (2)17VL-105 is NH ₃ and the bottoms product is organics. The ammonia is cooled down to form a liquid and expanded and the final ammonia product is sent to Tank Farm. | Continuous |
| <u>Sulfur recovery</u> | | |
| Sulfur recovery | The purpose of the Sulfur Recovery unit is to reduce the amount of sulfur released into the atmosphere as hydrogen sulfide (H ₂ S) gas by producing elemental sulfur as a saleable product. | Continuous |
| <u>Wet Acid</u> | | |
| Wet Sulfuric Acid | The purpose of the Wet Sulfuric Acid (WSA) unit is to reduce the amount of sulfur released into the atmosphere as hydrogen sulfide (H ₂ S) gas by producing sulfuric acid as a saleable product. | Continuous |
| <u>Carbo Tar</u> | | |
| Coker | The Delayed Coker Plant receives bottom of the barrel products from upstream units to produce coke. | Continuous |
| Calciner | The coke calcining process is used to thermally upgrade green coke in order to remove associated moisture and combustible volatile matter (VCM) and to otherwise improve critical physical properties like the electrical conductivity, real density, etc. | Continuous |
| Coal Tar filtration | CTF utilises three solids removal processes and one water removal process. | Dump bins, decanters, force feed evaporator – continuous |
| | Solids are removed by means of gravity separation in the feed receiving dump bins, followed by solids removal by means of centrifugal separation in the decanter and lastly the final solids are removed by the pressure leaf filters. The water is removed by means of a forced feed evaporator system. | Filters - batch |
| Unit 86 | The main unit processes for U86 Train 1 is heat exchange, centrifugation and distillation while the main processed for U86 Train 2 is heat exchange, distillation and then filtration. Tankage of product happens before and after processing. | All processes are continuous except for the batch filtration processes |
| Unit 76 | The unit consists mainly of conveyors systems combined with storage silos. Loading and weighting facilities are also on site. | Continuous |
| <u>Water and Ash</u> | | |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|---|--|-----------------------------|
| Multi hearth sludge incinerators | The purpose of this system is to incinerate waste activated sludge from the biological treatment systems which treat industrial and domestic effluent respectively. The systems has 4 centrifuges per side to dry the sludge, which is then incinerated in 1 of 2 multiple stage hearth incinerators per side, with a temperature of around 780°C in the burning zone. The off-gas is sent to an emission treatment system before it passes into the atmosphere, while the coarse ash is sent to Outside ash for disposal. | Continuous |
| HOW incinerators | The purpose of this system is to incinerate high organic waste (HOW). The HOW, which is pumped from U17/217 to the HOW storage tank, is ignited by means of a fuel gas pilot flame inside a single chamber, refractory brick-lined incinerator. The combustion temperature is controlled at 950°C, and there are two burners. Steam is used to atomize the HOW. The only combustion product is off-gas. | Continuous |
| Sewage incinerator | The purpose of this incinerator is to burn screenings from primary treatment. It is a single chamber, furnace-type incinerator. The incinerator is manually filled with screenings. Diesel is used as a fuel, and the incinerator has two burners and one fan per burner. The combustion is automated. The products are off-gas and ash. | Batch |
| Waste Recycling Facility Thermal Oxidizer | Some of the enclosed storage and treatment tanks at WRF do not vent to the atmosphere but rather to the thermal oxidiser. It is introduced to the burners (which are kept burning with fuel gas) with air for combustion. | Continuous |
| Market and Process Integration (MPI) | | |
| <u>Flares</u> | | |
| Central corridor flares | A system consisting of 2 flare stacks, 2 relief headers and other associated equipment to collect and completely incinerate off-gases, off-specification gases and emergency venting. | As required |
| Solvents | | |
| U2/36 | Separation of Non-Acid chemicals from extraction water received from Synthol (U20) and subsequent separation of the NAC's into Alcohols and Carbonyls. | Continuous |
| U2/37 | Separation of Raw Carbonyls into Acetone, Methyl-ethyl-ketone, Aldehydes and Methanol. | Continuous |
| U2/38 | Separation of Raw Alcohols into Ethylol, Iso-propylol, Propylol, Iso-butylol, Sabutol and Sabutol bottoms. | Continuous |
| U38N | Purification of Propylol to pure Propanol and producing Propanol B as a by-product. | Continuous |
| U73 | Purification of Ethylol to pure Ethanol and producing Ethanol Lights as a by-product. | Continuous |
| Unit 237n Ethanol (99) | The manufacture and purification of ethanol through reactive distillation | Continuous |
| Unit 590 | The production of Ethyl acetate and subsequent purification through distillation | Continuous |
| Hexene (U300) | Production on 1-Hexene | Continuous |
| 1-Octene Train 1 (U301) | Production of 1-Octene | Continuous |
| 1-Octene Train 2 (U301) | Production of 1-Octene | Continuous |
| Regenerator (U302) | Recovery of Potassium Carbonate | Continuous |
| Safol (U303) | Production of detergent alcohol Safol™ | Continuous |
| Octene Train 3 (U304) | Production of 1-octene from 1-heptene via reaction and distillation steps. | Continuous |
| Flare (Hexene and 590) | Destruction of organic gasses during emergency, start-up, shut down and upset conditions. | Intermittent |
| Polymers | | |
| <u>Polypropylene</u> | | |
| Co-catalyst preparation (TEA, Silane & IPA) | Batch preparation of Silane and IPA through dilution with Heptane and storage of TEA in hold up tanks. | Batch |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|--|-----------------------------|
| Polymerisation | To produce polypropylene powder. | Continuous |
| Extrusion | Conversion of polypropylene powder to pellets | Continuous |
| Flare | Destruction of hydrocarbon gases released during abnormal operations. | Batch |
| Bagging | Storage and bagging of pellets | Continuous |
| <u>Monomers</u> | | |
| <u>U24</u> | | |
| Ethane Crackers | Cracks the gas into an ethylene rich stream | Continuous |
| Quench Water System | Utilised for inter stage cooling | Continuous |
| Cracked Gas system | Compress gasses and creates the required pressure for transfer through all the subsequent processes | Continuous |
| Amine System Scrubber | Remove H ₂ S and CO ₂ from the cracked gas | Continuous |
| Amine Regeneration System | Stripping off the contaminated amine | Continuous |
| Caustic Scrubber | Further removes any remaining CO ₂ | Continuous |
| Pre-Cooling and Drying | Cool down the gas in order to knock out all possible free moisture and heavy hydrocarbons | Continuous |
| Turbo Expanders | Utilised to expand the H ₂ rich to facilitate the separation of the C ₂ fractions remaining in the H ₂ stream | Continuous |
| De-Methanizer | Separates CH ₄ from the C ₂ /C ₃ through distillation | Continuous |
| De-Ethanizer | Utilised to separate the C ₃ + from the C ₂ fractions | Continuous |
| C ₂ Hydrogenation | C ₂ H ₂ present in the C ₂ gas is converted into C ₂ H ₄ by means of hydrogenation. | Continuous |
| 2 nd Demethanizer | Serves as a second de-methanizing column stripping off CH ₄ and H ₂ from the C ₂ 's | Continuous |
| C ₂ Splitter | The final separation stage where the only two gasses - ethylene and ethane enters the column and is separated by means of distillation | Continuous |
| C ₃ /C ₄ Debutanizer | Separates C ₃ /C ₄ | Continuous |
| C ₃ /C ₄ Hydrogenation | Selectively removes acetylene and dienes | Continuous |
| KC 6001/2 | Is utilised to compress the ethylene into the ethylene header to Sasol 1 | Continuous |
| <u>U70</u> | | |
| 70VL0101 De-ethanizer Distillation column | Removes C ₂ components from C ₃ condensate by means of LP steam. The C ₂ components are recovered to U24 | Continuous |
| 70VL0102 De-propanizer Distillation column | Separates Propane from propylene (which is the final product) by means of LP steam | Continuous |
| 70KX010 Ammonia compressor | Utilised for cooling purposes | Continuous |
| <u>U280</u> | | |
| U280 | Ethylene recovery unit, separate ethylene from C ₂ stream | Continuous |
| <u>U285</u> | | |
| PPU2(U285) | Separation of propylene from propylene rich stream | Continuous |
| <u>U 288</u> | | |
| PPU3(U288) | Separation of propylene from propylene rich stream | Continuous |
| Product Pipelines | Product to tank farm and thereafter to customers. | Continuous |
| Feed pipelines | Transport feed from U23 and U223 to PPU's | Continuous |
| Bottoms pipelines | Transport splitter bottoms to Catpoly (U32 and 232) | Continuous |
| U-551 ME101/2 | To convert hydrocarbons into CO ₂ | Batch |
| Oil | | |

| Unit Process | Function of Unit Process | Batch or Continuous Process |
|--|--|-----------------------------|
| <u>Main flares</u> | | |
| 057ME-0120 | A system consisting of 2 flares (1 West and 1 East) to collect and completely incinerate off-gases, off-specification and emergency venting from High Pressure Tank Farm. | Continuous |
| 257ME-0120 | | |
| <u>Storage facility</u> | | |
| 56 | Storage of components, final products and blending | Continuous |
| 256 | Storage of components and final products | |
| 257 / 057 | Storage and blending of gasses | |
| 57 | Loading of products and gasses | |
| <u>Ground level flare system West</u> | | |
| | A system utilized for the burning of mixed alcohols in a pit flare burner at low level | As required |
| LOC | | |
| Central road loading | Loading of various products in road tankers. Various products are being loaded of which the products containing VOCs are loaded in excess of 50 000 m ³ /a | Batch |
| Central rail loading | Loading of various products in rail tankers. Various products are being loaded of which the products containing VOCs are loaded in quantities below 50 000 m ³ /a | Batch |
| Nitro | | |
| <u>Fertilisers</u> | | |
| Nitric Acid Process | Production of Nitric acid | Continuous |
| Ammonia Process | Production Of Ammonium Nitrate Solution | Continuous |
| LAN Fertilizer Process | Production of Granular Fertilizers | Continuous |
| Phosphorous Process | Production of Various grades of Liquid Fertilizers | Batch |
| Ammonia Process | | |
| Ammonium Sulfate and Ammonium Chloride Processes | Production Of Ammonium Sulfate crystals | Continuous |
| <u>Explosives</u> | | |
| 20D | Preparation of raw materials | Semi-Continuous |
| D-Houses | Mixing and cartridging of explosive emulsion | Semi-Continuous |
| E-Houses | Cooling and Packaging of cartridged emulsion | Semi-Continuous |
| F2 | Palleting of packed product | Semi-Continuous |
| Magazines | Storage of product | |
| Bulk Plant | Production of Bulk Matrix and DDS emulsion | Semi-Continuous |

3 TECHNICAL INFORMATION

Raw material consumption for the listed activities applying for MES postponement is tabulated in Table 3-1. For completeness, the raw materials used by all process are included in Appendix C1 (Table C1-1), unless the information is intellectual property (IP) or otherwise sensitive due to competition law. Pollution abatement technologies employed at Synfuels and Solvents for the listed activities applying for MES postponement are provided in Table 3-2 (all appliance and abatement equipment in use at Sasol Secunda provided in Appendix C; Table C1-2).

3.1 Raw Materials Used and Production Rates

Table 3-1: Raw materials used in listed activities seeking postponements

| Raw Material Type | Design Consumption Rate | Rate Unit |
|------------------------------------|-------------------------|--|
| Steam Station East and West | | |
| Coal | 84 | t/h per boiler |
| Boiler feed water | 610 | t/h per boiler |
| Fuel oil | 48 | m ³ /cold start up |
| Tar sludge East | 0.066 | t/h per boiler |
| Tar sludge West | 0.37 | t/h per boiler |
| Ammonia | 90 (East) and 40 (West) | kg/precipitator/h (90%NH ₃ East and 99% NH ₃ West) |
| Air (total) | 540 | km ³ /h/boiler |
| Low pressure (LP) steam (400kPag) | 34 | t/h per boiler |
| Tar value chain | | |
| Unit 039 MTP | 51 | m ³ /h |
| Unit 039 Waxy Oil | 43 | m ³ /h |
| Unit 039 FCC Slurry | 45 | m ³ /h |
| Unit 075 Green coke | 112000 | tons per year |
| Unit 075 Green coke Hybrid | 17000 | tons per year |
| Unit 076 Green Coke | 60000 | tons per year |
| Unit 096 Coal Tar | 1327 | m ³ /day |
| Unit 096 Oil | 484 | m ³ /day |
| Unit 086 Waxy Oil Train 1 API Oil | 18 | m ³ /h per train |
| Unit 086 Train 1 Waxy Oil API Oil | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Dam Tar | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Raw Tar | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Tank Sludge's | 18 | m ³ /h per train |
| Unit 086 OBF Waxy Oil 12 | 18 | m ³ /h per train |
| Unit 086 OBF HFO 150 | 18 | m ³ /h per train |
| Superflex catalytic cracker | | |
| C6/C7 feed | 94.5 | t/h |
| C2 rich gas | 16 | t/h |
| Unit 24 cracked gas | 16 | t/h |
| FT feed to VL7001 | 70 | t/h |

| Raw Material Type | Design Consumption Rate | Rate Unit |
|--|-------------------------|---|
| Rerun gasoline | 10 | t/h |
| 99% Hydrogen | 0.52 | t/h |
| Hydrogen to CD hydro columns | 3000 | Nm ³ /h |
| PPU3 vent gas | 3.5 | t/h |
| PP2 carrier gas | 5 | t/h |
| HVGO | 7 | m ³ /h |
| Caustic | 3 | t/h |
| Sulfur Recovery | | |
| Offgas from Rectisol & Phenosolvan | 200 | kNm ³ /h per absorber (8 absorbers in the factory) |
| Caustic soda | 12 | m ³ /day per phase |
| SAV | 8 | tonnes/week (only when required) |
| ADA | 8 | tonnes/week (only when required) |
| NaSCN | 40 | tonnes/day (only when required) |
| Wet Sulfuric Acid | | |
| Off gas from Rectisol & Phenosolvan | 55 | kNm ³ /h |
| Potable water (Rand Water) | 125 | m ³ /h supply to Proxa |
| Ammonia | 15 | Nm ³ /h |
| Multi hearth biosludge incinerators | | |
| Thickened waste activated sludge | 508 | m ³ /day |
| HOW incinerators | | |
| High organic waste | 48 | m ³ /day |

3.2 Appliances and Abatement Equipment Control Technology

Table 3-2: Appliances and abatement equipment control technology

| Appliance Name | Abatement Appliance Type | Appliance function / purpose |
|--|---|---|
| Steam Stations | | |
| ESPs (Boilers 1 – 17) | Electrostatic precipitators | Particulate removal |
| Sulfur recovery | | |
| Cyclones | Cyclones | To reduce PM emissions |
| Superflex Catalytic Cracker (SCC) | | |
| Cyclone System | Cyclones | To reduce PM emissions |
| Wet sulfuric acid | | |
| Scrubber | Scrubber Wet Electrostatic Precipitator Selective Catalytic Reduction | Reduce SO ₂ , PM and NO _x emissions |
| Multi hearth biosludge incinerators | | |
| Scrubber | Venturi Scrubber | Removal of particulate and gaseous emissions |

4 ATMOSPHERIC EMISSIONS

The establishment of a comprehensive emission inventory for the listed activities seeking postponements formed the basis for the assessment of the air quality impacts from the Secunda Complex operations on the receiving environment.

4.1 Point Source Parameters

The point source parameters for those units applying for MES postponement are provided in Table 4-1. For completeness, the details for all point sources at the Sasol Secunda complex are provided in Appendix C2; Table C2-3, Table C2-4, and Table C2-5.

4.2 Point Source Maximum Emission Rates during Normal Operating Conditions

The point source emissions are provided, for units applying for MES postponement, in Table 4-2.

In cases where periodic compliance measurements are conducted, these are measured in accordance with the methods prescribed in Schedule A of the MES, and aligned with what is prescribed in the Atmospheric Emission Licence. These reflect the average of measurements conducted over a 3-hour period during normal operating conditions.

Table 4-1: Point source parameters

| Point Source Number | Point Source Name | Point Source Coordinates* | | Height of Release above Ground (m) | Height above Nearby Building (m) | Diameter at Stack Tip or Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow Rate (m³/hr.) | Actual Gas Exit Velocity (m/s) | Type of Emission (Continuous /Batch) |
|--|-------------------|---------------------------|-----------|------------------------------------|----------------------------------|--|----------------------------------|--|--------------------------------|--------------------------------------|
| Steam Stations and Rectisol / Phenosolvan | | | | | | | | | | |
| 1 | Main Stack East | 26.5575 | 29.14993 | 301 | 281 | 14.4 | 185 | 11870000 | 23 – 27 | Continuous |
| 2 | Main Stack West | 26.56014 | 29.16841 | 250 | 230 | 13.6 | 185 | 10558000 | 23 - 27 | Continuous |
| Superflex Catalytic Cracker | | | | | | | | | | |
| 3 | SCC Main stack | 26.55599 | 29.1639 | 90 | 80 | 3.6 | 190 | 314135 | 8.6 | Continuous |
| Sulfur Recovery | | | | | | | | | | |
| 4 | Main Stack East | 26.5575 | 29.14993 | 301 | 281 | 14.4 | 185 | 11870000 | 23 – 27 | Continuous |
| 5 | Main Stack West | 26.56014 | 29.16841 | 250 | 230 | 13.6 | 185 | 10558000 | 23 - 27 | Continuous |
| Wet sulfuric acid | | | | | | | | | | |
| 6 | WSA stack | 26.559278 | 29.167642 | 75 | 50.35 | 2.75 | 41 | 206600 | 9.73 | Continuous |
| Multi hearth biosludge incinerators | | | | | | | | | | |
| 7 | Biosludge East | 26.54617 | 29.1422 | 30 | 10 | 1.4 | 66 | 91616.953 | 15.7455018 | Continuous |
| | | 26.54598 | 29.14155 | 30 | 10 | 1.4 | 65 | 87230.794 | 15.7782546 | Continuous |
| 8 | Biosludge West | 26.54096 | 29.14283 | 30 | 10 | 1.4 | 68 | 74985.327 | 13.530936 | Continuous |
| | | 26.54111 | 29.14226 | 30 | 10 | 1.4 | 61 | 81082.862 | 14.7078725 | Continuous |
| HOW Incinerators | | | | | | | | | | |
| 9 | HOW East | 26.5481 | 29.14257 | 15 | 7 | 1.9 | 354 | 211588.32 | 19.8836384 | 26.5481 |
| 10 | HOW West | 26.5432 | 29.14331 | 15 | 7 | 1.9 | 386 | 183686.66 | 17.9960849 | 26.5432 |

Table 4-2: Point source emission rates during normal operating conditions

| Point Source Number | Point Source Name | Pollutant Name | Average Emission Rate | | |
|---------------------|-----------------------------------|--|--|------------------|----------------------|
| | | | Emission Concentration (mg/Nm ³) | Averaging Period | Duration of Emission |
| 1 | Main Stack East (Boilers) | Particulates | 92 | Daily averages | Continuous |
| | | SO ₂ | 1 689 | | |
| | | NO _x | 1 167 | | |
| | Rectisol East | VOCs | 14 | Hourly* | Continuous |
| 2 | Main Stack West (Boilers) | Particulates | 92 | Daily averages | Continuous |
| | | SO ₂ | 1 689 | | |
| | | NO _x | 1 167 | | |
| | Rectisol West | VOCs | 65 | Hourly* | Continuous |
| 3 | Superflex Catalytic Cracker | Particulates | 261 | | |
| 4 | Main Stack East (Sulfur Recovery) | H ₂ S | 8 400 | | |
| 5 | Main Stack West (Sulfur Recovery) | H ₂ S | 8 400 | | |
| 6 | Wet Sulfuric Acid | SO ₂ | 790 | Hourly* | Continuous |
| | | NO _x as NO ₂ | 436 | | |
| | | HF | 0.35 | | |
| | | NH ₃ | 0.07 | | |
| | | HCl | 1.5 | | |
| | | H ₂ SO ₄ | 20 | | |
| | | SO ₃ | 233 | | |
| 7 | Biosludge East 1 | Particulates | 265 | Hourly* | Continuous |
| | | SO ₂ | 43 | | |
| | | NO _x | 387 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 1.22 | | |

| Point Source Number | Point Source Name | Pollutant Name | Average Emission Rate | | |
|---------------------|-------------------|--|--|------------------|----------------------|
| | | | Emission Concentration (mg/Nm ³) | Averaging Period | Duration of Emission |
| | | Hg | 0.50 | | |
| | | Cd+Tl | 0.01 | | |
| | | HF | 13.8 | | |
| | | NH ₃ | 22.8 | | |
| | | HCl | 8.7 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| 7 | Biosludge East 2 | Particulates | 260 | Hourly* | Continuous |
| | | SO ₂ | 84 | | |
| | | NO _x | 460 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 1.44 | | |
| | | Hg | 0 | | |
| | | Cd+Tl | 0.50 | | |
| | | HF | 53 | | |
| | | NH ₃ | 80 | | |
| | | HCl | 28 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| 8 | Biosludge West 1 | Particulates | 82 | Hourly* | Continuous |
| | | SO ₂ | 26 | | |
| | | NO _x | 188 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 12 | | |
| | | Hg | 0 | | |
| | | Cd+Tl | 0.5 | | |

| Point Source Number | Point Source Name | Pollutant Name | Average Emission Rate | | |
|---------------------|-------------------|--|--|------------------|----------------------|
| | | | Emission Concentration (mg/Nm ³) | Averaging Period | Duration of Emission |
| | | HF | 53 | | |
| | | NH ₃ | 80 | | |
| | | HCl | 28 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| 8 | Biosludge West 2 | Particulates | 172 | Hourly* | Continuous |
| | | SO ₂ | below detection limit | | |
| | | NO _x | 533 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 29 | | |
| | | Hg | <0.01 | | |
| | | Cd+Tl | 0.01 | | |
| | | HF | below detection limit | | |
| | | NH ₃ | 0.35 | | |
| | | HCl | 0.01 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| 9 | HOW East | Particulates | 109 | Hourly* | Continuous |
| | | SO ₂ | 23 | | |
| | | NO _x | 1 375 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 3.7 | | |
| | | Hg | <0.01 | | |
| | | Cd+Tl | 0.01 | | |
| | | HF | below detection limit | | |
| | | NH ₃ | 0.35 | | |

| Point Source Number | Point Source Name | Pollutant Name | Average Emission Rate | | |
|--|-------------------|--|--|------------------|----------------------|
| | | | Emission Concentration (mg/Nm ³) | Averaging Period | Duration of Emission |
| | | HCl | 0.01 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| 10 | HOW West | Particulates | 248 | Hourly* | Continuous |
| | | SO ₂ | below detection limit | | |
| | | NO _x | 1 182 | | |
| | | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V | 21.5 | | |
| | | Hg | 0.12 | | |
| | | Cd+Tl | 0.03 | | |
| | | HF | below detection limit | | |
| | | NH ₃ | 0.35 | | |
| | | HCl | 0.01 | | |
| | | Dioxins / Furans (ng TEQ/Nm ³) | <0.01 | | |
| *: Hourly averages are based on 3-hourly ad hoc sampling average measurements, as per Regulatory requirement | | | | | |

4.3 Point Source Maximum Emission Rates during Start-up, Maintenance and/or Shut-down

From a maintenance perspective, planned factory shutdowns are conducted yearly. The Sasol Synfuels plant consists of four 'phases'. Two phases are located at the Sasol Synfuels west factory; and two phases on the Sasol Synfuels east factory. Every year, one phase of the plant undergoes a "phase shutdown", and every four years, a "total shutdown" (representing two of the four phases) is undertaken. Statutory requirements sometimes drive the frequency of maintenance activities, for example, pressure vessel regulations drive boiler inspection schedules.

As for upset conditions, Section 30 of NEMA applies, and Sasol has not exceeded the 48 hour window in the preceding two years during start up, maintenance, upset and shutdown conditions, which has ensured that ambient impacts are limited in duration.

During maintenance activities, the real-time ambient air quality monitoring data is closely followed, to ensure that air quality does not exceed the national ambient air quality standards as a consequence of Sasol's activities. These activities are also communicated to the Licensing Authority as well as the communities around the facilities, normally through a newspaper notice.

The Atmospheric Impact Report Regulations require that the maximum emissions during start-up, shut down and upset conditions must be included within the AIR for the processes. This information is unfortunately not available for two practical reasons, explained below.

1. Since Sasol operates predominantly gaseous plants, operating the plant under start-up, shut down and upset condition is a period of high instability and for safety reasons, as few people as possible are allowed on the plant. Therefore ad hoc sampling under these conditions is a safety risk and therefore the sampling cannot be conducted. It should further be emphasised that the aim of the plant personnel is to get the plant back into operation as soon as possible and therefore the support required by sampling teams cannot be provided as the focus is on the returning the plant to stable operation as soon as possible.

Another practical limitation is identification of the precise process conditions that will result in a maximum emission concentration. Since these conditions are unstable, large variations in plant conditions occur dynamically and pin pointing the exact combination of conditions at which to take the sample indicative of a maximum concentration is virtually impossible. Additional to the last mentioned, a maximum concentration may hypothetically exist for only a couple of minutes, however the prescribed legislation requires certain sampling techniques to be done over a period of at least an hour and then to be repeated for two times. Doing this under start-up, shut down and upset conditions are almost impossible due to the dynamics of a plant.

2. In the event where online monitoring is available, Sasol can attempt to make concentrations available for start-up, shut down and upset conditions, however in investigating this Sasol has realised that the maximum concentrations are higher than the calibration range of the instrument, meaning that the online instrument is yielding only its maximum value. Since the actual true maximum concentration is higher than the instrument maximum, the true actual concentration cannot be provided and therefore an accurate maximum concentration under start-up, shut-down and upset conditions cannot be included.

In mentioning the above, cognisance should be taken that Sasol's ambient air quality monitoring stations monitor ambient air quality over a 24-hour period and any upset, start-up or shut down events will reflect in the ambient air quality measurements and results. Therefore, maximum measured concentrations, although not quantified on site, is included in measured values for ambient air quality.

4.4 Fugitive Emissions

Fugitive emissions on the Secunda complex are managed and quantified through two fugitive emissions monitoring programs.

4.4.1 Fugitive VOC emissions

The first monitoring program is associated with fugitive VOC emissions. These emissions originate from various sumps, drains and from process equipment, such as product storage tanks, valves and pumps. The on-site monitoring of fugitive process emissions is associated with Leak Detection and Repair. A third party contractor is contracted to conduct leak detection, with the help of a sniffer, to identify and quantify the leaks associated with various process emissions. The report results are then included in a maintenance plan and the leaking process units are repaired per schedule. This process has been implemented for a period exceeding five years.

As a last resort, all VOC emissions, where arising from point sources, are detected by the monitoring stations surrounding the Secunda complex. These measurements reflect the total, combined effect of VOC emissions from across the entire Secunda complex, and Sasol conservatively assumes all ambient VOCs are attributable to the Secunda complex.

4.4.2 Dustfall monitoring

Fallout dust is governed by the fallout dust regulations; Government Gazette No. 36974, No. R. 827; 1 November 2013). Secunda has a number of fallout dust monitoring stations measuring the dust fallout on site. The dust fallout buckets are placed in locations where fallout of dust from coal stockpiles, fine ash dams and construction activities will occur, to ensure adequate control of most probable dust sources is in place. The Safety, Health and Environmental function at the Secunda site is responsible for the measurement and management of dust in accordance with the fallout dust regulations and an accredited third party is responsible for replacing and analysing the buckets on a monthly basis. The position of the buckets was determined by dispersion modelling conducted by an independent consultant.

The graphs for 2012/2013 sampling campaign for fallout dust are included in Appendix C3 (Figure C3-1 – C3-7). These graphs indicate that the facility's fallout dust is predominantly within the lower range considered acceptable for domestic areas, despite being an industrial site. Sasol inherently does not operate a process with large amounts of dust or large stock piles of possible fugitive dust emissions, with the exception of some coal stock piles, coarse ash heaps and fine ash dams. The operational fine ash dam is wet and therefore wind-blown dust is limited. The non-operational fine ash dam has natural vegetation on the sides, but the fine ash from this non-operational fine ash dam is harvested for rehabilitation purposes of other sites within the ash storage area.

The monitoring plan philosophy is that Sasol conduct monitoring and investigate spikes in the monitoring results. In the event that a spike is observed, the problem will be addressed to ensure fugitive fallout dust is maintained within the standard.

4.5 Emergency Incidents

Unplanned downtime events such as upset conditions are undesirable from a production perspective as well as an environmental perspective and Sasol endeavours to minimise unplanned downtime by conducting regular and pro-active maintenance and ensuring control of the process within their designed operating parameters. While unplanned downtime cannot be completely eliminated, it is minimised as far as practicably possible, and rectified with high priority.

The MES prescribes that start-up, shut-down, upset and maintenance events should not exceed 48 hours – and if they do, a Section 30 NEMA incident is incurred (as also indicated in the AEL). Sasol's Secunda operations can confirm that, in the preceding two years, its facility has not exceeded the 48 hour window during start up, maintenance, upset and shutdown conditions, which has ensured that ambient impacts are limited in duration.

Sasol owns and operates accredited ambient air quality monitoring stations in the vicinity of its Secunda plant. The real-time ambient air quality monitoring data is closely followed during upset conditions at the plant, to ensure that air quality does not exceed the national ambient air quality standards as a consequence of Sasol's activities. These activities are also communicated to the Licensing Authority.

5 IMPACT OF ENTERPRISE ON THE RECEIVING ENVIRONMENT

The report includes the results for three emission scenarios per pollutant (per point source where necessary), in order to establish the delta impacts against air quality limit values. The scenarios are as follows:

- *Baseline Emissions* – modelling conducted based on the current inventory and impacts
- *Minimum Emissions Standards* – modelling conducted based on plants theoretically complying with:
 - Existing Plant Standards, and;
 - New Plant Standards
- *Alternative Emission Limits* – the emission reductions as proposed by Sasol, where applicable and different from the other three emission scenarios.

5.1 Analysis of Emissions' Impact on Human Health

5.1.1 Study Methodology

5.1.1.1 Study Plan

The study methodology may conveniently be divided into a “preparatory phase” and an “execution phase”. The basic methodology followed in this assessment is provided in Figure 5-1.

The preparatory phase included the following basic steps prior to performing the actual dispersion modelling and analyses:

1. Understand Scope of Work
2. Assign Appropriate Specialists (Appendix A)
3. Review of legal requirements (e.g. dispersion modeling guideline)
4. Prepare a Plan of Study for Peer Review
5. Decide on Dispersion Model

The Regulations regarding Air Dispersion Modelling (Gazette No 37804 vol 589; published 11 July 2014) was referenced for the dispersion model selection (Appendix B).

Three Levels of Assessment are defined in the draft Regulations Regarding Air Dispersion Modelling:

- Level 1: where worst-case air quality impacts are assessed using simpler screening models
- Level 2: for assessment of air quality impacts as part of license application or amendment processes, where impacts are the greatest within a few kilometers downwind (less than 50km)
- Level 3: require more sophisticated dispersion models (and corresponding input data, resources and model operator expertise) in situation:
 - where a detailed understanding of air quality impacts, in time and space, is required;
 - where it is important to account for causality effects, calms, non-linear plume trajectories, spatial variations in turbulent mixing, multiple source types & chemical transformations;
 - when conducting permitting and/or environmental assessment process for large industrial developments that have considerable social, economic and environmental consequences;
 - when evaluating air quality management approaches involving multi-source, multi-sector contributions from permitted and non-permitted sources in an airshed; or,

- when assessing contaminants resulting from non-linear processes (e.g. deposition, ground-level O₃, particulate formation, visibility)

The models recommended for Level 3 assessments are CALPUFF or SCIPUFF. In this study, CALPUFF was selected for the following reasons (as referenced in Figure 5-1 - *Model Aspects to Consider and Dispersion Models*):

- This Lagrangian Gaussian Puff model is also well suited to simulate low or calm wind speed conditions. Alternative regulatory models such as the US EPA AERMOD model treats all plumes as straight-line trajectories, which under calm wind conditions grossly over-estimates the plume travel distance.
- CALPUFF is able to perform chemical transformations. In this study the conversion of NO to NO₂ and the secondary formation of particulate matter was a concern.
- Convective conditions, frequently experienced in the region during summer, are effectively treated in CALPUFF.

The execution phase (i.e. dispersion modelling and analyses) firstly involves gathering specific information in relation to the emission source(s) and site(s) to be assessed. This includes:

- Source information: Emission rate, exit temperature, volume flow, exit velocity, etc.;
- Site information: Site building layout, terrain information, land use data;
- Meteorological data: Wind speed, wind direction, temperature, cloud cover, mixing height;
- Receptor information: Locations using discrete receptors and/or gridded receptors.

The model uses this specific input data to run various algorithms to estimate the dispersion of pollutants between the source and receptor. The model output is in the form of a predicted time-averaged concentration at the receptor. These predicted concentrations are added to suitable background concentrations and compared with the relevant ambient air quality standard or guideline. In some cases post-processing can be carried out to produce percentile concentrations or contour plots that can be prepared for reporting purposes.

The following steps were followed for the execution phase of the assessment:

- Decide on meteorological data input (Figure 5-1- CALMET). A summary of the model control options for CALMET is provided in Appendix D. Refer to Section 5.1.4.6.1.
- Prepare all meteorological model input files (Figure 5-1- CALMET)
 - Surface meteorological files
 - MM5 meteorological files
 - Topography
 - Land Use
- Select control options in meteorological model (Figure 5-1- CALMET)
 - Dispersion coefficients
 - Vertical levels
 - Receptor grid
- *Feedback to Project Team and revise where necessary*
- Review emissions inventory and ambient measurements
- *Feedback to Project Team and revise where necessary*
- Decide on dispersion model controls and module options (Figure 5-1- CALPUFF). A summary of the model control options for CALPUFF is provided in Appendix E. Refer to Section 5.1.4.6.3.
- Decide on dispersion module options (Figure 5-1- CALPUFF).

- Sulfate and nitrate formation module (MESOPUFF or RiVAD)
- NO₂ formation (MESOPUFF or RiVAD)
- Model resolution
- *Feedback to Project Team and revise where necessary*
- Decide on modelling domain and receptor locations (Figure 5-1– CALPUFF and Simulations)
- *Feedback to Project Team and revise where necessary*
- Prepare all dispersion model input files (Figure 5-1- CALPUFF)
 - Control options
 - Measured ambient O₃ and NH₃ for chemical transformation module
 - Meteorology
 - Source data
 - Receptor grid and discrete receptors
- Review all modelling input data files and fix where necessary
- Simulate source groups per pollutant and calculate air concentration levels for regular and discrete grid locations for the following scenarios (Figure 5-1–Simulations):
 - Baseline (current) air emissions
 - Change Baseline sources to reflect “Existing Plant”emissions standards
 - Change Baseline sources to reflect “New Plant” emissions standards
 - Change Baseline sources to reflect proposed Alternative Emission Limits, where applicable
- Compare against National Ambient Air Quality Standards (NAAQS)
- *Present Results to Project Team*
- Preparation of draft AIR
- *Present AIR to Project Team*
- Preparation of final AIR
- Updates to AIR in order to address stakeholder comments.




Figure 5-1: The basic study methodology followed for the assessment

5.1.1.2 Emission scenarios

In order to assess the impact of each of the postponements for which Sasol has applied, four emissions scenarios were modelled, with the results throughout the AIR presented as illustrated in Figure 5-2.

1. **Current baseline emissions**, reflective of the impacts of present operations, which are modelled as averages of measurements taken from continuous emission monitoring (where available) or periodic emission monitoring. This scenario is represented by the first column in the presentation of all AIR graphs (shown in blue in Figure 5-2). Baseline emissions were derived from accredited (ISO/IEC17025) 3rd parties and laboratories. Emissions measurements follow the requirements prescribed in Schedule A of GN 893. The reason baseline emissions were modelled as averages of measured point source emissions was to obtain a picture of long-term average impacts of Sasol's emissions on ambient air concentrations, which could be reasonably compared with monitored ambient concentrations, as a means of assessing the representativeness of the dispersion model's predictions. Modelling baseline emissions at a ceiling level, which is seldom reflective of actual emissions, would over-predict ambient impacts, and therefore not allow for reasonable assessment of the model's representativeness.

The following three scenarios are modelled to reflect the administrative basis of the MES, being ceiling emission levels. These scenarios are therefore theoretical cases where the point source is constantly emitting at the highest expected emission level possible under normal operating conditions, for the given scenario (i.e. the 100th percentile emission concentration).

2. **Compliance with the 2015 existing plant standards**. This is modelled as a ceiling emissions limit (i.e. maximum emission concentration) aligned with the prescribed standard, and reflects a scenario where abatement equipment is introduced to theoretically reduce emissions to conform to the standards. This scenario is represented by the second column in the presentation of all AIR graphs (shown in red in Figure 5-2). For example, this considers the renewal of ESPs and the implementation of low NO_x burners to meet Steam plant boiler existing plant standards, and some technology to theoretically achieve compliance with existing plant standards for H₂S emissions from the Sulfur Recovery plant;
3. **Compliance with the 2020 new plant standards**. This is modelled as a ceiling emissions limit (i.e. maximum emission concentration) aligned with the prescribed standard, and reflects a scenario where abatement equipment is introduced to theoretically reduce emissions to conform to the standards. This scenario is represented by the third column in the presentation of all AIR graphs (shown in green in Figure 5-2). For example, this considers the implementation of flue-gas desulphurisation (FGD) at the Steam plant's boilers, which would result in lowered flue gas temperatures from the boilers with a resulting detrimental effect on the co-dispersion of other pollutants including NO_x and PM; and,
4. **A worst-case scenario of operating constantly at the requested alternative emissions limits**, which have been specified as ceiling emissions limits (i.e. maximum emission concentrations). This scenario is represented by the fourth column in the presentation of all AIR graphs (shown in purple in Figure 5-2). It is re-emphasised that Sasol Synfuels will not physically increase its current baseline emissions (expressed as an average). In some instances the scenario appears higher than the baseline, only because it portrays the worst case outcome where the 100th percentile emission rate occurs under the 99th percentile worst meteorological conditions – and this is modelled assuming these conditions prevail for the entire duration of the modelling period. Sasol Synfuels seeks alternative emissions limits which are aligned with the manner in which the MES are stated and which accommodate the natural variability inherent in emissions under different operating conditions, and hence must request a ceiling emissions limit rather than an average emissions limit. The alternative emission limit is hence simply a different way of expressing current baseline

emissions (in cases where further abatement is not possible), or may even reflect a reduction in average baseline emissions (in cases where further abatement is possible, but not to a level which achieves compliance with the MES ceiling emissions limits).




Figure 5-2: Schematic displaying how the dispersion modelling scenarios are presented, for each receptor point in the modelling domain

In Figure 5-2, the black arrows above the red and green bars reflect the predicted delta (change) in ambient impacts of Sasol Synfuels' baseline emissions versus the given compliance scenario. At a practical level, the white arrow on the purple bar represents the theoretical delta increase in short-term ambient impacts, where 100th percentile emissions occur, compared with the predicted impact of average current baseline emissions. The blue dot in Figure 5-2 represents physically measured ambient air quality, reflective of the total impact of all sources in the vicinity, as the 99th percentile recorded value over the averaging period. On a given day, there is a 99% chance that the actual measured ambient air quality would be lower than this value, but this value is reflected for the purpose of aligning with modelling requirements. The orange line represents the applicable National Ambient Air Quality Standard (NAAQS) or, where not available, relevant international health-effect screening level, used for interpretation of the dispersion modelling results, as described in Section 5.1.8.2.

5.1.1.3 CALPUFF/CALMET Modelling Suite

As discussed in the previous section, the CALPUFF model was selected for use in the current investigation to predict maximum short-term (1 and 24-hour) and annual average ground-level concentrations at various receptor locations within the computational domains. CALPUFF is a multi-layer, multi-species non-steady-state puff dispersion model that can simulate the effects of time- and space-varying meteorological conditions on pollutant transport, transformation, and removal (Scire et al, 2000a). It can accommodate arbitrarily varying point source, area source, volume source, and line source emissions. The CALPUFF code includes algorithms for near-source effects such as building downwash, transitional plume rise, partial plume penetration, sub grid scale terrain interactions as well as longer range effects such as pollutant removal due to wet scavenging and dry deposition, chemical transformation, vertical wind shear, overwater transport and coastal interaction effects.

It is intended for use on scales from tens of metres to hundreds of kilometres from a source (US EPA 1998). A number of dispersion coefficients options are accommodated, including

- stability-based empirical relationships such as the Pasquill-Gifford or McElroy-Pooler dispersion coefficients;
- turbulence-based dispersion coefficients (based on measured standard deviations of the vertical and crosswind horizontal components of the wind); and
- similarity theory to estimate the turbulent quantities using the micrometeorological variables calculated by CALMET

The most desirable approach is to use turbulence-based dispersion coefficients using measured turbulent velocity variances or intensity components, if such data are readily available and they are of good quality. However, since reliable turbulent measurements are generally not available, the next best recommendation is to use the similarity approach.

CALPUFF also has the capability to model the effects of vertical wind shear by explicitly allowing different puffs to be independently advected by their local average wind speed and direction, as well as by optionally allowing well-mixed puffs to split into two or more puffs when across-puff shear becomes important. Another refinement is an option to use a probability density function (pdf) model to simulate vertical dispersion during convective conditions.

CALPUFF includes parameterized chemistry modules for the formation of secondary sulfate and nitrate from the oxidation of the emitted primary pollutants, SO₂ and NO_x. The conversion processes are assumed to be linearly dependent (first-order) on the relevant primary species concentrations. Two options are included, namely the MESOPUFF II and RIVAD/ARM3 chemistry options. In both options, a fairly simple stoichiometric thermodynamic model is used to estimate the partitioning of total inorganic nitrate between gas-phase nitric acid and particle-phase ammonium nitrate. Ammonia and ozone concentrations are required as background values to the model.

CALPUFF uses dry deposition velocities to calculate the dry deposition of gaseous and particulate pollutants to the surface. These dry deposition velocities can either be user-specified or calculated internally in CALPUFF. A resistance-based model is used for the latter option. For gaseous pollutants, the resistances that are considered are the atmospheric resistance, the deposition layer resistance, and the canopy resistance. For particles, a gravitational settling term is included and the canopy resistance is assumed to be negligible. CALPUFF uses the scavenging coefficient approach to parameterize wet deposition of gases and particles. The scavenging coefficient depends on pollutant characteristics (e.g., solubility and reactivity), as well as the precipitation rate and type of precipitation. The model provides default values for the scavenging coefficient for various species and two types of precipitation (liquid and frozen). These values may be overridden by the user.

The CALPUFF modelling system consists of a number of components, as summarised in Table 5-1, however only CALMET and CALPUFF contain the simulation engines to calculate the three-dimensional atmospheric boundary layer conditions and the dispersion and removal mechanisms of pollutants released into this boundary layer. The other codes are mainly used to assist with the preparation of input and output data. Table 5-1 also includes the development versions of each of the codes used in the investigation.

Table 5-1: Summary description of CALPUFF/CALMET model suite with versions used in the investigation

| Module | Version | Description |
|----------|------------------------|---|
| CALMET | v6.334 | Three-dimensional, diagnostic meteorological model |
| CALPUFF | v6.42 | Non-steady-state Gaussian puff dispersion model with chemical removal, wet and dry deposition, complex terrain algorithms, building downwash, plume fumigation and other effects. |
| CALPOST | V6.292 | A post-processing program for the output fields of meteorological data, concentrations and deposition fluxes. |
| CALSUM | v1.4 ⁽¹⁾ | Sums and scales concentrations or wet/dry fluxes from two or more source groups from different CALPUFF runs |
| PRTMET | v 4.495 ⁽¹⁾ | Lists selected meteorological data from CALMET and creates plot files |
| POSTUTIL | v1.641 ⁽¹⁾ | Processes CALPUFF concentration and wet/dry flux files. Creates new species as weighted combinations of modelled species; merges species from different runs into a single output file; sums and scales results from different runs; repartitions nitric acid/nitrate based on total available sulfate and ammonia. |
| TERREL | v3.69 ⁽¹⁾ | Combines dna grids terrain data |
| CTGPROC | v3.5 ⁽¹⁾ | processes and grids land use data |
| MAKEGEO | v3.2 ⁽¹⁾ | merges land use and terrain data to produce the geophysical data file for CALMET |

Note ⁽¹⁾: These modules indicate version number as listed on http://www.src.com/calpuff/download/mod6_codes.htm (for CALPro Plus v6) [version number not given in GUI interface or 'About' information].

A summary of the main CALMET and CALPUFF control options are given in Appendices D and E, respectively.

5.1.2 Legal Requirements

5.1.2.1 Atmospheric Impact Report

In the event where an application for postponement is being made, Section 21 of NEM: Air Quality Act (AQA), Regulations 11 and 12 state:

1. An application for postponement may be made to the National Air Quality Officer
2. The application contemplated in Regulation 11 must include, amongst others, an Atmospheric Impact Report

The format of the Atmospheric Impact Report is stipulated in the Regulations Prescribing the Format of the Atmospheric Impact Report, Government Gazette No. 36904, Notice Number 747 of 2013 (11 October 2013) (Appendix B; Table B-1).

Sasol appointed Airshed to compile this AIR to meet the requirements of Regulation 12 (Postponement of compliance time frames) of the Listed Activities and Associated Minimum Emissions Standards (Government Gazette No. 37054, 22 November 2013) (Appendix B; Table B-2).

5.1.2.2 National Ambient Air Quality Standards (NAAQS)

Modelled concentrations will be assessed against NAAQS (Table 5-2), where they are prescribed by South African legislation. Where no NAAQS exists for a relevant non-criteria pollutant, health screening effect levels based on international guidelines are used. These are discussed with the results of dispersion modelling in Section 5.1.8.2.

Table 5-2: National Ambient Air Quality Standards

| Pollutant | Averaging Period | Concentration ($\mu\text{g}/\text{m}^3$) | Permitted Frequency of Exceedance | Compliance Date |
|------------------------------------|-----------------------|--|-----------------------------------|--------------------------------------|
| Benzene (C_6H_6) | 1 year | 10 | 0 | Immediate till 31 December 2014 |
| | 1 year | 5 | 0 | 1 January 2015 |
| Carbon Monoxide (CO) | 1 hour | 30000 | 88 | Immediate |
| | 8 hour ^(a) | 10000 | 11 | Immediate |
| Lead (Pb) | 1 year | 0.5 | 0 | Immediate |
| Nitrogen Dioxide (NO_2) | 1 hour | 200 | 88 | Immediate |
| | 1 year | 40 | 0 | Immediate |
| Ozone (O_3) | 8 hour ^(b) | 120 | 11 | Immediate |
| PM _{2.5} | 24 hour | 65 | 4 | Immediate till 31 December 2015 |
| | 24 hour | 40 | 4 | 1 January 2016 till 31 December 2029 |
| | 24 hour | 25 | 4 | 1 January 2030 |
| | 1 year | 25 | 0 | Immediate till 31 December 2015 |
| | 1 year | 20 | 0 | 1 January 2016 till 31 December 2029 |
| | 1 year | 15 | 0 | 1 January 2030 |
| PM ₁₀ | 24 hour | 120 | 4 | Immediate till 31 December 2014 |
| | 24 hour | 75 | 4 | 1 January 2015 |
| | 1 year | 50 | 0 | Immediate till 31 December 2014 |
| | 1 year | 40 | 0 | 1 January 2015 |
| Sulfur Dioxide (SO_2) | 10 minutes | 500 | 526 | Immediate |
| | 1 hour | 350 | 88 | Immediate |
| | 24 hour | 125 | 4 | Immediate |
| | 1 year | 50 | 0 | Immediate |

Notes: (a) Calculated on 1 hour averages. (b) Running average.

5.1.3 Regulations regarding Air Dispersion Modelling

Air dispersion modelling provides a cost-effective means for assessing the impact of air emission sources, the major focus of which is to determine compliance with the relevant ambient air quality standards. Regulations regarding Air Dispersion Modelling were promulgated in Government Gazette No. 37804 vol. 589; 11 July 2014, and recommend a suite of dispersion models to be applied for regulatory practices as well as guidance on modelling input requirements, protocols and procedures to be followed. The Regulations regarding Air Dispersion Modelling are applicable –

- (a) in the development of an air quality management plan, as contemplated in Chapter 3 of the AQA;
- (b) in the development of a priority area air quality management plan, as contemplated in section 19 of the AQA;
- (c) in the development of an atmospheric impact report, as contemplated in section 30 of the AQA; and,
- (d) in the development of a specialist air quality impact assessment study, as contemplated in Chapter 5 of the AQA.

The Regulations have been applied to the development of this report. The first step in the dispersion modelling exercise requires a clear objective of the modelling exercise and thereby gives clear direction to the choice of the dispersion model most suited for the purpose. Chapter 2 of the Regulations present the typical levels of assessments, technical summaries of the prescribed models (SCREEN3, AERSCREEN, AERMOD, SCIPUFF, and CALPUFF) and good practice steps to be taken for modelling applications.

Dispersion modelling provides a versatile means of assessing various emission options for the management of emissions from existing or proposed installations. Chapter 3 of the Regulations prescribe the source data input to be used in the models. Dispersion modelling can typically be used in the:

- Apportionment of individual sources for installations with multiple sources. In this way, the individual contribution of each source to the maximum ambient predicted concentration can be determined. This may be extended to the study of cumulative impact assessments where modelling can be used to model numerous installations and to investigate the impact of individual installations and sources on the maximum ambient pollutant concentrations.
- Analysis of ground level concentration changes as a result of different release conditions (e.g. by changing stack heights, diameters and operating conditions such as exit gas velocity and temperatures).
- Assessment of variable emissions as a result of process variations, start-up, shut-down or abnormal operations.
- Specification and planning of ambient air monitoring programs which, in addition to the location of sensitive receptors, are often based on the prediction of air quality hotspots.

The above options can be used to determine the most cost-effective strategy for compliance with the NAAQS. Dispersion models are particularly useful under circumstances where the maximum ambient concentration approaches the ambient air quality limit value and provide a means for establishing the preferred combination of mitigation measures that may be required including:

- Stack height increases;
- Reduction in pollutant emissions through the use of air pollution control systems (APCS) or process variations;
- Switching from continuous to non-continuous process operations or from full to partial load.

Chapter 4 of the Regulations prescribe meteorological data input from onsite observations to simulated meteorological data. The chapter also gives information on how missing data and calm conditions are to be treated in modelling applications.

Meteorology is fundamental for the dispersion of pollutants because it is the primary factor determining the diluting effect of the atmosphere. Therefore, it is important that meteorology is carefully considered when modelling.

New generation dispersion models, including models such as AERMOD and CALPUFF¹, simulate the dispersion process using planetary boundary layer (PBL) scaling theory. PBL depth and the dispersion of pollutants within this layer are influenced by specific surface characteristics such as surface roughness, albedo and the availability of surface moisture:

- Roughness length (z_0) is a measure of the aerodynamic roughness of a surface and is related to the height, shape and density of the surface as well as the wind speed.
- Albedo is a measure of the reflectivity of the Earth's surface. This parameter provides a measure of the amount of incident solar radiation that is absorbed by the Earth/atmosphere system. It is an important parameter since absorbed solar radiation is one of the driving forces for local, regional, and global atmospheric dynamics.
- The Bowen ratio provides measures of the availability of surface moisture injected into the atmosphere and is defined as the ratio of the vertical flux of sensible heat to latent heat, where sensible heat is the transfer of heat from the surface to the atmosphere via convection and latent heat is the transfer of heat required to evaporate liquid water from the surface to the atmosphere.

Topography is also an important geophysical parameter. The presence of terrain can lead to significantly higher ambient concentrations than would occur in the absence of the terrain feature. In particular, where there is a significant relative difference in elevation between the source and off-site receptors large ground level concentrations can result. Thus the accurate determination of terrain elevations in air dispersion models is very important.

The modelling domain would normally be decided on the expected zone of influence; the latter extent being defined by the predicted ground level concentrations from initial model runs. The modelling domain must include all areas where the ground level concentration is significant when compared to the air quality limit value (or other guideline). Air dispersion models require a receptor grid at which ground-level concentrations can be calculated. The receptor grid size should include the entire modelling domain to ensure that the maximum ground-level concentration is captured and the grid resolution (distance between grid points) sufficiently small to ensure that areas of maximum impact adequately covered. No receptors however should be located within the property line as health and safety legislation (rather than ambient air quality standards) is applicable within the site.

Chapter 5 provides general guidance on geophysical data, model domain and coordinates system required in dispersion modelling, whereas Chapter 6 elaborates more on these parameters as well as the inclusion of background air concentration data. The chapter also provides guidance on the treatment of NO₂ formation from NO_x emissions, chemical transformation of sulfur dioxide into sulfates and deposition processes.

Chapter 7 of the Regulations outline how the plan of study and modelling assessment reports are to be presented to authorities. A comparison of how this study met the requirements of the Regulations is provided in Appendix B.

¹ The CALMET modelling system require further geophysical parameters including surface heat flux, anthropogenic heat flux and leaf area index (LAI).

5.1.4 Atmospheric Dispersion Processes

CALPUFF initiates the simulation of point source plumes with a calculation of buoyant plume rise as discussed below in Section 5.1.3.1. Transport winds are extracted from the meteorological data file at the location of the stack and at the effective plume height (stack height plus plume rise). For near-field effects, the height of the plume in transition to the final plume height is taken into account. The puff release rate is calculated internally, based on the transport speed and the distance to the closest receptor.

As the puff is transported downwind, it grows due to dispersion and wind shear, and the trajectory is determined by advection winds at the puff location and height at each time step. The pollutant mass within each puff is initially a function of the emission rate from the original source. The pollutant mass is also subject to chemical transformation, washout by rain and dry deposition, when these options are selected, as is the case in this application. Chemical transformation and removal are calculated based on a one-hour time step.

Both wet and dry deposition fluxes are calculated by CALPUFF, based on a full resistance model for dry deposition and the use of precipitation rate-dependent scavenging coefficients for wet deposition. Pollutant mass is removed from the puff due to deposition at each time step. For the present modelling analyses, most options were set at "default" values, including the MESOPUFF II transformation scheme² and the treatment of terrain.

5.1.4.1 Plume Buoyancy

Gases leaving a stack mix with ambient air and undergo three phases namely the initial phase, the transition phase and the diffusion phase (Figure 5-3). The initial phase is greatly determined by the physical properties of the emitted gases. These gases may have momentum as they enter the atmosphere and are often heated and are therefore warmer than the ambient air. Warmer gases are less dense than the ambient air and are therefore buoyant. A combination of the gases' momentum and buoyancy causes the gases to rise (vertical jet section, in Figure 5-3). In the Bent-Over Jet Section, entrainment of the cross flow is rapid because, by this time, appreciable growth of vortices has taken place. The self-generated turbulence causes mixing and determines the growth of plume in the thermal section. This is referred to as plume rise and allows air pollutants emitted in this gas stream to be lifted higher in the atmosphere. Since the plume is higher in the atmosphere and at a further distance from the ground, the plume will disperse more before it reaches ground level. With greater volumetric flow and increased exit gas temperatures, the plume centreline would be higher than if either the volumetric flow or the exit gas temperature is reduced. The subsequent ground level concentrations would therefore be lower.

This is particularly important in understanding some of the dispersion model results in Section 5.1.7. As an example, consider the emissions from a boiler. With the introduction of retrofitted emission controls (e.g. wet scrubber or bag filters), the exit gas temperature and perhaps the volumetric flow would be lower than the original values. Thus it is quite possible that the resultant decrease in plume momentum and buoyancy may actually result in higher ground level concentrations despite the reduction in point source emission concentrations, due to the lower plume centreline.

² A sensitivity study was carried out with the RIVAD II transformation scheme to examine the performance of the different approaches to calculating the SO₂ to SO₄ and NO_x to NO₃ transformation rates. The concentrations from the RIVAD II and the MESOPUFF II transformation schemes showed no real bias with the secondary particulate formation varying by -41% to 31% for the two schemes.




Figure 5-3: Plume buoyancy

5.1.4.2 Urban and Rural Conditions

Land use information is important to air dispersion modelling, firstly to ensure that the appropriate dispersion coefficients and wind profiles (specified as surface roughness) are used, and secondly, that the most appropriate chemical transformation models are employed. Urban conditions result in different dispersion conditions than in rural areas, as well as changing the vertical wind profiles. Urban conditions are also generally associated with increased levels of volatile organic compounds (VOCs), thereby influencing chemical equilibriums between the photochemical reactions of NO_x , CO and O_3 .

It can be appreciated that the definition of urban and rural conditions for the dispersion coefficients and wind profiles, on the one hand, and chemical reactions on the other, may not be the same. Nonetheless, it was decided to use the US Environmental Protection Agency's (US EPA) guideline on air dispersion models (US EPA 2005), to classify the surrounding land-use as rural or urban based on the Auer method, which is strictly recommended for selecting dispersion coefficients.

The classification scheme is based on the activities within a 3 km radius of the emitting stack. Areas typically defined as rural include residences with grass lawns and trees, large estates, metropolitan parks and golf courses, agricultural areas, undeveloped land and water surfaces. An area is defined as urban if it has less than 35% vegetation coverage or the area falls into one of the use types in Table 5-3.

Table 5-3: Definition of vegetation cover for different developments (US EPA 2005)

| Urban Land-Use | | |
|----------------|---------------------------|------------------|
| Type | Development Type | Vegetation Cover |
| I1 | Heavy industrial | Less than 5% |
| I2 | Light/moderate industrial | Less than 10% |
| C1 | Commercial | Less than 15% |
| R2 | Dense/multi-family | Less than 30% |
| R3 | Multi-family, two storey | Less than 35% |

According to this classification scheme, the Sasol Secunda facility is classified as urban.

5.1.4.3 Nitrogen Dioxide Formation

Of the several species of nitrogen oxides, only NO₂ is specified in the NAAQS. Since most sources emit uncertain ratios of these species and these ratios change further in the atmosphere due to chemical reactions, a method for determining the amount of NO₂ in the plume must be selected.

Estimation of this conversion normally follows a tiered approach, as discussed in the draft Regulations Regarding Air Dispersion Modelling (Gazette No 35981 published 14 December 2012), which presents a scheme for annual averages:

Tier 1: Total Conversion Method

Use any of the appropriate models recommended to estimate the maximum annual average NO₂ concentrations by assuming a total conversion of NO to NO₂. If the maximum NO_x concentrations are less than the NAAQS for NO₂, then no further refinement of the conversion factor is required. If the maximum NO_x concentrations are greater than the NAAQS for NO₂, or if a more "realistic" estimate of NO₂ is desired, proceed to the second tier level.

Tier 2: Ambient Ratio Method (ARM) - Multiply NO_x by a national ratio of NO₂/NO_x = 0.80

Assume a wide area quasi-equilibrium state and multiply the Tier 1 empirical estimate NO_x by a ratio of NO₂/NO_x = 0.80. The ratio is recommended for South Africa as the conservative ratio based on a review of ambient air quality monitoring data from the country. If representative ambient NO and NO₂ monitoring data is available (for at least one year of monitoring), and the data is considered to represent a quasi-equilibrium condition where further significant changes of the NO/NO₂ ratio is not expected, then the NO/NO₂ ratio based on the monitoring data can be applied to derive NO₂ as an alternative to the national ratio of 0.80.

In the Total Conversion Method, the emission rate of all NO_x species is used in the dispersion model to predict ground-level concentrations of total NO_x. These levels of NO_x are assumed to exist as 100% NO₂, and are directly compared to the NAAQS for NO₂. If the NAAQS are met, the Tier 2 methods are not necessary.

Although not provided in the draft Regulations (Gazette No 35981 published 14 December 2012), the conversion of NO to NO₂ may also be based on the amount of ozone available within the volume of the plume. The NO₂/NO_x conversion ratio is therefore coupled with the dispersion of the plume. This is known as the Ozone Limiting Method (OLM). Use of onsite ozone data is always preferred for the OLM method.

Ideally, the NO₂ formation should be dealt with in the dispersion model. CALPUFF has one such a module, known as the RIVAD / ARM3 chemical formulations. The RIVAD / ARM3 chemical formulations option in the CALPUFF model can be

used to calculate NO₂ concentrations directly in rural (non-urban) areas (Morris *et al.*, 1988). The RIVAD / ARM3 option incorporates the effect of chemical and photochemical reactions on the formation of nitrates and other deposition chemicals. However, since the Secunda study area was classified as urban (Section 5.1.4.2), the RIVAD / ARM3 chemical formulations should not be used.

Whilst the MESOPUFF II chemical transformation scheme, which is also included in the CALPUFF model accommodates NO_x reactions, these are only considering the formation of nitrates and not the NO /NO₂ reactions.

Given all of the above limitations, it was decided to employ the Ambient Ratio Method (ARM), i.e. the second version of the DEA Tier 2 option. The ARM ambient ratio method is based upon the premise that the NO₂/NO_x ratio in a plume changes as it is transported but attains an equilibrium value some distance away from the source (Scire and Borissova, 2011). In their study, Scire and Borissova analysed hourly monitored NO₂ and NO_x data for 2006 at 325 monitoring sites throughout USA, which amounted to approximately 2.8 million data points for each species. These observations were grouped into a number of concentration ranges (bins), and the binned data were used to compute bin maximums and bin average curves. Short-term (1-hr) NO₂/NO_x ratios were subsequently developed based on bin-maximum data. Similarly, long-term (annual average) NO₂/NO_x ratios were based on bin-averaged data. The method was tested using the NO₂/NO_x ratios applied to the observed NO_x at selected stations to predict NO₂, and then compared to observed NO₂ concentrations at that station. The comparison of NO₂ derived from observed NO_x using these empirical curves was shown to be a conservative estimate of observed NO₂, whilst at the same time arriving at a more realistic approximation than if simply assuming a 100% conversion rate. More details of the adopted conversion factors are given in Appendix F.

5.1.4.4 Particulate Formation

CALPUFF includes two chemical transformation schemes for the calculation of sulfate and nitrate formation from SO₂ and NO_x emissions. These are the MESOPUFF II and the RIVAD / ARM3 chemical formulations. Whilst the former scheme is not specifically restricted to urban or rural conditions; the latter was developed for use in rural conditions. Since the Secunda study area could be classified as urban (Section 5.1.5), the RIVAD / ARM3 chemical formulations should not be used. The chemical transformation scheme chosen for this analysis was therefore the MESOPUFF II scheme. As described in the CALPUFF User Guide it is a “pseudo first-order chemical reaction mechanism” and involves five pollutant species namely SO₂, sulfates (SO₄), NO_x, nitric acid (HNO₃) and particulate nitrate. CALPUFF calculates the rate of transformation of SO₂ to SO₄, and the rate of transformation of NO_x to NO₃, based on environmental conditions including the ozone concentration, atmospheric stability, solar radiation, relative humidity, and the plume NO_x concentration. The daytime reaction formulation depends on solar radiation and the transformation increases non-linearly with the solar radiation (see the SO₂ to SO₄ transformation rate equation (equation 2-253 in the CALPUFF User Guide). At night, the transformation rate defaults to a constant value of 0.2% per hour. Calculations based on these formulas show that the transformation rate can reach about 3 per cent per hour at noon on a cloudless day with 100 ppb of ozone.

With the MESOPUFF-II mechanism, NO_x transformation rates depend on the concentration levels of NO_x and O₃ (equations 2-254 and 2-255 in the CALPUFF User Guide) and both organic nitrates (RNO₃) and HNO₃ are formed. According to the scheme, the formation of RNO₃ is irreversible and is not subject to wet or dry deposition. The formation of HNO₃, however, is reversible and is a function of temperature and relative humidity. The formation of particulate nitrate is further determined through the reaction of HNO₃ and NH₃. Background NH₃ concentrations are therefore required as input to calculate the equilibrium between HNO₃ and particulate nitrate. At night, the NO_x transformation rate defaults to a constant value of 2.0% per hour. Hourly average ozone and ammonia concentrations were included as input in the CALPUFF model to facilitate

these sulfate and nitrate formation calculations (adjusting for the respective molecular weights of ammonium sulfate and ammonium nitrate).

The limitation of the CALPUFF model is that each puff is treated in isolation, i.e. any interaction between puffs from the same or different points of emission is not accounted for in these transformation schemes. CALPUFF first assumes that ammonia reacts preferentially with sulfate, and that there is always sufficient ammonia to react with the entire sulfate present within a single puff. The CALPUFF model performs a calculation to determine how much NH_3 remains after the particulate ammonium sulfate has been formed and the balance would then be available for reaction with NO_3 within the puff to form ammonium nitrate. The formation of particulate nitrate is subsequently limited by the amount of available NH_3 . Although this may be regarded a limitation, in this application the particulate formation is considered as a group and not necessarily per species.

5.1.4.5 Ozone Formation

Similar to sulphate, nitrate and nitrogen dioxide, ozone (O_3) can also be formed through chemical reactions between pollutants released into the atmosphere. As a secondary pollutant, O_3 is formed in the lower part of the atmosphere, from complex photochemical reactions following emissions of precursor gases such as NO_x and VOCs (Seinfeld and Pandis, 1998). O_3 is produced during the oxidation of CO and hydrocarbons by hydroxyls (OH) in the presence of NO_x and sunlight (Seinfeld and Pandis, 1998). The rate of ozone production can therefore be limited by CO, VOCs or NO_x . In densely populated regions with high emissions of NO_x and hydrocarbons, rapid O_3 production can take place and result in a surface air pollution problem. In these urban areas O_3 formation is often VOC-limited. O_3 is generally NO_x -limited in rural areas and downwind suburban areas.

O_3 concentration levels have the potential to become particularly high in areas where considerable O_3 precursor emissions combine with stagnant wind conditions during the summer, when high insolation and temperatures occur (Seinfeld and Pandis, 1998). The effects of sunlight on O_3 formation depend on its intensity and its spectral distribution.

The main sectors that emit ozone precursors are road transport, power and heat generation plants, household (heating), industry, and petrol storage and distribution. In many urban areas, O_3 nonattainment is not caused by emissions from the local area alone. Due to atmospheric transport, contributions of precursors from the surrounding region can also be important. The transport of O_3 is determined by meteorological and chemical processes which typically extend over spatial scales of several hundred kilometres. Thus, in an attempt to study O_3 concentrations in a local area, it is necessary to include regional emissions and transport. This requires a significantly larger study domain with the inclusion of a significantly more comprehensive emissions inventory of NO_x and VOCs sources (e.g. vehicle emissions in Gauteng). Such a collaborative study was not within the scope of this report.

5.1.4.6 Model Input

5.1.4.6.1 Meteorological Input Data

The option of Partial Observations was selected for the CALMET wind field model which used both measured and observed meteorological data (refer to Appendix D for all CALMET control options). For measured data, use was made of PSU/NCAR mesoscale model (known as MM5). MM5 is an acronym for the Fifth-Generation NCAR/Penn State Mesoscale Model, which is a limited-area, nonhydrostatic, terrain-following sigma-coordinate model designed to simulate or predict mesoscale and

regional-scale atmospheric circulation. Terrestrial and isobaric meteorological data are horizontally interpolated with observations from the standard network of surface and rawinsonde stations. MM5 data for the period 2010 to 2012 on a 12 km horizontal resolution for a 300 km by 300 km was used. MM5 data was supplemented with surface field observations from the monitoring stations operated by Sasol. For CALMET, the surface data was consolidated into one source file, taking the most representative data set into account. Meteorological parameters provided for the Sasol monitoring stations in the Secunda surrounds are provided in Table 5-4.

Table 5-4: Meteorological parameters provided for the Sasol monitoring stations in the vicinity of Secunda

| Monitoring Station | Latitude | Longitude | Closest Residential Area | Meteorology | | | | | | |
|--------------------|------------|-----------|--------------------------|-------------|----|------|---------|-------|---------|------|
| | | | | WD | WS | Temp | Rel Hum | Press | Sol rad | Rain |
| Bosjesspruit | -26.605833 | 29.210833 | Secunda | ✓ | ✓ | ✓ | | | ✓ | ✓ |
| Secunda Club | -26.523333 | 29.189667 | Secunda | ✓ | ✓ | ✓ | ✓ | ✓ | | ✓ |
| Langverwacht | -26.551667 | 29.112500 | Secunda | ✓ | ✓ | ✓ | ✓ | | ✓ | ✓ |

5.1.4.6.2 Land Use and Topographical Data

Readily available terrain and land cover data for use in CALMET was obtained from the Atmospheric Studies Group (ASG) via the United States Geological Survey (USGS) web site at ASG. Use was made of Shuttle Radar Topography Mission (SRTM) (90 m, 3 arc-sec) data and Lambert Azimuthal land use data for Africa.

5.1.4.6.3 Dispersion Coefficients

The option of dispersion coefficients from internally calculated sigma v, sigma w using micrometeorological variables (u^* , w^* , L , etc.) was selected (refer to Appendix E for all CALPUFF control options).

5.1.4.6.4 Grid Resolution and Model Domain

The CALMET modelling domain included an area of 300 km by 300 km with a grid resolution of 1 km. The vertical profile included ten vertical levels up to a height of 3 500 m. The CALPUFF model domain selected for the point sources at the Secunda complex included an area of 50 km by 50 km with a grid resolution of 200 m.

5.1.5 Atmospheric Dispersion Potential

Meteorological mechanisms govern the dispersion, transformation, and eventual removal of pollutants from the atmosphere. The analysis of hourly average meteorological data is necessary to facilitate a comprehensive understanding of the dispersion potential of the site. The horizontal dispersion of pollution is largely a function of the wind field. The wind speed determines both the distance of downward transport and the rate of dilution of pollutants.

Sasol currently operates three meteorological stations in the Secunda area (viz. Bosjesspruit, Langverwacht and Secunda Club). For this assessment, data was provided for Bosjesspruit, Langverwacht and Secunda Club monitoring stations for

the period 2010 to 2012. Parameters useful in describing the dispersion and dilution potential of the site i.e. wind speed, wind direction, temperature and atmospheric stability, are subsequently discussed. A summary of the measured meteorological data is given in Appendix G.

5.1.5.1 Surface Wind Field

Wind roses comprise 16 spokes, which represent the directions from which winds blew during a specific period. The colours used in the wind roses below, reflect the different categories of wind speeds; the red area, for example, representing winds >6m/s. The dotted circles provide information regarding the frequency of occurrence of wind speed and direction categories. The frequency with which calms occurred, i.e. periods during which the wind speed was below 1 m/s are also indicated.

The period wind field and diurnal variability for Langverwacht, Bosjesspruit and Secunda Club are provided in Figure 5-4, Figure 5-5, and Figure 5-6, respectively. The predominant wind direction at Langverwacht is from the east-northeast with high frequency of winds from this direction occurring during night-time conditions. The predominant wind direction for Bosjesspruit is from the northeast. The predominant wind direction at Secunda Club for the period 2010-2012 is from the west-northwest and from the northeast to east. More predominant westerly wind flow occurs during day-time conditions with an increase in eastly flow during night-time conditions. The extracted wind flow from CALMET (Figure 5-7) at Secunda Club receptor point reflects similar wind flow as measured data with the predominant wind direction from the west-northwest and from the northeast to east.




Figure 5-4: Period, day- and night-time wind rose for Langverwacht for the period 2010 - 2012




Figure 5-5: Period, day- and night-time wind rose for Bosjesspruit for the period 2010 - 2012




Figure 5-6: Period, day- and night-time wind rose for Secunda Club for the period 2010 - 2012




Figure 5-7: Period, day- and night-time wind rose for an extracted CALMET point at Secunda Club for the period 2010 - 2012

5.1.5.2 Temperature

Air temperature is important, both for determining the effect of plume buoyancy (the larger the temperature difference between the emission plume and the ambient air, the higher the plume is able to rise), and determining the development of the mixing and inversion layers.

The average monthly temperature trends are presented Figure 5-8, Figure 5-9 and Figure 5-10 for Langverwacht, Bosjesspruit and Secunda Club respectively. Monthly mean and hourly maximum and minimum temperatures are given in Table 5-5. Average temperatures ranged between 2.7 °C and 19.6 °C. The highest temperatures occurred in February to March and the lowest in June to July. During the day, temperatures increase to reach maximum at around 15:00 in the afternoon. Ambient air temperature decreases to reach a minimum at around 07:00 i.e. just before sunrise.

Table 5-5: Monthly temperature summary (2010 - 2012)

| Hourly Minimum, Hourly Maximum and Monthly Average Temperatures (°C) (2010 - 2012) | | | | | | | | | | | | |
|---|------|------|------|------|------|------|------|------|------|------|------|------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
| Langverwacht | | | | | | | | | | | | |
| Minimum | 15.3 | 14.1 | 12.3 | 8.5 | 4.4 | -1.2 | -1.3 | 1.6 | 7.6 | 11.1 | 13.1 | 14.5 |
| Maximum | 24.7 | 26.0 | 26.3 | 21.6 | 21.3 | 18.0 | 17.9 | 21.5 | 25.1 | 25.7 | 25.4 | 24.9 |
| Average | 19.5 | 19.6 | 18.7 | 14.3 | 11.7 | 7.0 | 7.3 | 10.8 | 15.6 | 17.9 | 18.8 | 19.5 |
| Bosjesspruit | | | | | | | | | | | | |
| Minimum | 9.9 | 13.7 | 14.6 | 12.1 | 5.5 | -3.7 | -3.2 | 0.4 | 7.3 | 7.6 | 12.3 | 11.0 |
| Maximum | 18.0 | 25.1 | 25.9 | 21.9 | 19.2 | 11.4 | 12.6 | 17.2 | 21.2 | 22.0 | 22.8 | 22.0 |
| Average | 13.0 | 18.8 | 19.6 | 16.2 | 11.5 | 2.7 | 3.7 | 8.0 | 13.5 | 14.4 | 17.0 | 16.9 |
| Secunda Club | | | | | | | | | | | | |
| Minimum | 14.4 | 13.6 | 12.7 | 9.4 | 6.1 | 1.6 | 1.2 | 3.7 | 8.7 | 11.3 | 10.4 | 14.2 |
| Maximum | 23.7 | 25.1 | 25.1 | 20.9 | 21.1 | 18.1 | 18.0 | 21.2 | 24.5 | 25.0 | 22.1 | 24.3 |
| Average | 18.7 | 19.0 | 18.3 | 14.5 | 12.7 | 8.8 | 8.8 | 11.8 | 15.9 | 17.7 | 15.8 | 18.9 |




Figure 5-8: Monthly average temperature profile for Langverwacht (2010 – 2012)




Figure 5-9: Monthly average temperature profile for Bosjesspruit (2010 – 2012)




Figure 5-10: Monthly average temperature profile for Secunda Club (2010 – 2012)

5.1.5.3 Atmospheric Stability

The atmospheric boundary layer properties are described by two parameters; the boundary layer depth and the Monin-Obukhov length.

The Monin-Obukhov length (L_{Mo}) provides a measure of the importance of buoyancy generated by the heating of the ground and mechanical mixing generated by the frictional effect of the earth's surface. Physically, it can be thought of as representing the depth of the boundary layer within which mechanical mixing is the dominant form of turbulence generation (CERC, 2004). The atmospheric boundary layer constitutes the first few hundred metres of the atmosphere. During daytime, the atmospheric boundary layer is characterised by thermal turbulence due to the heating of the earth's surface. Night-times are characterised by weak vertical mixing and the predominance of a stable layer. These conditions are normally associated with low wind speeds and lower dilution potential.

Diurnal variation in atmospheric stability, as calculated from on-site data, and described by the inverse Monin-Obukhov length and the boundary layer depth is provided in Figure 5-11. The highest concentrations for ground level, or near-ground level releases from non-wind dependent sources would occur during weak wind speeds and stable (night-time) atmospheric conditions.

For elevated releases, unstable conditions can result in very high concentrations of poorly diluted emissions close to the stack. This is called looping (Figure 5-11 (c)) and occurs mostly during daytime hours. Neutral conditions disperse the plume fairly equally in both the vertical and horizontal planes and the plume shape is referred to as coning (Figure 5-11 (b)). Stable conditions prevent the plume from mixing vertically, although it can still spread horizontally and is called fanning (Figure 5-11 (a)) (Tiwary & Colls, 2010).




Figure 5-11: Diurnal atmospheric stability (extracted from CALMET at the Secunda Club monitoring point)

5.1.5.4 Air Quality Monitoring data

Time series of the measured ambient air quality data is provided in Appendix G. A summary of ambient data measured at Bosjesspruit, Secunda Club and Langverwacht for the period 2010 – 2012 is provided in Table 5-7, Table 5-8 and Table 5-9 respectively.

Table 5-6: Summary of the ambient measurements at Bosjesspruit for the period 2010-2012 (units: µg/m³)

| Period | Hourly | | | | Annual Average | No of recorded hourly exceedances |
|-----------------------|--------|-----------------------------|-----------------------------|-----------------------------|----------------|-----------------------------------|
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| H₂S | | | | | | |
| 2010 | 696.72 | 61.04 | 3.86 | 0.03 | 3.17 | |
| 2011 | 329.42 | 88.88 | 16.42 | 3.47 | 7.64 | |
| 2012 | 290.24 | 104.79 | 11.74 | 1.30 | 6.83 | |
| <i>Period Average</i> | 438.79 | 84.90 | 10.67 | 1.60 | 5.88 | |
| NH₃ | | | | | | |
| 2010 | 274.32 | 37.90 | 8.12 | 1.24 | 3.61 | |
| 2011 | 155.97 | 24.39 | 3.36 | 0.11 | 1.58 | |
| 2012 | 320.66 | 105.25 | 16.68 | 1.35 | 7.69 | |
| <i>Period Average</i> | 250.32 | 55.85 | 9.39 | 0.90 | 4.29 | |
| NO₂ | | | | | | |
| 2010 | 374.90 | 123.58 | 44.36 | 12.89 | 20.25 | 20.00 |
| 2011 | 362.20 | 139.18 | 29.28 | 1.11 | 11.16 | 18.00 |
| 2012 | 234.70 | 83.63 | 34.65 | 9.72 | 14.94 | 1.00 |
| <i>Period Average</i> | 323.93 | 115.46 | 36.10 | 7.91 | 15.45 | 13.00 |
| SO₂ | | | | | | |
| 2010 | 494.15 | 175.51 | 57.92 | 8.29 | 21.80 | 5.00 |
| 2011 | 483.46 | 215.26 | 69.47 | 6.87 | 24.51 | 8.00 |
| 2012 | 576.51 | 221.95 | 64.22 | 9.18 | 24.66 | 12.00 |
| <i>Period Average</i> | 518.04 | 204.24 | 63.87 | 8.11 | 23.66 | 8.33 |

Table 5-7: Summary of the ambient measurements at Secunda Club for the period 2010-2012 (units: µg/m³)

| Period | Hourly | | | | Annual Average | No of recorded hourly exceedances |
|-----------------------|--------|-----------------------------|-----------------------------|-----------------------------|----------------|-----------------------------------|
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| H₂S | | | | | | |
| 2010 | 570.31 | 33.66 | 9.33 | 1.84 | 4.06 | |
| 2011 | 160.59 | 51.16 | 9.85 | 3.11 | 5.37 | |
| 2012 | 228.05 | 40.27 | 11.12 | 2.74 | 5.31 | |
| <i>Period Average</i> | 319.65 | 41.70 | 10.10 | 2.56 | 4.91 | |
| NH₃ | | | | | | |
| 2010 | 342.55 | 55.82 | 9.72 | 1.64 | 4.75 | |
| 2011 | 343.88 | 75.81 | 15.84 | 1.62 | 5.91 | |
| 2012 | 196.76 | 18.25 | 1.83 | - | 1.01 | |
| <i>Period Average</i> | 294.40 | 49.96 | 9.13 | 1.09 | 3.89 | |

| Period | Hourly | | | | Annual Average | No of recorded hourly exceedances |
|------------------------|----------------|-----------------------------|-----------------------------|-----------------------------|----------------|-----------------------------------|
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| O₃ | | | | | | |
| 2010 | 234.97 | 127.93 | 88.80 | 49.19 | 52.97 | |
| 2011 | 299.61 | 142.18 | 91.75 | 43.39 | 48.99 | |
| 2012 | 317.76 | 142.01 | 101.84 | 57.53 | 60.76 | |
| <i>Period Average</i> | 284.11 | 137.37 | 94.13 | 50.04 | 54.24 | |
| NO₂ | | | | | | |
| 2010 | 450.30 | 94.08 | 44.65 | 12.93 | 19.28 | 10.00 |
| 2011 | 450.30 | 100.22 | 45.16 | 13.11 | 19.64 | 15.00 |
| 2012 | 192.80 | 78.40 | 40.38 | 13.93 | 18.49 | - |
| <i>Period Average</i> | 364.47 | 90.90 | 43.39 | 13.32 | 19.14 | 8.33 |
| SO₂ | | | | | | |
| 2010 | 433.00 | 172.79 | 46.57 | 7.51 | 18.84 | 4.00 |
| 2011 | 459.60 | 172.52 | 42.84 | 4.15 | 16.16 | 6.00 |
| 2012 | 583.50 | 174.63 | 47.04 | 8.66 | 20.07 | 6.00 |
| <i>Period Average</i> | 492.03 | 173.31 | 45.49 | 6.77 | 18.36 | 5.33 |
| Period | Daily | | | | Annual Average | No of recorded daily exceedances |
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| PM₁₀ | | | | | | |
| 2010 | 127.79 | 74.53 | 54.76 | 26.39 | 30.15 | 3.00 |
| 2011 | 97.91 | 87.91 | 57.74 | 19.48 | 23.97 | 9.00 |
| 2012 | 86.65 | 73.17 | 57.13 | 27.99 | 30.43 | 3.00 |
| <i>Period Average</i> | 104.12 | 78.54 | 56.55 | 24.62 | 28.18 | 5.00 |
| Period | Annual Average | | | | | |
| Benzene | | | | | | |
| 2010 | 0.42 | | | | | |
| 2011 | 1.21 | | | | | |
| 2012 | 0.87 | | | | | |
| <i>Period Average</i> | 0.83 | | | | | |

Table 5-8: Summary of the ambient measurements at Langverwacht for the period 2010-2012 (units: µg/m³)

| Period | Hourly | | | | Annual Average | No of recorded hourly exceedances |
|------------------------|--------|-----------------------------|-----------------------------|-----------------------------|--------------------|-----------------------------------|
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| H₂S | | | | | | |
| 2010 | 696.72 | 70.01 | 21.57 | 5.19 | 9.55 | |
| 2011 | 229.44 | 75.03 | 21.80 | 1.56 | 7.74 | |
| 2012 | 475.37 | 68.96 | 25.13 | 3.22 | 9.52 | |
| <i>Period Average</i> | 467.18 | 71.33 | 22.83 | 3.32 | 8.94 | |
| NH₃ | | | | | | |
| 2010 | 347.44 | 178.37 | 55.18 | 6.96 | 20.07 | |
| 2011 | 347.44 | 269.04 | 92.07 | 16.82 | 35.05 | |
| 2012 | 332.62 | 108.17 | 41.65 | 1.41 | 13.71 | |
| <i>Period Average</i> | 342.50 | 185.19 | 62.97 | 8.40 | 22.95 | |
| O₃ | | | | | | |
| 2010 | 873.09 | 176.17 | 108.97 | 47.47 | 54.77 | |
| 2011 | 452.35 | 125.69 | 89.19 | 44.85 | 49.60 | |
| 2012 | 752.95 | 134.34 | 99.07 | 53.12 | 56.64 | |
| <i>Period Average</i> | 692.80 | 145.40 | 99.08 | 48.48 | 53.67 | |
| NO₂ | | | | | | |
| 2010 | 135.90 | 74.82 | 39.89 | 14.39 | 18.74 | - |
| 2011 | 135.90 | 83.56 | 47.96 | 15.84 | 21.22 | 1.00 |
| 2012 | 181.50 | 72.14 | 40.37 | 13.49 | 17.98 | - |
| <i>Period Average</i> | 151.10 | 76.84 | 42.74 | 14.57 | 19.32 | 0.33 |
| SO₂ | | | | | | |
| 2010 | 461.80 | 152.45 | 40.79 | 7.73 | 17.06 | 7.00 |
| 2011 | 449.82 | 165.48 | 43.93 | 6.07 | 14.86 | 11.00 |
| 2012 | 525.81 | 176.59 | 48.39 | 7.48 | 17.54 | 7.00 |
| <i>Period Average</i> | 479.14 | 164.84 | 44.37 | 7.09 | 16.49 | 12.00 |
| Period | Daily | | | | Annual Average Max | No of recorded daily exceedances |
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| PM₁₀ | | | | | | |
| 2010 | 192.51 | 121.41 | 85.33 | 36.59 | 44.52 | 50.00 |
| 2011 | 157.94 | 157.40 | 82.88 | 28.03 | 36.96 | 32.00 |
| 2012 | 115.23 | 109.97 | 76.94 | 37.07 | 40.36 | 33.00 |
| <i>Period Average</i> | 155.22 | 129.60 | 81.72 | 33.89 | 40.61 | 38.33 |

| Period | Hourly | | | | Annual Average | No of recorded hourly exceedances |
|-----------------------|--------|-----------------------------|-----------------------------|-----------------------------|----------------|-----------------------------------|
| | Max | 99 th Percentile | 90 th Percentile | 50 th Percentile | | |
| Benzene | | | | | | |
| 2010 | | | | | 1.62 | |
| 2011 | | | | | 1.06 | |
| 2012 | | | | | 1.68 | |
| <i>Period Average</i> | | | | | 1.46 | |

The following graphs summarise the observed concentrations of SO₂, NO₂ and PM₁₀ at Bosjesspruit, Secunda Club and Langverwacht monitoring stations for the years 2010, 2011 and 2012. The NAAQS have been included in the graphs for:

- SO₂ hourly (permitted 88 hourly exceedances of 350 µg/m³) and daily average (permitted 4 daily exceedances of 125 µg/m³)
- NO₂ hourly average (permitted 88 hourly exceedances of 200 µg/m³); and,
- PM₁₀ daily average (permitted 4 daily exceedances of 75 µg/m³; 2015 standards).

The hourly 99th percentiles for SO₂ were below the limit value of 350 µg/m³ at all three stations for all three years (Figure 5-12, Figure 5-14, and Figure 5-16). The daily 99th percentiles for SO₂ were below the limit value (125 µg/m³) at all the stations: Bosjesspruit (Figure 5-13), Secunda Club (Figure 5-15) and Langverwacht (Figure 5-17).




Figure 5-12: Observed hourly average SO₂ concentrations at Bosjesspruit




Figure 5-13: Observed daily average SO₂ concentrations at Bosjesspruit




Figure 5-14: Observed hourly average SO₂ concentrations at Secunda Club




Figure 5-15: Observed daily average SO₂ concentrations at Secunda Club




Figure 5-16: Observed hourly average SO₂ concentrations at Langverwacht




Figure 5-17: Observed daily average SO₂ concentrations at Langverwacht

The hourly 99th percentiles for NO₂ were below the limit value (200 µg/m³) at all three stations and for all three years (Figure 5-18, Figure 5-19, and Figure 5-20).




Figure 5-18: Observed hourly average NO₂ concentrations at Bosjesspruit




Figure 5-19: Observed hourly average NO₂ concentrations at Secunda Club




Figure 5-20: Observed hourly average NO₂ concentrations at Langverwacht

The daily 99th percentiles for PM₁₀ exceeded the limit value (75 µg/m³; 2015 standard) at both Secunda Club (Figure 5-21) and Langverwacht stations (Figure 5-22) for all three years. While the SO₂ and NO₂ annual averages were below the NAAQS, the PM₁₀ annual averages exceeded the 2015 limit value of 40 µg/m³ for all three years at Langverwacht and were close to the limit value at Secunda Club.




Figure 5-21: Observed daily average PM₁₀ concentrations at Secunda Club




Figure 5-22: Observed daily average PM₁₀ concentrations at Langverwacht

Time series plots (mean with 95% confidence interval) of ambient SO₂, NO₂, H₂S, PM₁₀, and benzene concentrations measured at Bosjesspruit (Figure 5-23 and Figure 5-24), Secunda Club (Figure 5-25 to Figure 5-28), and Langverwacht (Figure 5-29 to Figure 5-32) show the variation of these pollutants over daily, weekly and annual cycles.

The daily SO₂ show a typically industrial signature with increased SO₂ concentrations as just before midday due to the break-up of an elevated inversion layer, in addition to the development of daytime convective conditions causing the plume to be brought down to ground level relatively close to the point of release from tall stacks. Increased NO₂ concentrations during peak traffic times (07:00 to 08:00 and 16:00 to 18:00) illustrate the contribution of vehicle emissions to the ambient NO₂ concentrations. The winter (June, July and August) elevation of SO₂ and NO₂ shows the contribution of residential fuel burning to the ambient SO₂ and NO₂ concentrations.

Monthly variation of PM₁₀ shows a typical Highveld signature of elevated concentrations during winter months due to the greater contribution from domestic fuel burning, dust from uncovered soil and the lack of the settling influence of rainfall (Figure 5-27 and Figure 5-31).

Large temporal and spatial variation is evident in H₂S with different time-period patterns evident at each of the monitoring stations. Benzene shows a strong daily periodicity with elevated concentrations at 06:00 and 18:00. Benzene concentrations at both monitoring stations were elevated during winter months.




Figure 5-23: Time series plot of observed SO₂ and NO₂ concentrations at Bosjesspruit (shaded area indicates 95th percentile confidence interval)




Figure 5-24: Time series plot of normalised observed H₂S concentrations at Bosjesspruit (shaded area indicates 95th percentile confidence interval)




Figure 5-25: Time series plot of normalised observed SO₂ and NO₂ concentrations at Secunda Club (shaded area indicates 95th percentile confidence interval)




Figure 5-26: Time series plot of normalised observed H₂S concentrations at Secunda Club (shaded area indicates 95th percentile confidence interval)




Figure 5-27: Time series plot of normalised observed PM₁₀ concentrations at Secunda Club (shaded area indicates 95th percentile confidence interval)




Figure 5-28: Time series plot of normalised observed benzene concentrations at Secunda Club (shaded area indicates 95th percentile confidence interval)




Figure 5-29: Time series plot of normalised observed SO₂ and NO₂ concentrations at Langverwacht (shaded area indicates 95th percentile confidence interval)




Figure 5-30: Time series plot of normalised observed H₂S concentrations at Langverwacht (shaded area indicates 95th percentile confidence interval)




Figure 5-31: Time series plot of normalised observed PM₁₀ concentrations at Langverwacht (shaded area indicates 95th percentile confidence interval)




Figure 5-32: Time series plot of normalised observed benzene concentrations at Langverwacht (shaded area indicates 95th percentile confidence interval)

5.1.6 Model Performance

5.1.6.1 Understanding of Observed Concentrations

An analysis of the observed NO₂, SO₂, PM₁₀ and H₂S concentrations at Bosjesspruit, Secunda Club and Langverwacht monitoring stations was completed, in which the concentration values have been categorised into wind speed and direction bins for different concentrations. This information is most easily visualised as polar plots, where the centre of the polar plot refers to the location of the monitoring station, as shown for NO₂ observations in Figure 5-33 (Bosjesspruit), Figure 5-36 (Secunda Club) and Figure 5-41 (Langverwacht). The corresponding SO₂ analyses are summarised in Figure 5-34 (Bosjesspruit), Figure 5-37 (Secunda Club) and Figure 5-42 (Langverwacht) with PM₁₀ provided in Figure 5-38 (Secunda Club) and Figure 5-43 (Langverwacht) and H₂S provided in Figure 5-35 (Bosjesspruit), Figure 5-39 (Secunda Club) and Figure 5-44 (Langverwacht).

These polar plots (Carslaw and Ropkins, 2012; Carslaw, 2013) provide an indication of the directional contribution as well as the dependence of concentrations on wind speed. Whereas the directional display is fairly obvious, i.e. when higher concentrations are shown to occur in a certain sector, e.g. north-westerly for SO₂ at Bosjesspruit (Figure 5-34), it is understood that most of the high concentrations occur when winds blow from that sector. The presence of a high concentration pattern which is more symmetrical around the centre of the plot, it is an indication that the contributions are near-equally distributed, and occur under calm-wind conditions, as is displayed for NO₂ in Figure 5-41.

Furthermore, since the observed concentrations have also been categorised according to wind speed categories, it provides an indication of the plume height. As explained in Section 5.1.4.1 (plume buoyancy), stronger winds reduce the amount of plume rise, and may effectively increase ground level concentrations. However, since an increased wind speed also enhances plume dispersion, a concentration maximum would be reached for a wind speed where the plume rise and dilution effects cancel each other. These conditions would be different for day- and night-time atmospheric stabilities. It is expected that high ground level concentrations from elevated stacks would be more prevalent during stronger wind speeds during stable conditions than daytime, convective conditions, when the plume buoyancy is often not as effective in lifting the plume centreline. Low-level emissions behave differently, and higher concentrations would normally be observed during weak-wind conditions.

The NO₂ concentrations observed at Bosjesspruit (Figure 5-33) indicate that most of the high concentrations occur with north-westerly winds of between 5 m/s and 10 m/s. Slightly lower air concentration contributions were from the north to north-north-easterly direction with winds of about 10 m/s. Concentrations of less than 35 µg/m³ were observed with winds from the south-east. The north-westerly sector is clearly associated with the Sasol Secunda operations. Whilst the northerly sector may also include Sasol, it is also believed that other sources may contribute to these observations, including vehicular exhaust emissions, which can potentially be significant NO₂ emitters. The south-easterly observations are most likely due to emitters of NO₂ other than Sasol.

The SO₂ concentrations observed at Bosjesspruit (Figure 5-34) indicate that most of the high concentrations occur with north-westerly winds of between 5 m/s and 10 m/s and north/north-northeasterly winds of above 10 m/s. High concentrations were also measured with south-easterly winds above 10 m/s. As with NO₂, the contribution from the north-westerly sector, is most likely associated with the Sasol Secunda operations, whereas the other two directions are most likely due to other emitters of SO₂.

The H₂S concentrations observed at Bosjesspruit (Figure 5-35) indicate that most of the high concentrations occur with north-westerly winds of between 5 m/s and 10 m/s. Higher concentrations were also measured with south-easterly winds above 10 m/s. The concentrations from the north-westerly sector are most likely associated with the Sasol Secunda operations, whereas the concentrations from the south eastern sector are most likely due to other emitters of H₂S.

The NO₂ concentrations observed at Secunda Club (Figure 5-36) indicate that most of the high concentrations occur with south-westerly winds of less than 6 m/s. These are most likely due to emissions at the Sasol operations. Lower air concentration observation from the north, may be due to vehicular exhaust emissions and more remote sources of NO₂. Concentrations of less than 25 µg/m³ were also observed with winds from the south-east.

The SO₂ concentrations observed at Secunda Club (Figure 5-37) show three distinct wind directions, namely from the south-west (majority of high concentrations), the north (Secunda town and other more remote emitters) and south-east (remote emitters).

The PM₁₀ concentrations observed at Secunda Club (Figure 5-38) are mainly from the western sector where industrial, mining and vehicle activity sources are most likely to contribute to the concentrations. Lower particulate concentrations are associated with winds from the eastern sector.

The H₂S concentrations observed at Secunda Club (Figure 5-39) show highest concentrations associated with winds of ~10m/s. These are most likely due to emissions from Sasol operations.

The highest observed benzene concentrations at the Secunda Club (Figure 5-40) are associated with winds of 10 m/s or greater, from the south-west of the monitoring station, mostly likely due to emissions from Sasol operations.

The NO₂ concentrations observed at Langverwacht (Figure 5-41) observed high concentrations, during calm-wind conditions (most-likely localised emitters), with winds from a northerly and east-south-easterly directions. Two different sources are identified with northerly winds, one peak at about 4 m/s and the other at about 12 m/s. The east-south-easterly emitters are most likely due to Sasol operations, whereas the northerly observations are due to more remote sources of NO₂.

Mean SO₂ concentrations (about 100 µg/m³) were observed with winds from the north-north-east and east-south-east at Langverwacht (Figure 5-42). The east-south-easterly sector is most likely associated with the Sasol Secunda operations. Whilst the northerly sector may also include Sasol, it is also believed that other sources are likely to contribute to these observations.

The highest mean PM₁₀ concentrations at Langverwacht were observed with winds from the west-south-west at wind speeds of less than 2 m/s (Figure 5-43). The contributing sources of particulate matter would include vehicle entrainment, domestic fuel burning, industrial and mining activity.

The highest mean H₂S concentrations were observed with winds from the east-south-east, which is most likely associated with the Sasol Secunda operations (Figure 5-44).

The highest observed benzene concentrations at Langverwacht (Figure 5-45) are associated with winds of 10 m/s or greater, from the east of the monitoring station, mostly likely due to emissions from Sasol operations.




Figure 5-33: Polar plot of hourly median NO₂ concentration observations at Bosjesspruit for 2010 to 2012




Figure 5-34: Polar plot of hourly median SO₂ concentration observations at Bosjesspruit for 2010 to 2012




Figure 5-35: Polar plot of hourly median H₂S concentration observations at Bosjesspruit for 2010 to 2012




Figure 5-36: Polar plot of hourly median NO₂ concentration observations at Secunda Club for 2010 to 2012




Figure 5-37: Polar plot of hourly median SO₂ concentration observations at Secunda Club for 2010 to 2012




Figure 5-38: Polar plot of hourly median PM₁₀ concentration observations at Secunda Club for 2010 to 2012




Figure 5-39: Polar plot of hourly median H₂S concentration observations at Secunda Club for 2010 to 2012




Figure 5-40: Polar plot of hourly median benzene concentration observations at Secunda Club for 2010 to 2012




Figure 5-41: Polar plot of hourly median NO₂ concentration observations at Langverwacht for 2010 to 2012




Figure 5-42: Polar plot of hourly median SO₂ concentration observations at Langverwacht for 2010 to 2012




Figure 5-43: Polar plot of hourly median PM₁₀ concentration observations at Langverwacht for 2010 to 2012




Figure 5-44: Polar plot of hourly median H_2S concentration observations at Langverwacht for 2010 to 2012




Figure 5-45: Polar plot of hourly median benzene concentration observations at Langverwacht for 2010 to 2012

5.1.6.2 Model validation

Ambient concentrations of NO₂, SO₂, H₂S and PM₁₀ measured by Sasol in Secunda help provide an understanding of existing ambient air concentrations as well as providing a means of verifying the dispersion modelling. Since the aim of the investigation is to illustrate the change in ground level concentrations from the current levels (i.e. baseline emission scenario) to those levels theoretically resulting from implementation of technical solutions to lower emissions to the promulgated emission limits (i.e. existing and new plant standards), the intension was not to comprehensively include all air emissions from the Sasol Secunda operation or those associated with activities other than Sasol. Unaccounted emissions include those from unintended leaks within the plant (fugitive emissions) and vents, as well as air emissions from other industries, emissions from activities occurring within the communities, and biomass burning (especially during winter season), as well as long-range transport into the modelling domain. However, information about community activities, such as the amount of traffic within the community and the amount of fuel used for heating is often difficult to estimate.

These emissions, when combined, may potentially add up to be a significant portion of the observed concentrations the modelling domain. In terms of the current investigation, the portion of air quality due to air emission sources that is not included in the model emissions inventory constitutes the background concentration.

Discrepancies between predicted and observed concentrations may also be as a result of process emission variations, and may include upset emissions and shutdown emissions. These conditions could result in significant under-estimating or over-estimating the ambient concentrations.

A summary of the predicted concentrations and their comparison with observations are given in Appendix H. In order to establish model performance under average emission conditions, it is not uncommon to use a certain percentile of predicted and observed concentrations for comparison. Although these may range from a 90th to 99.9th percentile, it was decided to use the DEA NAAQS for guidance. For criteria pollutants SO₂, NO₂ and PM₁₀, the NAAQS requires compliance with the 99th percentile. As hourly averages, this allows exceedances of the limit value of 88 hours (i.e. 1%) (SO₂ and NO₂) per year, and, for daily averages, 4 days (i.e. 1%) (PM₁₀) per year. To estimate the background concentrations not associated with the emission included in the simulations, the methodology described below was therefore adopted.

- For short-term (1-hour and 24-hour) predicted averaging periods, the 99th percentile value from the cumulative frequency distribution of the monitoring data (per year) were used.
- For the annual predicted averaging period (long-term), the observed concentration is used at the percentile where the modelled concentration becomes zero, but not less than the 50th percentile of the cumulative frequency distribution of the monitoring data (per year) were used.

The monitoring station at Secunda Club and Langverwacht are closer to the Sasol operations than the Bosjesspruit monitoring station. However, all three monitoring stations recorded fairly similar short-term SO₂ concentration values; viz. peaks of 479 µg/m³ (Langverwacht), 492 µg/m³ (Secunda Club), and 518 µg/m³ (Bosjesspruit), and 99th percentiles of 165 µg/m³ (Langverwacht), 174 µg/m³ (Secunda Club) and 204 µg/m³ (Bosjesspruit), respectively.

Table 5-9 is a summary of comparisons between predicted and observed SO₂ concentrations at Bosjesspruit. As shown in the table of the observed peak concentration, the predicted peak accounted for the observed peak. However, the difference between prediction and observation increases significantly when considering long-term comparisons (i.e. 50th percentile and annual average), clearly illustrating the contribution of emission sources not included in the dispersion model's emissions

inventory. Not shown in the table is the observed concentration at the percentile where the prediction was zero – considered to be the background or non-inventory ambient concentration - namely, 17.7 µg/m³ (average of 2010, 2011 and 2012).

Table 5-9: Comparison of predicted and observed SO₂ concentrations at Bosjesspruit monitoring station in Secunda

| | Bosjesspruit | | | |
|-----------------|--|----------|-------------|-----------------------|
| | SO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction* |
| | Predicted | Observed | Unaccounted | |
| Peak | 519.7 | 547.1 | 27.4 | 5% |
| 99th Percentile | 124.7 | 204.1 | 79.4 | 39% |
| 90th Percentile | 2.8 | 58.8 | 56.0 | 96% |
| 50th Percentile | 0.0 | 7.9 | 7.9 | 100% |
| Annual Average | 5.1 | 22.6 | 17.5 | 78% |

* unaccounted fraction as a percentage of observed concentration

Table 5-10 is a summary of comparisons between predicted and observed SO₂ concentrations at Secunda Club. In contrast to Bosjesspruit, where the peak concentration was shown to be from Sasol operations, approximately 22% of the observed peak concentration was unaccounted for. Although this may still have resulted from the Sasol operations, it is also a possibility that another, even more localised source may have added to the observed peak.. A slightly lower concentration was predicted for the 99th percentile, which may be due to other sources in the Sasol complex or more remotely. The observed concentration at the zero prediction percentiles was determined to be 18.4 µg/m³ (average of 2010, 2011 and 2012).

Table 5-10: Comparison of predicted and observed SO₂ concentrations at Secunda Club monitoring station in Secunda

| | Secunda Club | | | |
|-----------------|--|----------|-------------|----------------------|
| | SO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 452.8 | 511.7 | 58.9 | 22% |
| 99th Percentile | 75.7 | 173.6 | 97.9 | 56% |
| 90th Percentile | 0.6 | 45.5 | 44.9 | 99% |
| 50th Percentile | 0.0 | 6.8 | 6.8 | 100% |
| Annual Average | 2.7 | 18.4 | 15.7 | 85% |

* unaccounted fraction as a percentage of observed concentration

Table 5-11 is a summary of comparisons between predicted and observed SO₂ concentrations at Langverwacht. Although not an exact match, the observed peak concentration was predicted to be from Sasol. In contrast to Secunda Club, the prediction was slightly higher than the observed peak concentration. As with the other two monitoring stations, the difference between prediction and observation increases significantly when considering long-term comparisons (i.e. 50th percentile and annual average). The observed concentration at the zero prediction percentiles was determined to be 16.5 µg/m³ (average of 2010, 2011 and 2012).

Table 5-11: Comparison of predicted and observed SO₂ concentrations at Langverwacht monitoring station in Secunda

| | Langverwacht | | | |
|-----------------|--|----------|-------------|----------------------|
| | SO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 576.6 | 493.3 | 0.0 | 0% |
| 99th Percentile | 79.8 | 164.8 | 85.1 | 52% |
| 90th Percentile | 0.4 | 44.4 | 44.0 | 99% |
| 50th Percentile | 0.0 | 7.1 | 7.1 | 100% |
| Annual Average | 2.8 | 18.1 | 15.2 | 84% |

* unaccounted fraction as a percentage of observed concentration

The performance evaluation was completed using the fractional bias method. Fractional bias is one of the evaluation methods recommended by the U.S. EPA for determining dispersion model performance (U.S. EPA 1992). Fractional bias provides a comparison of the means and standard deviation of both modelled and monitored concentrations for any given number of locations.

In this assessment, both short- and long-term fractional biases were computed. In this regards, the short- and long-term background concentrations were added to the predicted hourly and annual average concentrations prior to the calculation of the fractional bias. With the short-term fractional bias the 99th percentile (with background concentration for each year, as shown in Table 5-12) was compared to the same ranked monitored concentrations. The long-term fractional bias was based on the annual predicted mean and standard deviations (with estimated background concentration for each year) and observed concentrations.

Table 5-12: Estimated SO₂ background concentrations for Bosjesspruit, Secunda Club and Langverwacht

| Year | SO ₂ Concentration (µg/m ³) | | | | | |
|------|--|-----------|--------------|-----------|--------------|-----------|
| | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | Short-term | Long-Term | Short-term | Long-Term | Short-term | Long-Term |
| 2010 | 35.8 | 16.3 | 110.6 | 22.4 | 81.1 | 17.1 |
| 2011 | 96.01 | 18.2 | 95.9 | 15.10 | 81.3 | 14.9 |
| 2012 | 106.3 | 18.7 | 97.9 | 17.35 | 92.9 | 17.54 |

In Figure 5-46, the fractional bias is plotted with the means on the X-axis and the standard deviations on the Y-axis. The box on the plot encloses the area of the graph where the model predictions are within a factor of two (corresponding to a fractional bias of between -0.67 and +0.67). The U.S. EPA states that predictions within a factor of two are a reasonable performance target for a model before it is used for refined regulatory analysis (U.S. EPA 1992). Data points appearing on the left half of the plot indicate an over-prediction and those on the right half of the plot represent under-predictions.

The fractional bias of the means for both short- and long-term predictions were less than 0.67, clearly showing good model performance (i.e. within a factor of two). Using the individual fractional biases, the model's prediction is shown to be well within a factor of two, with fractional biases of the mean ranging from 0.01 (Bosjesspruit, long-term) to 0.05 (Bosjesspruit, short-term), -0.04 (Secunda Club, short-term) to 0.13 (Secunda Club, long-term) and 0.15(Langverwacht, short-term) to -0.07 (Langverwacht, long-term).

The same calculations and comparisons were repeated for NO₂ predictions and observations. The CALPUFF predictions were specifically for NO_x and the formation on HNO₃ and other nitrates using the MESOPUFF II chemical transformation mechanism, as discussed in Section 5.1.4.3.




Figure 5-46: Fractional bias of means and standard deviation for SO₂

Table 5-12 is a summary of comparisons between predicted and observed NO₂ concentrations at Bosjesspruit. As shown in the table, significantly lower concentrations were predicted than the observed peak concentrations. This may be due to unaccounted NO₂ emitters as well as the rather simplistic methodology of applying a constant conversion rate from NO_x to NO₂ (Section 5.1.3.3). The 99th percentile compared better with only 19% unaccounted for in the observed concentrations. As for SO₂, the difference between prediction and observation increases significantly when considering long-term comparisons (i.e. 50th percentile and annual average), clearly illustrating the contribution of emission sources not included in the dispersion model's emissions inventory. Not shown in the table is the observed concentration at the percentile where the prediction was zero, namely 11.4 µg/m³ (average of 2010, 2011 and 2012).

Table 5-13: Comparison of predicted and observed NO₂ concentrations at Bosjesspruit monitoring station in Secunda

| | Bosjesspruit | | | |
|-----------------|--|----------|-------------|----------------------|
| | NO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 133.1 | 399.4 | 266.3 | 67% |
| 99th Percentile | 73.9 | 115.9 | 42.0 | 36% |
| 90th Percentile | 3.4 | 36.2 | 32.8 | 91% |
| 50th Percentile | 0.0 | 7.9 | 7.9 | 100% |
| Annual Average | 3.0 | 15.5 | 12.5 | 81% |

* unaccounted fraction as a percentage of observed concentration

Table 5-14 is a summary of comparisons between predicted and observed NO₂ concentrations at Secunda Club. Similar to Bosjesspruit, the peak concentration observed was not predicted; however, the 99th percentile was relatively close to the observed value. Approximately 26% of the predicted concentration was unaccounted for in the observed concentrations. The observed concentration at the zero prediction percentiles was determined to be 14.4 µg/m³ (average of 2010, 2011 and 2012).

The predicted peak and 99th percentile NO₂ concentrations at Langverwacht (Table 5-17), compares more favourably than at Bosjesspruit and Secunda Club. The observed 99th percentile concentration was also very similar to the predicted concentration with only a 15% difference. The observed concentration at the zero prediction percentiles was determined to be 22.6 µg/m³ (average of 2010, 2011 and 2012).

Table 5-14: Comparison of predicted and observed NO₂ concentrations at Secunda Club monitoring station in Secunda

| | Secunda Club | | | |
|-----------------|--|----------|-------------|----------------------|
| | NO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 117.5 | 351.4 | 233.9 | 67% |
| 99th Percentile | 44.8 | 91.2 | 46.4 | 51% |
| 90th Percentile | 0.9 | 43.5 | 42.6 | 98% |
| 50th Percentile | 0.0 | 13.4 | 13.4 | 100% |
| Annual Average | 1.5 | 19.2 | 17.7 | 92% |

* unaccounted fraction as a percentage of observed concentration

Table 5-15: Comparison of predicted and observed NO₂ concentrations at Langverwacht monitoring station in Secunda

| | Langverwacht | | | |
|-----------------|--|----------|-------------|----------------------|
| | NO ₂ Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 149.4 | 178.5 | 29.1 | 16% |
| 99th Percentile | 44.4 | 77.1 | 32.7 | 42% |
| 90th Percentile | 1.7 | 42.9 | 41.2 | 96% |
| 50th Percentile | 0.0 | 14.6 | 14.6 | 100% |
| Annual Average | 1.6 | 19.4 | 17.8 | 92% |

* unaccounted fraction as a percentage of observed concentration

Background concentrations were estimated for short- and long-term concentrations for each of the three years of simulations, as summarised in Table 5-16.

Table 5-16: Estimated NO₂ background concentrations for Bosjesspruit, Secunda Club and Langverwacht

| Year | NO ₂ Concentration (µg/m ³) | | | | | |
|------|--|-----------|--------------|-----------|--------------|-----------|
| | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | Short-term | Long-Term | Short-term | Long-Term | Short-term | Long-Term |
| 2010 | 39.6 | 16.7 | 44.3 | 18.1 | 38.4 | 17.3 |
| 2011 | 26.5 | 8.5 | 44.6 | 18.3 | 46.5 | 19.6 |
| 2012 | 32.2 | 12.3 | 38.9 | 16.7 | 38.9 | 16.4 |

Subsequently, short-term fractional biases (i.e. using the 99th percentile with background concentration for each year) as well as long-term fractional biases (i.e. annual concentrations with estimated background concentration for each year) were calculated for the three monitoring stations. The results are summarised in Figure 5-47.

Using the individual fractional biases of the means, the model's prediction is shown to be well within a factor of two, clearly showing good model performance, with fractional biases of the mean ranging from 0.04 (Bosjesspruit, long-term) to 0.10 (Bosjesspruit, short-term), 0.13 (Secunda Club, short-term) to 0.39 (Secunda Club, long-term) and 0.12 (Langverwacht, short-term) to 0.24 (Langverwacht, long-term).




Figure 5-47: Fractional bias of means and standard deviation for NO₂

Table 5-17 is a summary of comparisons between predicted and observed H₂S concentrations at Bosjesspruit. Although the observed peak concentration was not predicted, the predicted 99th percentile was very close to the observed value. Based

on the 99th percentile, approximately 12% was unaccounted for in the observed concentrations. The observed concentration at the zero prediction percentiles was determined to be 4.2 µg/m³ (average of 2010, 2011 and 2012).

The predicted peak and 99th percentile H₂S concentrations at Secunda Club (Table 5-18), compares more favourably with observed concentrations. The observed 99th percentile concentration was slightly over predicted by the model and the peak observed concentration, under predicted by the model. The observed concentration at the zero prediction percentiles was determined to be 7.0 µg/m³ (average of 2010, 2011 and 2012).

Table 5-17: Comparison of predicted and observed H₂S concentrations at Bosjesspruit monitoring station in Secunda

| | Bosjesspruit | | | |
|-----------------|---|----------|-------------|----------------------|
| | H ₂ S Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 255.3 | 409.7 | 154.4 | 38% |
| 99th Percentile | 61.2 | 84.3 | 10.3 | 27% |
| 90th Percentile | 0.0 | 0.9 | 0.9 | 100% |
| 50th Percentile | 0.0 | 0.9 | 0.9 | 100% |
| Annual Average | 2.5 | 5.8 | 2.6 | 56% |

* unaccounted fraction as a percentage of observed concentration

Table 5-18: Comparison of predicted and observed H₂S concentrations at Secunda Club monitoring station in Secunda

| | Secunda Club | | | |
|-----------------|---|----------|-------------|----------------------|
| | H ₂ S Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 221.1 | 344.1 | 123.0 | 36 |
| 99th Percentile | 38.0 | 43.8 | 5.8 | 13% |
| 90th Percentile | 0.0 | 2.6 | 2.6 | 100% |
| 50th Percentile | 0.0 | 2.6 | 2.6 | 100% |
| Annual Average | 1.4 | 5.1 | 3.8 | 73% |

* unaccounted fraction as a percentage of observed concentration

Table 5-19 is a summary of predicted H₂S concentrations compared with the observed concentrations at Langverwacht. Different from the other two monitoring locations, the peak concentration was significantly under-predicted by the model, but the 99th percentile was relatively close to the observed value. Based on the 99th percentile, approximately 29% of the observed concentration was unaccounted for. The observed concentration at the zero prediction percentiles was determined to be 16.1 µg/m³ (average of 2010, 2011 and 2012).

Table 5-19: Comparison of predicted and observed H₂S concentrations at Langverwacht monitoring station in Secunda

| | Langverwacht | | | |
|-----------------|---|----------|-------------|----------------------|
| | H ₂ S Concentration (µg/m ³) | | | Unaccounted Fraction |
| | Predicted | Observed | Unaccounted | |
| Peak | 282.8 | 572.5 | 289.7 | 51% |
| 99th Percentile | 40.9 | 74.4 | 33.5 | 45% |
| 90th Percentile | 0.0 | 3.1 | 3.1 | 100% |
| 50th Percentile | 0.0 | 3.1 | 3.1 | 100% |
| Annual Average | 1.4 | 9.1 | 7.7 | 84% |

* unaccounted fraction as a percentage of observed concentration

Background concentrations were estimated for short- and long-term concentrations for each of the three years of simulations, as summarised in Table 5-20.

Table 5-20: Estimated H₂S background concentrations for Bosjesspruit, Secunda Club and Langverwacht

| Year | H ₂ S Concentration (µg/m ³) | | | | | |
|------|---|-----------|--------------|-----------|--------------|-----------|
| | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | Short-term | Long-Term | Short-term | Long-Term | Short-term | Long-Term |
| 2010 | 5.9 | 0.9 | 9.9 | 3.2 | 22.9 | 8.9 |
| 2011 | 15.0 | 65.4 | 10.6 | 4.6 | 24.6 | 7.1 |
| 2012 | 0.0 | 0.0 | 10.8 | 3.4 | 24.4 | 7.0 |

The short-term fractional biases (i.e. using the 99th percentile with background concentration for each year) as well as long-term fractional biases (i.e. annual concentrations with estimated background concentration for each year) were calculated for the three monitoring stations. The results are summarised in Figure 5-48.

Using the individual fractional biases of the means, the model's prediction is shown to be well within a factor of two, with fractional biases of the mean ranging from 0.28 (Bosjesspruit, long-term) to 0.37 (Bosjesspruit, short-term), 0.07 (Secunda Club, short-term) to 0.53 (Secunda Club, long-term) and 0.04 (Langverwacht, short-term) to 0.65 (Langverwacht, long-term).




Figure 5-48: Fractional bias of means and standard deviation for H₂S

5.1.7 Scenario Emission Inventory

The source parameters and emissions per scenario were provided by Sasol for the assessment and are given in Table 5-21 and Table 5-22 respectively. It is important to note that scenarios for compliance with existing and new plant standards were prepared for all point sources, whether or not Sasol deemed compliance to be feasible or not, and hence these construe theoretical abatement outcomes. The motivation reports for Sasol’s postponement applications outline reasons for which Sasol believes these theoretical point source reductions cannot be achieved.

Table 5-21: Source parameters per scenario provided for Sasol Secunda facility

| Source Group | Source name | Height of Release Above Ground (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m ³ /hr) | Actual Gas Exit Velocity (m/s) |
|--|-----------------|------------------------------------|---------------------------------------|----------------------------------|---|--------------------------------|
| Scenario 1 – Baseline emissions | | | | | | |
| Steam Stations | Main Stack East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Main Stack West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| Sulfur | Sulfur recovery | 301 | 14.4 | 185 | 11870000 | 20.2 |

| Source Group | Source name | Height of Release Above Ground (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) |
|---|----------------------|------------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|
| Recovery | East | | | | | |
| | Sulfur recovery West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| HOW Incinerators | HOW West | 15 | 1.9 | 354 | 211588.324 | 19.9 |
| | HOW East | 15 | 1.9 | 386 | 183686.66 | 18.0 |
| Biosludge Incinerators | Biosludge East | 30 | 1.4 | 66 | 91616.9532 | 15.7 |
| | | 30 | 1.4 | 65 | 87230.7939 | 15.8 |
| | Biosludge West | 30 | 1.4 | 68 | 74985.3274 | 13.5 |
| | | 30 | 1.4 | 61 | 81082.8619 | 14.7 |
| WSA | WSA | 75 | 2.75 | 41 | 206600 | 9.7 |
| Rectisol | Rectisol East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Rectisol West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| SCC | SCC | 90 | 3.6 | 190 | 314135 | 8.6 |
| Scenario 2a – Compliance with Existing Plant Standards | | | | | | |
| Steam Stations | Main Stack East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Main Stack West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| Sulfur Recovery | Sulfur recovery East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Sulfur recovery West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| HOW Incinerators | HOW West | 15 | 1.9 | 354 | 211588 | 19.9 |
| | HOW East | 15 | 1.9 | 386 | 183687 | 18.0 |
| Biosludge Incinerators | Biosludge East | 30 | 1.4 | 66 | 91617 | 15.7 |
| | | 30 | 1.4 | 65 | 87231 | 15.8 |
| | Biosludge West | 30 | 1.4 | 68 | 74985 | 13.5 |
| | | 30 | 1.4 | 61 | 81083 | 14.7 |
| WSA | WSA | 75 | 2.75 | 41 | 206600 | 9.7 |
| Rectisol | Rectisol East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Rectisol West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| SCC | SCC | 90 | 3.6 | 190 | 314135 | 8.6 |
| Scenario 2b – Compliance with New Plant Standards | | | | | | |
| Steam Stations | Main Stack East | 301 | 14.4 | 75 | 9019127 | 15.4 |
| | Main Stack West | 250 | 13.6 | 75 | 8022236 | 15.3 |
| Sulfur Recovery | Sulfur recovery East | 301 | 14.4 | 75 | 9019127 | 15.3 |

| Source Group | Source name | Height of Release Above Ground (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) |
|---|----------------------|------------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|
| | Sulfur recovery West | 250 | 13.6 | 75 | 8022236 | 15.3 |
| HOW Incinerators | HOW West | 15 | 1.9 | 354 | 211588 | 19.9 |
| | HOW East | 15 | 1.9 | 386 | 183687 | 18.0 |
| Biosludge Incinerators | Biosludge East | 30 | 1.4 | 66 | 91617 | 15.7 |
| | | 30 | 1.4 | 65 | 87231 | 15.8 |
| | Biosludge West | 30 | 1.4 | 68 | 74985 | 13.5 |
| | | 30 | 1.4 | 61 | 81083 | 14.7 |
| WSA | WSA | 75 | 2.75 | 41 | 206600 | 9.7 |
| Rectisol | Rectisol East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Rectisol West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| SCC | SCC | 90 | 3.6 | 190 | 314135 | 8.6 |
| Scenario 3 – Alternative Emission Limits | | | | | | |
| Steam Stations | Main Stack East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Main Stack West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| Sulfur Recovery | Sulfur recovery East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Sulfur recovery West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| HOW Incinerators | HOW West | 15 | 1.9 | 354 | 211588 | 19.9 |
| | HOW East | 15 | 1.9 | 386 | 183687 | 18.0 |
| Biosludge Incinerators | Biosludge East | 30 | 1.4 | 66 | 91617 | 15.7 |
| | | 30 | 1.4 | 65 | 87231 | 15.8 |
| | Biosludge West | 30 | 1.4 | 68 | 74985 | 13.5 |
| | | 30 | 1.4 | 61 | 81083 | 14.7 |
| WSA | WSA | 75 | 2.75 | 41 | 206600 | 9.7 |
| Rectisol | Rectisol East | 301 | 14.4 | 185 | 11870000 | 20.2 |
| | Rectisol West | 250 | 13.6 | 185 | 10558000 | 20.2 |
| SCC | SCC | 90 | 3.6 | 190 | 314135 | 8.6 |

Table 5-22: Source emissions per scenario provided for Sasol Secunda facility

| Source Group | Source name | Particulates (g/s) | SO ₂ (g/s) | NO _x (g/s) | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V (g/s) | Hg (g/s) | Cd+Tl (g/s) | HF (g/s) | NH ₃ (g/s) | HCl (g/s) | H ₂ S (g/s) | SO ₃ (g/s) | VOCs (benzene) (g/s) | H ₂ SO ₄ (g/s) |
|---|----------------------|--------------------|-----------------------|-----------------------|--|----------|-------------|----------|-----------------------|-----------|------------------------|-----------------------|----------------------|--------------------------------------|
| Scenario 1 – Baseline emissions | | | | | | | | | | | | | | |
| Steam Stations | Main Stack East | 70.06 | 2 899.19 | 1 939.08 | | | | | | | | | | |
| | Main Stack West | 62.32 | 2 578.74 | 1 725.55 | | | | | | | | | | |
| Sulfur Recovery | Sulfur recovery East | | | | | | | | | | 1 401.22 | | | |
| | Sulfur recovery West | | | | | | | | | | 1 246.34 | | | |
| HOW Incinerators | HOW West | 1.62 | 0.06 | 7.31 | 0.14 | 0.00063 | 0.00022 | 0.03 | 0.01 | 0.05 | | | | |
| | HOW East | 0.61 | 0.12 | 6.83 | 0.03 | 0.00005 | 0.00005 | 0.03 | 0.00 | 0.03 | | | | |
| Biosludge Incinerators | Biosludge East | 1.40 | 0.07 | 1.95 | 0.06 | - | 0.00074 | 0.06 | 0.09 | 0.03 | | | | |
| | | 1.16 | 0.40 | 1.98 | 0.06 | - | 0.00022 | 0.05 | 0.11 | 0.02 | | | | |
| | Biosludge West | 0.30 | 0.10 | 0.26 | 0.01 | - | 0.00053 | 0.06 | 0.09 | 0.03 | | | | |
| | | 1.17 | 0.03 | 4.39 | 0.03 | - | 0.00033 | 0.05 | 0.11 | 0.02 | | | | |
| WSA | WSA | | 10.67 | | | | | 0.01 | 0.003 | 0.06 | | 3.13 | | 0.27 |
| Rectisol | Rectisol East | | | | | | | | | | | | 2.00 | |
| | Rectisol West | | | | | | | | | | | | 10.00 | |
| SCC | SCC | 10.60 | | | | | | | | | | | | |
| Scenario 2a – Compliance with Existing Plant Standards | | | | | | | | | | | | | | |
| Steam Stations | Main Stack East | 166.81 | 5 838.42 | 1 834.89 | | | | | | | | | | |
| | Main Stack West | 148.37 | 5 193.09 | 1 632.08 | | | | | | | | | | |
| Sulfur Recovery | Sulfur recovery East | | | | | | | | | | 700.61 | | | |
| | Sulfur recovery West | | | | | | | | | | 623.17 | | | |

| Source Group | Source name | Particulates (g/s) | SO ₂ (g/s) | NO _x (g/s) | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V (g/s) | Hg (g/s) | Cd+Tl (g/s) | HF (g/s) | NH ₃ (g/s) | HCl (g/s) | H ₂ S (g/s) | SO ₃ (g/s) | VOCs (benzene) (g/s) | H ₂ SO ₄ (g/s) |
|--|----------------------|--------------------|-----------------------|-----------------------|--|----------|-------------|----------|-----------------------|-----------|------------------------|-----------------------|----------------------|--------------------------------------|
| HOW Incinerators | HOW West | 0.54 | 1.09 | 4.34 | 0.01 | 0.00109 | 0.00109 | 0.02 | 0.22 | 0.22 | | | | |
| | HOW East | 0.45 | 0.90 | 3.59 | 0.01 | 0.00090 | 0.00090 | 0.02 | 0.18 | 0.18 | | | | |
| Biosludge Incinerators | Biosludge East | 0.43 | 0.87 | 3.48 | 0.01 | 0.00087 | 0.00087 | 0.02 | 0.17 | 0.17 | | | | |
| | | 0.42 | 0.83 | 3.32 | 0.01 | 0.00083 | 0.00083 | 0.02 | 0.17 | 0.17 | | | | |
| | Biosludge West | 0.35 | 0.71 | 2.83 | 0.01 | 0.00071 | 0.00071 | 0.01 | 0.14 | 0.14 | | | | |
| | | 0.39 | 0.78 | 3.13 | 0.01 | 0.00078 | 0.00078 | 0.02 | 0.16 | 0.16 | | | | |
| WSA | WSA | | 10.67 | | | | | 0.01 | 0.003 | 0.06 | | 2.49 | | 0.27 |
| Rectisol | Rectisol East | | | | | | | | | | | | 42.0 | |
| | Rectisol West | | | | | | | | | | | | 37.0 | |
| SCC | SCC | 4.87 | | | | | | | | | | | | |
| Scenario 2b – Compliance with New Plant Standards | | | | | | | | | | | | | | |
| Steam Stations | Main Stack East | 83.41 | 834.06 | 1 251.09 | | | | | | | | | | |
| | Main Stack West | 74.19 | 741.87 | 1 112.81 | | | | | | | | | | |
| Sulfur Recovery | Sulfur recovery East | | | | | | | | | | 443.62 | | | |
| | Sulfur recovery West | | | | | | | | | | 394.58 | | | |
| HOW Incinerators | HOW West | 0.22 | 1.09 | 4.34 | 0.01 | 0.00109 | 0.00109 | 0.02 | 0.22 | 0.22 | | | | |
| | HOW East | 0.18 | 0.90 | 3.59 | 0.01 | 0.00090 | 0.00090 | 0.02 | 0.18 | 0.18 | | | | |
| Biosludge Incinerators | Biosludge East | 0.17 | 0.87 | 3.48 | 0.01 | 0.00087 | 0.00087 | 0.02 | 0.17 | 0.17 | | | | |
| | | 0.17 | 0.83 | 3.32 | 0.01 | 0.00083 | 0.00083 | 0.02 | 0.17 | 0.17 | | | | |
| | Biosludge West | 0.14 | 0.71 | 2.83 | 0.01 | 0.00071 | 0.00071 | 0.01 | 0.14 | 0.14 | | | | |
| | | 0.16 | 0.78 | 3.13 | 0.01 | 0.00078 | 0.00078 | 0.02 | 0.16 | 0.16 | | | | |
| WSA | WSA | | 8.71 | | | | | 0.06 | 0.004 | 0.19 | | 0.62 | | 0.27 |

Atmospheric Impact Report: Sasol Secunda Facility

| Source Group | Source name | Particulates (g/s) | SO ₂ (g/s) | NO _x (g/s) | Sum of Pb, As, Sb, Cr, Co, Cu, Mn, Ni, V (g/s) | Hg (g/s) | Cd+Tl (g/s) | HF (g/s) | NH ₃ (g/s) | HCl (g/s) | H ₂ S (g/s) | SO ₃ (g/s) | VOCs (benzene) (g/s) | H ₂ SO ₄ (g/s) |
|---|------------------------------------|--------------------|-----------------------|-----------------------|--|----------|-------------|----------|-----------------------|-----------|------------------------|-----------------------|----------------------|--------------------------------------|
| Rectisol | Rectisol East | | | | | | | | | | | | 21.7 | |
| | Rectisol West | | | | | | | | | | | | 19.3 | |
| SCC | SCC | 4.06 | | | | | | | | | | | | |
| Scenario 3 – Alternative Emission Limits | | | | | | | | | | | | | | |
| Steam Stations | Main Stack East | 216.86 | 3 336.24 | 3 574.60 | | | | | | | | | | |
| | Main Stack West | 192.89 | 2 967.48 | 3 179.49 | | | | | | | | | | |
| Sulfur Recovery | Sulfur recovery East (without WSA) | | | | | | | | | | 2 085.15 | | | |
| | Sulfur recovery West (without WSA) | | | | | | | | | | 1 854.68 | | | |
| | Sulfur recovery East (with WSA) | | | | | | | | | | 1 584.71 | | | |
| | Sulfur recovery West (with WSA) | | | | | | | | | | 1 409.55 | | | |
| HOW Incinerators | HOW West | 30.37 | 1.09 | 81.42 | 0.46 | 0.006 | 0.003 | 0.152 | 0.217 | 0.217 | | | | |
| | HOW East | 25.08 | 0.90 | 67.25 | 0.38 | 0.005 | 0.002 | 0.126 | 0.179 | 0.179 | | | | |
| Biosludge Incinerators | Biosludge East | 15.48 | 2.61 | 17.04 | 0.04 | 0.015 | 0.001 | 0.487 | 0.818 | 0.487 | | | | |
| | | 14.78 | 2.49 | 16.27 | 0.04 | 0.014 | 0.001 | 0.465 | 0.781 | 0.465 | | | | |
| | Biosludge West | 12.60 | 2.12 | 13.87 | 0.03 | 0.012 | 0.001 | 0.396 | 0.665 | 0.396 | | | | |
| | | 13.91 | 2.34 | 15.31 | 0.04 | 0.013 | 0.001 | 0.438 | 0.734 | 0.438 | | | | |
| WSA | WSA | | 10.67 | | | | | 0.015 | 0.003 | 0.06 | | 3.94 | | |
| Rectisol | Rectisol East | | | | | | | | | | | | 50.0 | |
| | Rectisol West | | | | | | | | | | | | 44.5 | |
| SCC | SCC | 13.40 | | | | | | | | | | | | |

5.1.8 Model Results

Air quality standards are fundamental tools to assist in air quality management. The National Ambient Air Quality Standards (NAAQS) (Section 5.1.2.2) are intended to reduce harmful effects on health of the majority of the population, including the very young and the elderly. In this section, predicted ambient concentrations of criteria pollutants at specific sensitive receptors are compared against the promulgated local NAAQS (Table 5-2). Predicted ambient concentrations of non-criteria pollutants (for which NAAQS are not specified) at specific sensitive receptors, are compared against appropriate international health effect screening levels (listed in Table 5-27).

Prior to dispersion modelling, fifteen receptors were identified in the vicinity of the Secunda operations (within the 50-by-50 km modelling domain). Sensitive receptors included residential areas, ambient air quality monitoring stations and points of maximum predicted pollutant concentrations (Figure 5-49 and Table 5-23). Ambient air quality monitoring stations were the first receptors identified because comparison of the predicted concentrations could be compared with measured concentrations for model validation. Residential areas, both close to the point sources and further away, were then selected. After an initial model screening process, predicted points of maximum concentrations of criteria pollutants were included as sensitive receptors in all dispersion modelling. Grid intercept points corresponding with the identified receptors were given code names such as GR1 (Grid Receptor 1). Receptor code names have been included in figures and tables for the sake of brevity. Receptors are presented in the figures and tables in increasing distance from the main source of pollutants – the Steam Stations. In response to stakeholder comments, schools and clinics within the domain were identified and are now included in the sensitive receptor map (Figure 5-49) and in the isopleth plots in Section 5.1.8.




Figure 5-49: Receptors identified for assessment of impact as a result of Secunda operations

Table 5-23: Receptors identified for assessment of impact as a result of Secunda operations

| Receptor code name ^(a) | Receptor details | Distance from source (metres) ^(b) |
|-----------------------------------|--|--|
| Langverwacht | SASOL Langverwacht monitoring station | 4717.714 |
| Secunda Club | SASOL Secunda Club monitoring station | 4970.651 |
| GR4 | Edge of plume (ash disposal facility) | 5648.012 |
| GR7 | Winkelhaak Mines | 6394.214 |
| Bosjessspruit | SASOL Bosjessspruit monitoring station | 7324.395 |
| GR5 | Embalenhle - point of maximum predicted concentrations | 7775.289 |
| GR8 | Northern boundary of Secunda | 8041.975 |
| GR3 | Point of maximum predicted concentrations near Bosjessspruit | 8851.271 |
| GR6 | Embalenhle (residential area) | 9157.673 |
| GR9 | Evander (residential area) | 11130.76 |
| GR10 | Kinross (residential area) | 18376.47 |
| GR2 | SW (Edge of domain) | 28262.32 |
| GR12 | NE (Edge of domain) | 30158.32 |
| GR1 | SE (Edge of domain) | 31042.69 |
| GR11 | NW (Edge of domain) Leandra (residential area) | 31289.15 |

(a) Code names used in Figures and Tables for brevity

(b) Figures and tables present findings for receptors in increasing distance from site

Since the focus of the study is to illustrate the relative changes in ambient concentrations of pollutants theoretically arising from different point source emission scenarios, the predicted concentration differences from scenario to scenario were provided as percentages increase or decrease over the modelled baseline scenario ($C_{Baseline\ Scenario}$). However, these percentages need to also include concentrations attributable to other sources not accommodated in the model ($C_{Background}$). The change in concentration from any of the future source or source group scenario ($C_{s, Future\ Scenario}$) compared to the baseline source or source group scenario ($C_{s, Baseline\ Scenario}$) was therefore expressed as follows:

$$\frac{C_{s, Future\ Scenario} - C_{s, Baseline\ Scenario}}{C_{Baseline\ Scenario} + C_{Background}}$$

Equation 1

The average long-term background concentrations, as given in Table 5-24, were used in this expression rather than the short-term value. If the short-term background concentrations were to be used instead (i.e. a higher value), the comparison would be less optimistic since the denominator would be larger and the fraction therefore smaller. This offers a more conservative approach.

It should be noted that the changes in ground-level concentrations, at the receptors, between the scenarios shown in the results: (1) are theoretical changes and may not necessarily be technically possible, and; (2) represent the maximum achievable improvements and are, therefore, not indicative of the day-to-day average reduction at every receptor point cumulatively.

Table 5-24: Estimated background concentrations of SO₂, NO₂ and PM₁₀ for use in predicted concentration changes between scenarios

| Monitoring Station | Background Concentration (µg/m ³) | | | |
|--------------------|---|-----------------|------------------|------------------|
| | SO ₂ | NO ₂ | PM ₁₀ | H ₂ S |
| Bosjesspruit | 18.2 | 11.4 | | 57.5 |
| Secunda Club | 18.4 | 14.4 | 78.0 | 44.9 |
| Langverwacht | 16.5 | 22.6 | 123.2 | 75.6 |
| Average | 17.7 | 16.1 | 100.6 | 59.3 |

5.1.8.1 Criteria pollutants

The findings for each of the criteria pollutants (SO₂, NO₂ and PM) are presented for each of the sources or source groups identified in two figures. The first figure presents the predicted pollutant concentration (99th percentile) at the identified receptors (Table 5-23) for each of the emission scenarios (baseline operating conditions, emissions in theoretical compliance with Existing Plant Standards [2015] and New Plant Standards [2020], and the Alternative Emission Limits) relative to the appropriate NAAQS. The second figure presents the theoretical percentage change in ground-level concentrations between the emission scenarios. The predicted frequency of exceedance of NAAQS is provided in a table for all source groups comparing the impact as a result of the emission scenarios.

For the Secunda operations, the source groups are:

- Steam Stations (as the combined impact of both Main Stack East and Main Stack West)
- Biosludge Incinerators (as the combined impact of Biosludge East 1 & 2, Biosludge West 1 & 2)
- HOW (high organic waste) Incinerators (as the combined impact of Incinerator HOW East and HOW West)
- Wet Sulfuric Acid plant (acid mist and SO₃)
- SCC (particulates)
- Sulfur recovery units (H₂S)
- Rectisol (VOCs)

The following sections focus on predicted short-term impacts. Long-term impacts are addressed in Appendix I.

Isopleth plots have included for the Baseline Emissions and Alternative Emission Limit scenarios for the Steam Station emissions of SO₂, NO₂, PM, and H₂S.

5.1.8.1.1 Sulfur Dioxide (SO₂)

Ambient concentrations of SO₂ as a result of Secunda baseline operations (Figure 5-50) were predicted to fall below the hourly NAAQS, where impact on nearby receptors is mainly a result of emissions from the Steam Stations (Figure 5-51). If Sasol were theoretically able to comply with New Plant Standards for its Steam Station boilers, ambient SO₂ concentrations would be expected to drop below 75 µg/m³ at all receptors (Figure 5-51), resulting in a 20% or greater improvement relative to the airshed baseline (Figure 5-52). At Alternative Emission Limits ambient SO₂ concentrations were predicted to be less than 150 µg/m³ at all except two (Bosjesspruit and GR3) receptors (Figure 5-50 and Figure 5-51); equivalent to an increase of SO₂ ambient concentrations, relative to the airshed baseline, between 7.5% and 20.4% depending on the receptor (Figure 5-52). Despite this increase compliance with the NAAQS was predicted.

Isopleth plots are presented for the predicted 99th percentile hourly ground-level SO₂ concentrations as a result of the Baseline (Figure 5-59) and Alternative Emission Limits (Figure 5-60) from the Steam Stations. The maximum predicted 99th percentile ground-level concentrations were below the NAAQ limit concentration and as such the level presented in both figures represents 29% of the hourly limit (100 µg/m³).




Figure 5-50: Predicted 99th percentile hourly SO₂ concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-51: Predicted 99th percentile hourly SO₂ concentration at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-52: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1)

Impacts on ambient SO₂ concentrations as a result of the Biosludge and HOW incinerators are expected to be minimal compared with the Steam Stations (Figure 5-54, and Figure 5-56), where concentrations at all receptors for all scenarios are predicted to be less than 10 µg/m³. Theoretical compliance with Existing and New Plant Standards for the incinerators will result in small increases in ambient SO₂ concentrations (~2% - Figure 5-55 and Figure 5-56), due to higher permitted emission rates compared with the current baseline operating emissions. At the Alternative Emission Limits, increased emissions from the Biosludge Incinerators were predicted to result in increased ambient SO₂ concentrations, by an average of 4%, relative to the airshed baseline.

Predicted ambient SO₂ concentrations as a result of emissions from the Wet Sulfuric Acid Plant were predicted to be less than 2 µg/m³ for all scenarios (Figure 5-57) where theoretical compliance with New Plant Standards would result in less than a 1% improvement to the airshed baseline (Figure 5-58).




Figure 5-53: Predicted 99th percentile hourly SO₂ concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-54: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Sunfuels Biosludge Incinerators (change calculated using Equation 1)




Figure 5-55: Predicted 99th percentile hourly SO₂ concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-56: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (change calculated using Equation 1)




Figure 5-57: Predicted 99th percentile hourly SO₂ concentration at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-58: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (change calculated using Equation 1)




Figure 5-59: Predicted 99th percentile SO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure 5-60: Predicted 99th percentile SO₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations

5.1.8.1.2 Nitrogen Dioxide (NO₂)

The maximum predicted NO₂ concentrations are expected at receptors Bosjessspruit and GR3 for the baseline (Figure 5-61 and Figure 5-62). This may be a result of atmospheric chemical transformations (conversion of NO to NO₂), where receptors located further away from operations, were predicted to have higher ambient NO₂ concentrations. Reductions in ambient NO₂ concentrations were predicted at all receptors due to theoretical compliance with Existing Plant Standards as a result of reduced emissions from the Steam Stations (Figure 5-63). Increases in ambient NO₂ concentrations are expected at the first 11 receptors (Figure 5-63) due to theoretical compliance with New Plant Standards, relative to the airshed baseline, as a result of changes to plume buoyancy. Alternative Emission Limits, as proposed for the Steam Stations, were predicted to result in increased ambient NO₂ concentrations (Figure 5-62) where ambient NO₂ increases between 28% and 57% were predicted (Figure 5-63). Isopleth plots are presented for the predicted 99th percentile hourly ground-level NO₂ concentrations as a result of the Baseline (Figure 5-64) and Alternative Emission Limits (Figure 5-65) from the Steam Stations. The maximum predicted 99th percentile ground-level concentrations were below the NAAQ limit concentration and as such the level presented in both figures represents 22% of the hourly limit (44 µg/m³).

Biosludge incinerator emissions, due to theoretical compliance with Existing Plant Standards, were predicted to result in elevated NO₂ concentrations at all receptors (less than 7.5% increase - Figure 5-66 and Figure 5-67) due to increases in the allowable emissions from the Biosludge Incinerators. The HOW incinerators (Figure 5-68) are a minor contributor to the ground-level impacts and compliance with Existing and New Plant Standards is likely to result in minor improvements (less than 3% - Figure 5-69). The Alternative Emission Limits proposed for the Biosludge and HOW Incinerators were predicted to result in increased ambient NO₂ concentrations of 35% and 32% on average, relative to the airshed baseline (Figure 5-67 and Figure 5-69).




Figure 5-61: Predicted 99th percentile hourly NO₂ concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-62: Predicted 99th percentile hourly NO₂ concentration at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-63: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at identified receptors for Synfuels Steam Stations (change calculated using Equation 1)




Figure 5-64: Predicted 99th percentile NO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure 5-65: Predicted 99th percentile NO₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations




Figure 5-66: Predicted 99th percentile hourly NO₂ concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-67: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1)




Figure 5-68: Predicted 99th percentile hourly NO₂ concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-69: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1)

5.1.8.1.3 Particulate Matter (PM_{2.5} and PM₁₀)

For particulate matter, NAAQS are available for PM₁₀ and PM_{2.5}. Ambient air quality impacts for both particulate fractions (i.e. PM₁₀ and PM_{2.5}) thus need to be considered.

Predicted concentrations of particulate matter (PM) were conservatively assumed to be PM_{2.5} since it was not possible to establish the PM_{2.5}/PM₁₀ split. Monitoring of PM at the Secunda Club and Langverwacht monitoring stations, however, only includes PM₁₀ and therefore figures present predicted PM concentrations relative to the daily PM₁₀ NAAQS.

The current emissions from the source groups of concern at the Secunda operations result in low ground-level concentrations of particulates (PM); less than 30 µg/m³ for all source groups (Figure 5-70). Further reductions (up to 5% reduction compared with the baseline operations) in ground-level PM concentrations are expected after compliance with Existing and New Plant Standards (Figure 5-71, Figure 5-75, Figure 5-77, and, Figure 5-79). Increased ambient PM concentrations were predicted for the Alternative Emission Limits proposed for the Steam Stations (3% on average), Biosludge (9% on average) and HOW Incinerators (4% on average) relative to the airshed baseline.

Isopleth plots are presented for the predicted 99th percentile daily ground-level PM concentrations as a result of the Baseline (Figure 5-72) and Alternative Emission Limits (Figure 5-73) from the Steam Stations. The maximum predicted 99th percentile ground-level concentrations were below the daily NAAQ limit and as such the level presented in both figures represents 9% of the daily guideline (7 µg/m³).




Figure 5-70: Predicted 99th percentile daily PM concentration at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-71: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1)




Figure 5-72: Predicted 99th percentile daily PM concentrations as a result of Baseline emissions from the Steam Stations




Figure 5-73: Predicted 99th percentile daily PM concentrations as a result of Alternative Emission Limit emissions from the Steam Stations




Figure 5-74: Predicted 99th percentile daily PM concentration at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-75: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (change calculated using Equation 1)




Figure 5-76: Predicted 99th percentile daily PM concentration at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-77: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (change calculated using Equation 1)

Regarding the Secunda SCC, the interim Alternative Emission Limit is a ceiling limit of 330 mg/Nm³ since the existing plant standard cannot be complied with in the interim. Therefore the Sasol Synfuels facility is requesting a postponement of the standard until a technology solution is implemented to allow compliance with the new plant standard in one abatement step. A smaller reduction was predicted for the interim Alternative Emission Limit in comparison to compliance with Existing and New Plant Standards (Figure 5-79) but the modelled interim alternative emission limit scenario demonstrates no significant increase in ambient air quality concentrations (less than 10 µg/m³). While the SCC does not result in modelled ambient PM₁₀ concentrations above the NAAQS, measured ambient concentrations reflecting the cumulative contribution from all sources in the airshed indicate that ambient PM₁₀ concentrations do exceed the NAAQS. This is due to other sources of PM₁₀ emissions in the ambient environment.

Isopleth plots are presented for the predicted 99th percentile daily ground-level PM concentrations as a result of the Baseline (Figure 5-80) and Alternative Emission Limits (Figure 5-81) from the SCC (Catalytic Cracker). The maximum predicted 99th percentile ground-level concentrations were below the daily NAAQ limit and as such the level presented in both figures represents 4% of the daily guideline (3 µg/m³).




Figure 5-78: Predicted 99th percentile daily PM concentrations at identified receptors for Synfuels SCC (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-79: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels SCC (change calculated using Equation 1)




Figure 5-80: Predicted 99th percentile daily PM₁₀ concentrations as a result of Baseline Emission Limit emissions from the Catalytic Cracker




Figure 5-81: Predicted 99th percentile daily PM₁₀ concentrations as a result of Alternative Emission Limit emissions from the Catalytic Cracker

The contribution of predicted PM₁₀ to total predicted PM (including secondary particulate formation) was calculated for the Synfuels Steam Stations (Table 5-25). PM₁₀ contribution to total PM varied by between 12.4 and 24.7% depending on the sensitive receptor, indicating the role of SO₂ and NO₂ emissions on particulate formation. The large contribution of secondary particulate formation is likely due to the high NH₃ levels in the area allowing for formation of ammonium sulfates and ammonium nitrates.

Table 5-25: Predicted 99th percentile daily PM₁₀ and total PM concentration at identified receptors for Synfuels Steam Stations

| Receptor | PM concentration (µg/m ³) | PM ₁₀ concentration (µg/m ³) | PM ₁₀ contribution |
|--------------|---------------------------------------|---|-------------------------------|
| GR1 | 5.10 | 0.83 | 16.3% |
| GR2 | 4.31 | 0.73 | 17.0% |
| GR3 | 8.29 | 1.59 | 19.2% |
| GR4 | 10.15 | 1.64 | 16.1% |
| GR5 | 8.46 | 1.66 | 19.7% |
| GR6 | 7.41 | 1.70 | 23.0% |
| GR7 | 6.79 | 1.36 | 20.0% |
| GR8 | 7.34 | 1.09 | 14.8% |
| GR9 | 6.16 | 1.00 | 16.2% |
| GR10 | 5.06 | 0.95 | 18.8% |
| GR11 | 3.21 | 0.51 | 16.0% |
| GR12 | 4.78 | 0.59 | 12.4% |
| Bosjesspruit | 8.67 | 2.14 | 24.7% |
| Secunda Club | 7.67 | 1.33 | 17.4% |
| Langverwacht | 9.24 | 1.98 | 21.5% |

5.1.8.1.4 Total Volatile Organic Compounds (TVOC)

The predicted impact as a result of TVOC emissions from the combined Rectisol East and West plant operations was assessed against the NAAQS annual standard for benzene ($5 \mu\text{g}/\text{m}^3$) (Figure 5-82 and Figure 5-83). Ambient TVOC concentrations from these sources were predicted to fall well within the annual standard.




Figure 5-82: Predicted annual average TVOC concentrations at identified receptors for Synfuels Rectisol (relative to the annual NAAQS for benzene)

Figure 5-83 shows the impacts of the different scenarios more clearly, by repeating the graph for Figure 5-82 with the axis re-scaled.




Figure 5-83: Predicted annual average TVOC concentrations at identified receptors for Synfuels Rectisol (relative to the annual NAAQS for benzene) (Based on Figure 5-82 with the y-axis rescaled for visibility)

Predicted baseline impacts on ambient VOC concentrations from current operations are no higher than 0.012 µg/Nm³. Predicted impacts at the existing plant standard ceiling limit are higher, since the ceiling value of 250 mg/Nm³ is modelled and not current average emissions. Theoretical compliance with New Plant Standards shows an improvement on theoretical compliance with Existing Plant Standards. At the proposed Alternative Emission Limit, the greatest differential in predicted ambient concentrations for existing plant standards compared with the requested alternative emission limit is 0.015 µg/Nm³ at Bosjesspruit. Operating at the alternative emission limit would not exceed 0.2% contribution towards the NAAQS.

5.1.8.2 Non-Criteria Pollutants

Ambient pollutant concentrations, either from the dispersion modelling or from direct physical measurements, are typically compared to defined standards or other thresholds to assess the health and/or environmental risk implications of the predicted or measured air quality. In South Africa, NAAQS have been set for criteria pollutants at limits deemed to uphold a permissible level of health risk and the assessment has accordingly been based on a comparison between the predicted concentrations and the NAAQS. The measured concentrations have been used to ascertain the representativeness of the modelling and to assess compliance with the NAAQS as a function of all sources of emissions.

Where NAAQS have not been set health-effect screening levels, appropriate for assessing the non-criteria pollutants emitted by Sasol Synfuels, were identified from literature reviews and internationally recognised databases. These non-criteria pollutants for which screening levels were identified, include the sulphur recovery plant as a source of H₂S; the wet sulphuric acid plant as a source of SO₃; and, various emissions from incinerators, namely lead, arsenic, antimony, chromium, cobalt, copper, manganese, nickel and vanadium. The health-effect screening levels used are listed in Table

5-26. In the case of H₂S, Sasol commissioned an independent toxicologist to conduct a desktop study of suitable health benchmarks for use in the AIR (Annexure C).

Table 5-26: Most stringent health-effect screening level identified for all non-criteria pollutants assessed

| Compound | Acute exposure ^(a) [units: µg/m ³] | Chronic exposure ^(b) [units: µg/m ³] |
|---|--|--|
| Lead (Pb) | (c) | (d) |
| Arsenic (As) | 0.2 (g) | 0.015 (g) |
| Antimony (Sb) | (c) | (d) |
| Chromium (Cr) | (c) | 0.1 (e) |
| Cobalt (Co) | (c) | 0.1 (f) |
| Copper (Cu) | 100 (g) | (d) |
| Manganese (Mn) | (c) | 0.05 (e) |
| Nickel (Ni) | 0.2 (g) | 0.014 (g) |
| Vanadium (V) | 0.8 (f) | 0.1 (f) |
| Hydrogen sulphide (H ₂ S) | 135 (h) | (d) |
| Sulfur trioxide (SO ₃) | 22.5 (f) | (d) |
| Ammonia (NH ₃) | 1184 ^(f) | (d) |
| (a) Hourly concentrations compared with short-term / acute exposure health effect screening level (b) Annual concentrations compared with long-term / chronic exposure health effect screening level (c) No hourly health screening level (d) No annual health screening level (e) US-EPA IRIS Inhalation Reference Concentrations (µg/m ³) – chronic (f) US ATSDR Maximum Risk Levels (MRLs) (µg/m ³) - acute (g) Californian OEHHA (µg/m ³) – acute (h) Haahtele <i>et al.</i> , 1992 - acute (4-hour average) | | |

A screening exercise of non-criteria pollutants emitted from the Sasol Synfuels Facility (combined) Incinerators – including all non-criteria pollutants listed in Table 5-22 - was undertaken to identify pollutants that would be likely to exceed the most stringent health-effect screening levels identified. The non-criteria pollutants that would possibly exceed the screening level concentrations included: manganese (Mn), ammonia (NH₃), hydrogen chloride (HCl), and, hydrogen fluoride (HF). Further analysis showed that predicted ground-level concentrations are likely to comply with the strictest health effect screening concentrations (Table 5-27).

Table 5-27: Screening of non-criteria pollutants against health effect screening levels

| Compound | Acute exposure ^(a) [units: µg/m ³] | | | Chronic exposure ^(b) [units: µg/m ³] | | |
|--|---|--------------------------------------|---|---|--------------------------------------|---|
| | Minimum concentration ^(c) | Maximum concentration ^(d) | Strictest health effect screening level | Minimum concentration ^(c) | Maximum concentration ^(d) | Strictest health effect screening level |
| <i>Scenario 1 - Baseline emissions</i> | | | | | | |
| Mn | | | | 0.0000 | 0.0021 | 0.05 ^(e) |
| NH ₃ | 0.0000 | 0.0031 | 1184 ^(f) | | | |
| HCl | 0.0000 | 0.0276 | 2100 ^(g) | | | |
| HF | 0.0000 | 0.0205 | 240 ^(g) | | | |
| <i>Scenario 2a and 2b – Theoretical compliance with Existing and New Plant Standards</i> | | | | | | |
| Mn | | | | 0.0000 | 0.0002 | 0.05 ^(e) |
| NH ₃ | 0.0000 | 0.1353 | 1184 ^(f) | | | |
| HCl | 0.0000 | 0.1353 | 2100 ^(g) | | | |
| HF | 0.0000 | 0.0137 | 240 ^(g) | | | |
| <i>Scenario 3 – Alternative Emission Limits</i> | | | | | | |
| Mn | | | | 0.0000 | 0.0251 | 0.05 ^(e) |
| NH ₃ | 0.0000 | 9.0631 | 1184 ^(f) | | | |
| HCl | 0.0000 | 5.3992 | 2100 ^(g) | | | |
| HF | 0.0000 | 5.3992 | 240 ^(g) | | | |

- (a) hourly concentrations compared with short-term / acute exposure health effect screening level
- (b) annual concentrations compared with long-term / chronic exposure health effect screening level
- (c) minimum concentration predicted across the 12 receptors (Table 5-23)
- (d) maximum concentration predicted across the 12 receptors (Table 5-23)
- (e) US-EPA IRIS Inhalation Reference Concentrations (µg/m³) – chronic
- (f) US ATSDR Maximum Risk Levels (MRLs) (µg/m³) - acute
- (g) Californian OEHHA (µg/m³) – acute

5.1.8.2.1 Sum of lead, arsenic, antimony, chromium, cobalt, copper, manganese, nickel and vanadium

Baseline emissions of the ‘Sum of lead, arsenic, antimony, chromium, cobalt, copper, manganese, nickel and vanadium’ from the Sasol Synfuels Facility Incinerators will exceed the Existing Plant Standards. The ambient impact of these emissions was modelled (at emission rates provide in Table 5-22) for the baseline emissions and if Existing and New Plant Standards were achieved. After accounting for the proportional contribution of each pollutant, predicted concentrations (99th percentile hourly and annual average) were compared with the appropriate strictest health effect screening levels. No exceedances of hourly / acute (Table 5-28) or annual / chronic (Table 5-29) screening levels were found. No exceedances of hourly / acute (Table 5-28) or annual / chronic (Table 5-29) screening levels were predicted for the Alternative Emission Limits.

Table 5-28: Predicted hourly ambient concentrations ($\mu\text{g}/\text{m}^3$) of metal pollutants emitted from the Sasol Synfuels Facility Incinerators (a)

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (b) | Cobalt (Co) (b) | Copper (Cu) (d) | Manganese (Mn) (b) | Nickel (Ni) (c) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| Scenario 1 - Baseline emissions – HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0020 | 0.0003 | 0.0001 | 0.0041 | 0.0001 | 0.0033 | 0.0408 | 0.0281 | 0.0014 |
| Secunda Club | 0.0009 | 0.0002 | 0.0001 | 0.0019 | 0.0001 | 0.0016 | 0.0192 | 0.0132 | 0.0007 |
| GR4 | 0.0019 | 0.0003 | 0.0001 | 0.0038 | 0.0001 | 0.0031 | 0.0382 | 0.0263 | 0.0013 |
| GR7 | 0.0011 | 0.0002 | 0.0001 | 0.0021 | 0.0001 | 0.0017 | 0.0216 | 0.0149 | 0.0007 |
| Bosjesspruit | 0.0019 | 0.0003 | 0.0001 | 0.0038 | 0.0001 | 0.0031 | 0.0380 | 0.0262 | 0.0013 |
| GR5 | 0.0009 | 0.0002 | 0.0001 | 0.0018 | 0.0000 | 0.0015 | 0.0183 | 0.0126 | 0.0006 |
| GR8 | 0.0008 | 0.0001 | 0.0000 | 0.0016 | 0.0000 | 0.0013 | 0.0163 | 0.0112 | 0.0006 |
| GR3 | 0.0010 | 0.0002 | 0.0001 | 0.0021 | 0.0001 | 0.0017 | 0.0213 | 0.0147 | 0.0007 |
| GR6 | 0.0008 | 0.0001 | 0.0001 | 0.0017 | 0.0000 | 0.0014 | 0.0169 | 0.0117 | 0.0006 |
| GR9 | 0.0005 | 0.0001 | 0.0000 | 0.0011 | 0.0000 | 0.0009 | 0.0108 | 0.0075 | 0.0004 |
| GR10 | 0.0004 | 0.0001 | 0.0000 | 0.0009 | 0.0000 | 0.0007 | 0.0086 | 0.0059 | 0.0003 |
| GR2 | 0.0003 | 0.0001 | 0.0000 | 0.0006 | 0.0000 | 0.0005 | 0.0061 | 0.0042 | 0.0002 |
| GR12 | 0.0001 | 0.0000 | 0.0000 | 0.0003 | 0.0000 | 0.0002 | 0.0027 | 0.0018 | 0.0001 |
| GR1 | 0.0006 | 0.0001 | 0.0000 | 0.0013 | 0.0000 | 0.0010 | 0.0128 | 0.0088 | 0.0004 |
| GR11 | 0.0003 | 0.0000 | 0.0000 | 0.0006 | 0.0000 | 0.0005 | 0.0059 | 0.0041 | 0.0002 |
| Scenario 1 - Baseline emissions – Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.007 | 0.006 | 0.001 | 0.015 | 0.001 | 0.057 | 0.015 | 0.014 | 0.014 |
| Secunda Club | 0.002 | 0.002 | 0.001 | 0.005 | 0.000 | 0.021 | 0.005 | 0.005 | 0.005 |
| GR4 | 0.010 | 0.009 | 0.002 | 0.023 | 0.001 | 0.087 | 0.022 | 0.022 | 0.022 |
| GR7 | 0.002 | 0.002 | 0.001 | 0.006 | 0.000 | 0.021 | 0.005 | 0.005 | 0.005 |
| Bosjesspruit | 0.008 | 0.007 | 0.002 | 0.018 | 0.001 | 0.067 | 0.017 | 0.017 | 0.017 |
| GR5 | 0.005 | 0.005 | 0.001 | 0.011 | 0.000 | 0.042 | 0.011 | 0.011 | 0.011 |

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (b) | Cobalt (Co) (b) | Copper (Cu) (d) | Manganese (Mn) (b) | Nickel (Ni) (c) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| GR8 | 0.003 | 0.002 | 0.001 | 0.006 | 0.000 | 0.023 | 0.006 | 0.006 | 0.006 |
| GR3 | 0.003 | 0.003 | 0.001 | 0.007 | 0.000 | 0.027 | 0.007 | 0.007 | 0.007 |
| GR6 | 0.003 | 0.003 | 0.001 | 0.008 | 0.000 | 0.030 | 0.008 | 0.008 | 0.008 |
| GR9 | 0.001 | 0.001 | 0.000 | 0.003 | 0.000 | 0.010 | 0.003 | 0.003 | 0.003 |
| GR10 | 0.002 | 0.002 | 0.000 | 0.004 | 0.000 | 0.016 | 0.004 | 0.004 | 0.004 |
| GR2 | 0.001 | 0.001 | 0.000 | 0.003 | 0.000 | 0.011 | 0.003 | 0.003 | 0.003 |
| GR12 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.002 | 0.001 | 0.001 | 0.001 |
| GR1 | 0.001 | 0.001 | 0.000 | 0.003 | 0.000 | 0.012 | 0.003 | 0.003 | 0.003 |
| GR11 | 0.001 | 0.001 | 0.000 | 0.002 | 0.000 | 0.007 | 0.002 | 0.002 | 0.002 |
| Scenario 2a and 2b – Theoretical compliance with Existing and New Plant Standards – HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0002 | 0.0000 | 0.0000 | 0.0005 | 0.0000 | 0.0004 | 0.0046 | 0.0032 | 0.0002 |
| Secunda Club | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0002 | 0.0024 | 0.0016 | 0.0001 |
| GR4 | 0.0002 | 0.0000 | 0.0000 | 0.0005 | 0.0000 | 0.0004 | 0.0046 | 0.0032 | 0.0002 |
| GR7 | 0.0001 | 0.0000 | 0.0000 | 0.0003 | 0.0000 | 0.0002 | 0.0027 | 0.0019 | 0.0001 |
| Bosjesspruit | 0.0002 | 0.0000 | 0.0000 | 0.0005 | 0.0000 | 0.0004 | 0.0050 | 0.0034 | 0.0002 |
| GR5 | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0002 | 0.0023 | 0.0016 | 0.0001 |
| GR8 | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0002 | 0.0020 | 0.0014 | 0.0001 |
| GR3 | 0.0001 | 0.0000 | 0.0000 | 0.0003 | 0.0000 | 0.0002 | 0.0027 | 0.0019 | 0.0001 |
| GR6 | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0002 | 0.0022 | 0.0015 | 0.0001 |
| GR9 | 0.0001 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0013 | 0.0009 | 0.0000 |
| GR10 | 0.0001 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0011 | 0.0007 | 0.0000 |
| GR2 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0007 | 0.0005 | 0.0000 |
| GR12 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0003 | 0.0002 | 0.0000 |
| GR1 | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0001 | 0.0015 | 0.0011 | 0.0001 |

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (b) | Cobalt (Co) (b) | Copper (Cu) (d) | Manganese (Mn) (b) | Nickel (Ni) (c) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| GR11 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0007 | 0.0005 | 0.0000 |
| Scenario 2a and 2b – Theoretical compliance with Existing and New Plant Standards – Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.001 | 0.001 | 0.000 | 0.003 | 0.000 | 0.012 | 0.003 | 0.003 | 0.003 |
| Secunda Club | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.004 | 0.001 | 0.001 | 0.001 |
| GR4 | 0.002 | 0.002 | 0.000 | 0.004 | 0.000 | 0.016 | 0.004 | 0.004 | 0.004 |
| GR7 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.004 | 0.001 | 0.001 | 0.001 |
| Bosjesspruit | 0.002 | 0.001 | 0.000 | 0.003 | 0.000 | 0.013 | 0.003 | 0.003 | 0.003 |
| GR5 | 0.001 | 0.001 | 0.000 | 0.002 | 0.000 | 0.008 | 0.002 | 0.002 | 0.002 |
| GR8 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.004 | 0.001 | 0.001 | 0.001 |
| GR3 | 0.001 | 0.001 | 0.000 | 0.001 | 0.000 | 0.005 | 0.001 | 0.001 | 0.001 |
| GR6 | 0.001 | 0.001 | 0.000 | 0.002 | 0.000 | 0.006 | 0.002 | 0.002 | 0.002 |
| GR9 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.002 | 0.001 | 0.001 | 0.001 |
| GR10 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.003 | 0.001 | 0.001 | 0.001 |
| GR2 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.002 | 0.001 | 0.001 | 0.001 |
| GR12 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR1 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.002 | 0.001 | 0.001 | 0.001 |
| GR11 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| Scenario 3 – Alternative Emission Limits - HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0348 | 0.0059 | 0.0021 | 0.0706 | 0.0019 | 0.0574 | 0.1345 | 0.0796 | 0.0246 |
| Secunda Club | 0.0179 | 0.0031 | 0.0011 | 0.0363 | 0.0010 | 0.0295 | 0.0615 | 0.0392 | 0.0127 |
| GR4 | 0.0347 | 0.0059 | 0.0021 | 0.0705 | 0.0019 | 0.0574 | 0.1238 | 0.0734 | 0.0246 |
| GR7 | 0.0205 | 0.0035 | 0.0012 | 0.0416 | 0.0011 | 0.0339 | 0.0687 | 0.0479 | 0.0145 |
| Bosjesspruit | 0.0379 | 0.0065 | 0.0023 | 0.0768 | 0.0020 | 0.0625 | 0.1200 | 0.0791 | 0.0268 |
| GR5 | 0.0175 | 0.0030 | 0.0011 | 0.0355 | 0.0009 | 0.0289 | 0.0588 | 0.0395 | 0.0124 |

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (b) | Cobalt (Co) (b) | Copper (Cu) (d) | Manganese (Mn) (b) | Nickel (Ni) (c) | Vanadium (V) (e) |
|--|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| GR8 | 0.0153 | 0.0026 | 0.0009 | 0.0311 | 0.0008 | 0.0253 | 0.0523 | 0.0331 | 0.0108 |
| GR3 | 0.0205 | 0.0035 | 0.0012 | 0.0417 | 0.0011 | 0.0339 | 0.0668 | 0.0391 | 0.0145 |
| GR6 | 0.0164 | 0.0028 | 0.0010 | 0.0333 | 0.0009 | 0.0271 | 0.0548 | 0.0356 | 0.0116 |
| GR9 | 0.0099 | 0.0017 | 0.0006 | 0.0201 | 0.0005 | 0.0164 | 0.0346 | 0.0227 | 0.0070 |
| GR10 | 0.0080 | 0.0014 | 0.0005 | 0.0163 | 0.0004 | 0.0133 | 0.0276 | 0.0183 | 0.0057 |
| GR2 | 0.0057 | 0.0010 | 0.0003 | 0.0115 | 0.0003 | 0.0094 | 0.0198 | 0.0127 | 0.0040 |
| GR12 | 0.0024 | 0.0004 | 0.0001 | 0.0049 | 0.0001 | 0.0040 | 0.0085 | 0.0055 | 0.0017 |
| GR1 | 0.0117 | 0.0020 | 0.0007 | 0.0238 | 0.0006 | 0.0193 | 0.0409 | 0.0270 | 0.0083 |
| GR11 | 0.0055 | 0.0009 | 0.0003 | 0.0111 | 0.0003 | 0.0091 | 0.0191 | 0.0121 | 0.0039 |
| Scenario 3 – Alternative Emission Limits - Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.005 | 0.001 | 0.000 | 0.011 | 0.000 | 0.009 | 0.106 | 0.073 | 0.004 |
| Secunda Club | 0.001 | 0.000 | 0.000 | 0.003 | 0.000 | 0.002 | 0.026 | 0.018 | 0.001 |
| GR4 | 0.007 | 0.001 | 0.000 | 0.013 | 0.000 | 0.011 | 0.135 | 0.093 | 0.005 |
| GR7 | 0.002 | 0.000 | 0.000 | 0.003 | 0.000 | 0.003 | 0.033 | 0.023 | 0.001 |
| Bosjesspruit | 0.005 | 0.001 | 0.000 | 0.009 | 0.000 | 0.007 | 0.092 | 0.063 | 0.003 |
| GR5 | 0.003 | 0.001 | 0.000 | 0.006 | 0.000 | 0.005 | 0.065 | 0.044 | 0.002 |
| GR8 | 0.001 | 0.000 | 0.000 | 0.003 | 0.000 | 0.002 | 0.027 | 0.019 | 0.001 |
| GR3 | 0.002 | 0.000 | 0.000 | 0.004 | 0.000 | 0.003 | 0.042 | 0.029 | 0.001 |
| GR6 | 0.003 | 0.000 | 0.000 | 0.005 | 0.000 | 0.004 | 0.052 | 0.036 | 0.002 |
| GR9 | 0.001 | 0.000 | 0.000 | 0.002 | 0.000 | 0.001 | 0.016 | 0.011 | 0.001 |
| GR10 | 0.001 | 0.000 | 0.000 | 0.002 | 0.000 | 0.002 | 0.021 | 0.014 | 0.001 |
| GR2 | 0.001 | 0.000 | 0.000 | 0.002 | 0.000 | 0.001 | 0.016 | 0.011 | 0.001 |
| GR12 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.004 | 0.002 | 0.000 |
| GR1 | 0.001 | 0.000 | 0.000 | 0.002 | 0.000 | 0.002 | 0.020 | 0.014 | 0.001 |

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (b) | Cobalt (Co) (b) | Copper (Cu) (d) | Manganese (Mn) (b) | Nickel (Ni) (c) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| GR11 | 0.001 | 0.000 | 0.000 | 0.001 | 0.000 | 0.001 | 0.011 | 0.008 | 0.000 |
| (a) exceedances of strictest health screening level highlighted (b) no hourly health screening level (c) Californian OEHHA ($\mu\text{g}/\text{m}^3$) – acute screening level of 0.2 $\mu\text{g}/\text{m}^3$ (d) Californian OEHHA ($\mu\text{g}/\text{m}^3$) – acute screening level of 100 $\mu\text{g}/\text{m}^3$ over 1 hour (e) US ATSDR Maximum Risk Levels (MRLs) ($\mu\text{g}/\text{m}^3$) – acute MRL of 0.8 $\mu\text{g}/\text{m}^3$ | | | | | | | | | |

Table 5-29: Predicted annual ambient concentrations ($\mu\text{g}/\text{m}^3$) of metal pollutants emitted from the Sasol Secunda Facility Incinerators (a)

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (d) | Cobalt (Co) (e) | Copper (Cu) (b) | Manganese (Mn) (f) | Nickel (Ni) (g) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| Scenario 1 - Baseline emissions – HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0001 | 0.0018 | 0.0012 | 0.0001 |
| Secunda Club | 0.0001 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0012 | 0.0008 | 0.0000 |
| GR4 | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0001 | 0.0018 | 0.0012 | 0.0001 |
| GR7 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0010 | 0.0007 | 0.0000 |
| Bosjesspruit | 0.0001 | 0.0000 | 0.0000 | 0.0002 | 0.0000 | 0.0002 | 0.0022 | 0.0015 | 0.0001 |
| GR5 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0008 | 0.0006 | 0.0000 |
| GR8 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0010 | 0.0007 | 0.0000 |
| GR3 | 0.0001 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0012 | 0.0008 | 0.0000 |
| GR6 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0001 | 0.0009 | 0.0006 | 0.0000 |
| GR9 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0000 | 0.0006 | 0.0004 | 0.0000 |
| GR10 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0000 | 0.0005 | 0.0004 | 0.0000 |
| GR2 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0003 | 0.0002 | 0.0000 |
| GR12 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0002 | 0.0001 | 0.0000 |
| GR1 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0005 | 0.0003 | 0.0000 |
| GR11 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0003 | 0.0002 | 0.0000 |
| Scenario 1 - Baseline emissions – Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.003 | 0.001 | 0.001 | 0.001 |
| Secunda Club | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR4 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.003 | 0.001 | 0.001 | 0.001 |

Atmospheric Impact Report: Sasol Secunda Facility

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (d) | Cobalt (Co) (e) | Copper (Cu) (b) | Manganese (Mn) (f) | Nickel (Ni) (g) | Vanadium (V) (e) |
|---|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| GR7 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| Bosjesspruit | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.002 | 0.001 | 0.001 | 0.001 |
| GR5 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR8 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR3 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR6 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR9 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR10 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 |
| GR2 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR12 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR1 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR11 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Scenario 2a and 2b – Theoretical compliance with Existing and New Plant Standards – HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0002 | 0.0001 | 0.0000 |
| Secunda Club | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR4 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0002 | 0.0001 | 0.0000 |
| GR7 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| Bosjesspruit | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0003 | 0.0002 | 0.0000 |
| GR5 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR8 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR3 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR6 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR9 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0001 | 0.0000 |
| GR10 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0000 |
| GR2 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| GR12 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| GR1 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0000 |
| GR11 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| Scenario 2a and 2b – Theoretical compliance with Existing and New Plant Standards – Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |

Atmospheric Impact Report: Sasol Secunda Facility

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (d) | Cobalt (Co) (e) | Copper (Cu) (b) | Manganese (Mn) (f) | Nickel (Ni) (g) | Vanadium (V) (e) |
|--|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| Secunda Club | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR4 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR7 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Bosjesspruit | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR5 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR8 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR3 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR6 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR9 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR10 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR2 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR12 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR1 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| GR11 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Scenario 3 – Alternative Emission Limits – HOW Incinerators | | | | | | | | | |
| Langverwacht | 0.0015 | 0.0003 | 0.0001 | 0.0031 | 0.0001 | 0.0025 | 0.0057 | 0.003 | 0.0011 |
| Secunda Club | 0.0011 | 0.0002 | 0.0001 | 0.0023 | 0.0001 | 0.0018 | 0.0039 | 0.002 | 0.0008 |
| GR4 | 0.0016 | 0.0003 | 0.0001 | 0.0033 | 0.0001 | 0.0027 | 0.0057 | 0.004 | 0.0012 |
| GR7 | 0.0009 | 0.0002 | 0.0001 | 0.0019 | 0.0001 | 0.0015 | 0.0032 | 0.002 | 0.0007 |
| Bosjesspruit | 0.0020 | 0.0003 | 0.0001 | 0.0040 | 0.0001 | 0.0032 | 0.0070 | 0.004 | 0.0014 |
| GR5 | 0.0008 | 0.0001 | 0.0000 | 0.0016 | 0.0000 | 0.0013 | 0.0027 | 0.002 | 0.0006 |
| GR8 | 0.0009 | 0.0002 | 0.0001 | 0.0018 | 0.0000 | 0.0015 | 0.0032 | 0.002 | 0.0006 |
| GR3 | 0.0011 | 0.0002 | 0.0001 | 0.0022 | 0.0001 | 0.0018 | 0.0037 | 0.002 | 0.0008 |
| GR6 | 0.0008 | 0.0001 | 0.0000 | 0.0016 | 0.0000 | 0.0013 | 0.0028 | 0.002 | 0.0006 |
| GR9 | 0.0006 | 0.0001 | 0.0000 | 0.0011 | 0.0000 | 0.0009 | 0.0019 | 0.001 | 0.0004 |
| GR10 | 0.0005 | 0.0001 | 0.0000 | 0.0010 | 0.0000 | 0.0008 | 0.0017 | 0.001 | 0.0003 |
| GR2 | 0.0002 | 0.0000 | 0.0000 | 0.0005 | 0.0000 | 0.0004 | 0.0009 | 0.001 | 0.0002 |
| GR12 | 0.0002 | 0.0000 | 0.0000 | 0.0003 | 0.0000 | 0.0003 | 0.0005 | 0.000 | 0.0001 |
| GR1 | 0.0005 | 0.0001 | 0.0000 | 0.0009 | 0.0000 | 0.0008 | 0.0016 | 0.001 | 0.0003 |
| GR11 | 0.0003 | 0.0001 | 0.0000 | 0.0006 | 0.0000 | 0.0005 | 0.0010 | 0.001 | 0.0002 |

Atmospheric Impact Report: Sasol Secunda Facility

| Receptor | Lead (Pb) (b) | Arsenic (As) (c) | Antimony (Sb) (b) | Chromium (Cr) (d) | Cobalt (Co) (e) | Copper (Cu) (b) | Manganese (Mn) (f) | Nickel (Ni) (g) | Vanadium (V) (e) |
|--|---------------|------------------|-------------------|-------------------|-----------------|-----------------|--------------------|-----------------|------------------|
| Scenario 3 – Alternative Emission Limits – Biosludge Incinerators | | | | | | | | | |
| Langverwacht | 0.0003 | 0.0002 | 0.0001 | 0.0006 | 0.0000 | 0.0023 | 0.0006 | 0.0006 | 0.0006 |
| Secunda Club | 0.0001 | 0.0001 | 0.0000 | 0.0003 | 0.0000 | 0.0010 | 0.0003 | 0.0003 | 0.0003 |
| GR4 | 0.0003 | 0.0002 | 0.0001 | 0.0006 | 0.0000 | 0.0023 | 0.0006 | 0.0006 | 0.0006 |
| GR7 | 0.0001 | 0.0001 | 0.0000 | 0.0003 | 0.0000 | 0.0010 | 0.0003 | 0.0003 | 0.0003 |
| Bosjesspruit | 0.0002 | 0.0002 | 0.0000 | 0.0005 | 0.0000 | 0.0019 | 0.0005 | 0.0005 | 0.0005 |
| GR5 | 0.0001 | 0.0001 | 0.0000 | 0.0003 | 0.0000 | 0.0012 | 0.0003 | 0.0003 | 0.0003 |
| GR8 | 0.0001 | 0.0001 | 0.0000 | 0.0002 | 0.0000 | 0.0009 | 0.0002 | 0.0002 | 0.0002 |
| GR3 | 0.0001 | 0.0001 | 0.0000 | 0.0003 | 0.0000 | 0.0010 | 0.0003 | 0.0003 | 0.0003 |
| GR6 | 0.0001 | 0.0001 | 0.0000 | 0.0003 | 0.0000 | 0.0010 | 0.0002 | 0.0002 | 0.0002 |
| GR9 | 0.0001 | 0.0001 | 0.0000 | 0.0001 | 0.0000 | 0.0005 | 0.0001 | 0.0001 | 0.0001 |
| GR10 | 0.0001 | 0.0001 | 0.0000 | 0.0001 | 0.0000 | 0.0005 | 0.0001 | 0.0001 | 0.0001 |
| GR2 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0003 | 0.0001 | 0.0001 | 0.0001 |
| GR12 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0000 | 0.0000 |
| GR1 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0004 | 0.0001 | 0.0001 | 0.0001 |
| GR11 | 0.0000 | 0.0000 | 0.0000 | 0.0001 | 0.0000 | 0.0002 | 0.0001 | 0.0001 | 0.0001 |
| (a) exceedances of strictest health screening level highlighted (b) no annual health screening level (c) Californian OEHHA ($\mu\text{g}/\text{m}^3$) – chronic screening level of $0.015 \mu\text{g}/\text{m}^3$ (d) US-EPA IRIS inhalation reference concentration – chronic ($0.1 \mu\text{g}/\text{m}^3$) (e) US ATSDR Maximum Risk Levels (MRLs) ($\mu\text{g}/\text{m}^3$) – chronic MRL of $0.1 \mu\text{g}/\text{m}^3$ (f) US-EPA IRIS inhalation reference concentration – chronic ($0.05 \mu\text{g}/\text{m}^3$) (g) Californian OEHHA ($\mu\text{g}/\text{m}^3$) – chronic screening level of $0.014 \mu\text{g}/\text{m}^3$ | | | | | | | | | |

5.1.8.2.2 Hydrogen Sulphide (H₂S)

Dispersion modelling included assessing the ambient impact of H₂S emissions from the Synfuels Sulfur Recovery Plant. Predicted daily H₂S concentrations were compared against the WHO (2000) 24-hour health-based guideline (150 µg/m³) for Sulfur Recovery Plant Emissions (Figure 5-84); where no exceedances of the guideline were predicted. The Alternative Emission Limit proposed by Sasol is 12 500 mg/Nm³ which reflects the ceiling emission level that can be met given all current realities of normal operating conditions on the plant. The largest improvement in ambient concentrations of H₂S in relation to the airshed baseline would be under the theoretical compliance with New Plant Standards (Figure 5-85), while the largest increase to ambient H₂S across the airshed was predicted under the Alternative Emission Limit (Figure 5-84).

Isopleth plots are presented for the predicted 99th percentile daily ground-level H₂S concentrations as a result of the Baseline (Figure 5-86) and Alternative Emission Limits (Figure 5-87) from the Synfuels Sulfur Recovery Plant. The maximum predicted 99th percentile ground-level concentrations were below the WHO daily guideline and as such the level presented in both figures represents 3% of the daily guideline (4 µg/m³).




Figure 5-84: Predicted 99.9th percentile daily H₂S concentrations at identified receptors for Synfuels Sulfur Recover Plant compared against WHO (2000) guideline (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-85: Theoretical change in H₂S concentrations between scenarios and the airshed baseline at the identified receptors for the Synfuels Sulfur Recovery Plant (change calculated using Equation 1)




Figure 5-86: Predicted 99th percentile daily H₂S concentrations as a result of Baseline emissions from the Sulfur Recovery Plant




Figure 5-87: Predicted 99th percentile daily H₂S concentrations as a result of Alternative Emission Limit emissions from the Sulfur Recovery Plant

The WHO daily guideline was considered to be too high to provide meaningful assessment of ambient H₂S on the receptors and after consultation with Dr WCA van Niekerk (Infotox³), the predicted 4-hourly ambient H₂S concentrations were compared against the more conservative 135 µg/m³ health effect screening level (4-hour average) recommended by Haahtela *et al.* (1992). At this exposure level, health effects include difficulty breathing, irritation of eyes, headache and nausea.

The dispersion modelling findings show that for the baseline emissions, and Alternative Emission Limit scenarios, receptors are not likely to experience H₂S concentrations above the health-effect screening level (Figure 5-88), where the Alternative Emission Limit is likely to result in an increase in ambient H₂S concentrations relative to the airshed baseline (Figure 5-89).

Isopleth plots are presented for the predicted 99th percentile 4-hourly ground-level H₂S concentrations as a result of the Baseline (Figure 5-90) and Alternative Emission Limits (Figure 5-91) from the Synfuels Sulfur Recovery Plant. The maximum predicted 99th percentile ground-level concentrations were below the WHO daily guideline and as such the level presented in both figures represents 20% of the daily guideline (27 µg/m³).

³ Report to SASOL Document number 032-2013 Rev 1.0: Toxicological review for Hydrogen Sulphide




Figure 5-88: Predicted 99.9th percentile H₂S concentrations at identified receptors for Synfuels Sulfur Recovery Plant compared against Haahtele *et al.* (1992) guideline (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure 5-89: Theoretical change in H₂S concentrations between scenarios and the airshed baseline at the identified receptors for Sulfur Recovery Plant (change calculated using Equation 1)




Figure 5-90: Predicted 99th percentile 4-hourly H₂S concentrations as a result of Baseline emissions from the Sulfur Recovery Plant




Figure 5-91: Predicted 99th percentile 4-hourly H₂S concentrations as a result of Alternative Emission Limit emissions from the Sulfur Recovery Plant

5.1.8.2.3 Acid mist

Dispersion modelling included assessing the ambient impact of sulfur trioxide (SO₃) and sulfuric acid (H₂SO₄) emissions (collectively known as acid mist) from the Synfuels Wet Sulfuric Acid Plant. Predicted hourly acid mist concentrations (Figure 5-92) were compared against the ASTDR (1999) acceptable ambient air concentration guideline for acid mist (22.5 µg/m³). Repeating the graph with the y-axis re-scaled to show the ambient impacts of the different scenarios in relation to the ASTDR (1999) hourly guideline found no exceedances of the guideline were predicted (Figure 5-93).




Figure 5-92: Predicted hourly acid mist (SO₃ and H₂SO₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant




Figure 5-93: Predicted hourly acid mist (SO₃ and H₂SO₄) concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (in relation to the ASTDR (1999) hourly guideline) (Based on Figure 5-92 with y-axis rescaled for clarity)

Predicted annual average ambient acid mist concentrations were calculated (Figure 5-94) and repeating the graph with the axis re-scaled to show the ambient impacts of the different scenarios in relation to the OEHHA (2008) chronic REL (Figure 5-95) found no exceedances of the chronic REL were predicted.




Figure 5-94: Predicted annual acid mist (SO₃ and H₂SO₄) concentrations at identified receptors for Synfuels Wet Sulphuric Acid Plant




Figure 5-95: Predicted annual acid mist (SO₃ and H₂SO₄) concentrations at identified receptors for Synfuels Wet Sulphuric Acid Plant (in relation to the OEHHA (2008) chronic REL)

5.1.9 Uncertainty of Modelled Results

The main steps of uncertainty management are to:

- identify and understand uncertainties;
- understand whether uncertainties matter for decisions being made at the time;
- if they do matter, decide what to do about them; and,
- recommend a way forward.

Managing uncertainties attempts to eliminate the source of technical disagreements and failure to understand them often leads to a conclusion that all uncertainties need to be eliminated before project decisions can be made. The first decision about how to manage uncertainties relates to their significance given the decision being addressed. In the current context, the different parts of the investigation were grouped into similar uncertainty regimes, namely:

- dispersion model uncertainties;
- input data uncertainties;
- the methodology of validating model results; and,
- the methodology of expressing the modelled scenarios.

A comprehensive discussion on uncertainties is provided in Appendix .

As discussed in Section 5.1.5, the baseline predictions with the inclusion of estimated background concentrations performed well within the generally accepted (U.S. EPA 2005) “factor of two” accuracy of dispersion models. Unless greater general experience is gained or some further formal validation studies are conducted, it is not possible to say how much more confidence can be given to well-executed plume and puff models.

However, with the incremental differences between scenarios expressed as a ratio of the baseline concentration, the impact of model inaccuracies are essentially eliminated. As discussed in Appendix J, it is estimated that the ambient monitoring has an uncertainty of 5% with a 95% confidence interval and the emissions monitoring an uncertainty of 10% with a 95% confidence interval. Based on these uncertainties, it is estimated that the concentration ratios of the different emission scenarios have an uncertainty of -22.9% and +27.4%.

The Intergovernmental Panel on Climate Change (IPCC) produced a qualitative method for consistent communication of uncertainties in the IPCC Fifth Assessment Report. This Guidance Note has been summarised in Appendix K. On application of this guide, the results from this investigation is considered to be of “high confidence” based on a “high agreement” of the baseline predictions with observations, albeit based only on three monitoring sites, i.e. “medium evidence”.

5.2 Analysis of Emissions’ Impact on the Environment

Understanding the impact of deposition of atmospheric sulfur (S) and nitrogen (N) on South African ecosystems has been on-going since the late 1980’s (Tyson *et al.* 1988), with much of the earlier work focussing on the circulation over the sub-continent (Tyson *et al.* 1996). More recent research has focussed on quantifying S and N deposition (Galpin and Turner

1999, Zunckel *et al.* 1996, Scorgie and Kornelius 2009, Josipovic *et al.* 2010) and the subsequent impacts on ecosystems (Fey and Guy 1993, Van Tienhoven *et al.* 1995, Reid 2007, Bird 2011, Josipovic *et al.* 2011).

These studies estimating deposition of S and or N compounds to ecosystems present ranges of deposition rates where the differences are related to the distance from major industrial sources; the method of estimation (field work and/or calculation based on deposition velocities or dispersion modelling). As an indication, total S deposition over the industrialised Highveld of South Africa was modelled to range between 8 and 35 kg/ha/year with background levels of approximately 1 kg/ha/year (Scorgie and Kornelius 2009). In contrast, using ambient SO₂ concentrations and an inferential deposition model to calculate S deposition, Zunckel *et al.*(1996) estimated total S deposition of 13.9 kg/ha/year as maximum deposition rate on the Highveld. Estimates of nitrogen deposition range between 6.7 kg/ha/year (Collett *et al.* 2010) and 15 kg/ha/year (Scorgie and Kornelius 2009). Considering total acidic input from atmospheric sources, Josipovic and colleagues (2011) calculated a range of deposition rates between 15.8 and 23.2 kg/ha/year. All estimates are within the range of deposition rates for S and N as for some of the industrialised regions of Europe and North America (compared in Scorgie and Kornelius 2009, and Bird 2011) raising concern that the acidic loading of sulfur and nitrogen on the ecosystems of the Highveld – South Africa's most heavily industrialised region – could have implications for ecosystem functioning.

Establishing clear cause-effect relationships in complex ecosystem studies can be difficult, especially where the extent of visible damage is large and local emissions are low (Matzner and Murach 1995). Reasons include: time lags between stressor (high concentration of atmospheric pollutants) and visible symptomatic response of biota; interaction of natural factors (e.g. climate, soil and pests) and human activities (such as management, site history and air pollution); local ecosystem uniqueness and difficulty of extrapolating to larger scales; or, symptomatic responses that are not unique to the cause (e.g. defoliation) (Matzner and Murach 1995). The synergistic effect of pollutant cocktails can also add complexity to identifying causative pollutants (Emberson 2003).

Mobilisation of active forms of S and N into the atmosphere, and later as deposition onto ecosystems, can result in acidification of soils and freshwater systems, soil nutrient depletion, fertilization of naturally (usually nitrogen) limited systems and increased availability of metal ions (e.g. Al) disrupting ecosystem functioning (Rodhe *et al.* 1995) and changing plant and/or freshwater species diversity (Stevens *et al.* 2004). Although investigating the impact of atmospheric pollution from Sasol operations was beyond the scope of this study, some research findings suggest that grassland ecosystems of the Highveld are not yet affected by sulfur and nitrogen deposition (Reid 2007, Bird 2011); however, some areas may be approaching critical loads (Bird 2011, Josipovic *et al.* 2011).

6 COMPLAINTS

| Year | Nature of complaints | Actions taken to investigate complaints | Causes of complaints identified | Measures taken to avoid reoccurrences in instances where the plant's operations were found to be the cause |
|------|--|--|--|--|
| 2013 | <p>A total of 3 external Sasol related complaints were received during 2013. The following Sasol related complaints were received:</p> <p>3 odour complaints were received, one related to H₂S odours, one related to sulfur odours and another related to general odours.</p> | <p>Sasol operates a complaint line where any environmental complaint can be registered. The environmental standby will investigate the complaint and ensure that the necessary steps are taken to reduce and manage the impact and to reduce the time of the incident.</p> | <p>Process upsets, parked trains at Trichardt junction yard and Sasol emissions during low wind conditions</p> | <p>An investigation form is sent to the relevant BU's SHERQ manager who launches a full investigation. Measures implemented to prevent a similar incident from reoccurring need to be specified and implemented. This is tracked from the Environmental Centre</p> |
| 2012 | <p>A total of 4 external Sasol Synfuels related complaints were received during 2012.</p> <p>The following Sasol Synfuels related incidents occurred and were handled during the past financial year:</p> <p>1 complaint related to the formation of a white haze in Secunda was received during this period.</p> <p>3 odour complaints were received, mostly related to ammonia and H₂S odours in Secunda.</p> | <p>Sasol operates a complaint line where any environmental complaint can be registered. The environmental standby will investigate the complaint and ensure that the necessary steps are taken to reduce and manage the impact and to reduce the time of the incident.</p> | <p>Process upsets, meteorological conditions unfavourable to adequate dispersion</p> | <p>An investigation form is sent to the relevant BU's SHERQ manager who launches a full investigation. Measures implemented to prevent a similar incident from reoccurring need to be specified and implemented. This is tracked from the Environmental Centre</p> |

7 CURRENT OR PLANNED AIR QUALITY MANAGEMENT INTERVENTIONS

An overview of approved air quality management improvement interventions, currently implemented and scheduled over the next 5 to 10 years, is detailed in the accompanying Motivation Report (Chapter 7).

8 COMPLIANCE AND ENFORCEMENT ACTIONS

No directives or compliance notices have been issued to Sasol Synfuels, Secunda in the last five years

9 ADDITIONAL INFORMATION

Beyond the requirements stipulated in the AIR Regulations and Dispersion Modelling Regulations, the following additional information is considered useful for better understanding the impacts of Sasol's activities and the implications of the requested postponements on ambient air quality. A brief description of each of these analyses is provided below, and referenced to where in the applications the information may be found.

a) Polar plots

Polar plots have been provided in Section 5.1.6.1 of the AIR to visually demonstrate directional contribution as well as the dependence of concentrations on wind speed, in much the same way as a pollution rose does. The polar plots identify major contributing emissions sources impacting on a monitoring station and the direction of the impact. These polar plots do not replace isopleth plots, but rather provide additional information on the measured air quality in the region of the facility.

b) Peer review of dispersion model

To provide increased certainty to both the DEA and the public that the dispersion modelling approach of Airshed is accurate, valid and representative, Sasol decided to take an additional step to appoint an independent international expert, Exponent Incorporated, to peer review the modelling methodology. The peer reviewer report is included in the application material. Furthermore, the peer reviewer's findings were addressed in the manner described by Airshed Planning Professionals in their written response, included as an appendix to the peer reviewer's report. Exponent Inc. is a world-renowned expert assisting the US-EPA with compliance modelling in similar instances in the United States

c) Delta approach to assessing implications of postponements for ambient air quality

In assessing the impacts of Sasol's postponement applications on ambient air quality, a fit-for-purpose approach, as requested for by the Dispersion modelling Regulations, was taken to assess the results from the dispersion modelling, which is referred to as the "delta approach". The delta approach is premised on recognising that the difference between the current or "before additional compliance is implemented" emission scenario (i.e. the baseline scenario) and "after additional compliance is implemented" scenario (i.e. the 2020 MES compliance scenario) relates to the change in emissions from the point sources in question.

Therefore, the delta approach focuses on demonstrating the change in predicted ambient impacts of the various compliance scenarios, to guide decision makers toward better understanding the implications of the approval of postponements on air quality, and how compliance with the existing and new plant standards would impact on prevailing ambient air quality.

A detailed explanation of the scenarios modelled to highlight the delta changes in ambient air quality arising from retrofit of abatement technology is provided in Section 5.1.1.2 of the AIR. In summary, the four scenarios modelled include:

- Baseline Emissions – modelling conducted based on the current inventory and impacts
- Minimum Emissions Standards – modelling conducted based on plants theoretically complying with:
 - Existing Plant Standards, and
 - New Plant Standards

- Alternative Emission Limits – the proposed maximum emission concentrations, where applicable and different from the other three emission scenarios.

d) Toxicological review for hydrogen sulfide

Sasol has made application for postponement for certain non-criteria pollutants where NAAQS have not been set. In order to assess the ambient impacts of Sasol's emissions in these cases, benchmark limits were identified by the independent consultant that compiled the AIR, Airshed, from literature reviews of peer-reviewed studies available internationally. These non-criteria pollutants for which benchmarks were identified, include H₂S, SO₃ and various emissions from incinerators, namely lead, arsenic, antimony, chromium, cobalt, copper, manganese, nickel and vanadium. A summary of the screening levels used to assess non-criteria pollutants is provided in Section 5.1.8.2 of the AIR and in Section 6.2.5 of the motivation report for the additional postponements.

In the case of H₂S, since it is believed that Sasol is the dominant contributor to ambient concentrations, Sasol commissioned an independent toxicologist to conduct a detailed desktop study of suitable health benchmarks for use in the AIR. The toxicological review is included as Annexure C to the additional postponement application.

e) Estimating background ambient air pollutant concentrations

A background air concentration is normally defined as that concentration which would result from air emission sources outside the chosen modelling domain. This concentration can, for instance, be estimated by analysing observed air concentrations for those wind directions when it is blowing towards the sources included in the modelling domain. In other words, the observation point would be upwind from the sources being simulated by the dispersion modelling.

However, as used in the current investigation, background concentrations could also incorporate the contributions from air emission sources present in the modelling domain, but which were not included in the dispersion simulations. For example, air emissions from vehicle tailpipes can significantly contribute to the local ambient NO₂ concentrations. Although most of the sources of air emissions within the Sasol operations were included in the simulations, there remains some that were excluded, for instance fugitive emissions, but would add to the background concentration level.

Since these sources are not neatly located for easy analysis of upwind contributions, the procedure normally adopted to estimate background air concentrations could not be followed. Instead, the "background" concentration was established by comparing the predicted air concentrations with the observed air concentrations. The background concentration as used in this application therefore corresponds to the observed concentration value at a monitoring site when the simulated value at this site reached a near zero value. In other words, the observed residual air concentration was assumed to arise from other sources in the modelling domain.

With this method, the assumption is made that the model performs realistically and that the residual concentration determined this way is a good reflection of the emissions not included in the simulations. In an attempt to illustrate the model accuracy, the fractional bias was calculated for each monitoring station as described in Section 5.1.6.2. This methodology has been prescribed by the US EPA (U.S. EPA 1992) as an acceptable manner to illustrate the validity of atmospheric dispersion model. Given the good model performance, as measure by the fractional bias, it is assumed that the background concentration obtained using this methodology is reasonable estimates.

f) Ambient impacts of secondary particulates arising from Sasol emissions

As detailed in the AIR, one of the reasons for selection of the CALPUFF modelling suite is the fact this this enabled inclusion of the impact of the chemical conversion of sulphur dioxide and nitrogen oxides to secondary particulates within the dispersion model results. Thus, the predicted PM₁₀ concentrations reflected in Section 5.1.8.1.3 of the AIR include direct emissions of PM₁₀ plus secondary particulates formed from Sasol's emissions.

10 ANNEXURE A(i)

DECLARATION OF ACCURACY OF INFORMATION – APPLICANT

Name of Enterprise: Sasol Synfuels

Declaration of accuracy of information provided:

Atmospheric Impact Report in terms of section 30 of the Act.

I, Willem Frederick Oasthuizen [duly authorised], declare that the information provided in this atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality officer is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at Secunda on this 11th day of April 2014


SIGNATURE

GM (SHE)
CAPACITY OF SIGNATORY

11 ANNEXURE A(ii)

DECLARATION OF ACCURACY OF INFORMATION – APPLICANT

Name of Enterprise: SECUNDA SYNFUELS OPERATIONS

Declaration of accuracy of information provided:

Atmospheric Impact Report in terms of section 30 of the Act.

I, SIMON VAN RENSSSEN [duly authorised], declare that all additional information provided in this atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality officer is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at SECUNDA on this 16 day of SEPT 2014

A. van Renssen

SIGNATURE

VICE PRESIDENT : SAFETY, HEALTH, ENVIRONMENT.
CAPACITY OF SIGNATORY

12 ANNEXURE B(i)

DECLARATION OF INDEPENDENCE - PRACTITIONER

Name of Practitioner: _Reneé von Gruenewaldt

Name of Registration Body: South African Council for Natural Scientific Professions

Professional Registration No.: 400304/07

Declaration of independence and accuracy of information provided:

Atmospheric Impact Report in terms of section 30 of the Act.

I, Reneé von Gruenewaldt, declare that I am independent of the applicant. I have the necessary expertise to conduct the assessments required for the report and will perform the work relating the application in an objective manner, even if this results in views and findings that are not favourable to the applicant. I will disclose to the applicant and the air quality officer all material information in my possession that reasonably has or may have the potential of influencing any decision to be taken with respect to the application by the air quality officer. The information provided in this atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality officer is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at Midrand on this 31st day of March 2014



SIGNATURE

Principal Air Quality Scientist

CAPACITY OF SIGNATORY

13 ANNEXURE B(ii)

DECLARATION OF INDEPENDENCE - PRACTITIONER

Name of Practitioner: _Reneé von Gruenewaldt

Name of Registration Body: South African Council for Natural Scientific Professions

Professional Registration No.: 400304/07

Declaration of independence and accuracy of information provided:

Atmospheric Impact Report in terms of section 30 of the Act.

I, Reneé von Gruenewaldt, declare that I am independent of the applicant. I have the necessary expertise to conduct the assessments required for the report and will perform the work relating the application in an objective manner, even if this results in views and findings that are not favourable to the applicant. I will disclose to the applicant and the air quality officer all material information in my possession that reasonably has or may have the potential of influencing any decision to be taken with respect to the application by the air quality officer. The additional information provided in this atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality officer is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at Midrand on this 23rd day of September 2014



SIGNATURE

Principal Air Quality Scientist

CAPACITY OF SIGNATORY

14 REFERENCES

- Bird, T. L. 2011. *Some impacts of sulfur and nitrogen deposition on the soils and surface waters of the Highveld grasslands, South Africa*. dissertation, School of Animal, Plant and Environmental Sciences, Faculty of Science, University of the Witwatersrand, Johannesburg.
- Carslaw, D.C. and Ropkins, K. (2012). openair — an R package for air quality data analysis. *Environmental Modelling and Software*. Volume 27-28, p52-61.
- Carslaw, D.C. (2013). *The openair manual — open-source tools for analysing air pollution data*. Manual for version 0.8-0, King's College London.
- CERC. (2004). *ADMS Urban Training. Version 2. Unit A*.
- Collett, K. S., Piketh, S.J. and Ross, K.E. 2010. An assessment of the atmospheric nitrogen budget on the South African Highveld. *South African Journal of Science* 106 (5/6): 9 pages.
- Dudhia J, Gill D, Guo Y, et al., 1999. *PSU/NCAR Mesoscale Modelling System Tutorial Class notes and User's Guide*, MM5 Modelling System Version 2.
- Emberson, L. 2003. "Air pollution impacts on crops and forests: An introduction." In *Air pollution impacts on crops and forests*, edited by Lisa Emberson, M. R. Ashmore and F. Murray, 3. London: Imperial College Press.
- Fey, M. V., and Guy, S.A. 1993. The capacity of soils in the Vaal Dam Catchment to retain sulphate from atmospheric pollution. In *Water Research Commission Report*. Pretoria: Water Research Commission.
- Galpin, J. S., and Turner, C.R. 1999. "Trends in composition of rain quality data from the South African interior." *South African Journal of Science* no. 95 (5):225-228.
- Haahtela T, Marttila O, Vilka V, Jäppinen P and Jaakkola J J K, 1992. The South Karelia air pollution study: acute health effects of malodorous sulfur air pollutants released by a pulp mill. *American Journal of Public Health*, 82(4):603-605.
- Josipovic, Miroslav, Harold J. Annegarn, Melanie A. Kneen, Jacobus J. Pienaar, and Stuart J. Piketh. 2011. Atmospheric dry and wet deposition of sulfur and nitrogen species and assessment of critical loads of acidic deposition exceedance in South Africa. *South African Journal of Science* 107 (3/4): 10, <http://www.sajs.co.za/index.php/SAJS/article/view/478/602>.
- Josipovic, Miroslav, Harold Annegarn, Melanie Kneen, Jacobus Pienaar, and Stuart Piketh. 2010. "Concentrations, distributions and critical level exceedance assessment of SO₂, NO₂ and O₃ in South Africa." *Environmental monitoring and assessment* no. 171 (1):181196. doi: 10.1007/s10661-009-1270-5.
- MCERTS (2011). Manual stack emission monitoring Performance standard for organisations Environment Agency, Version 7.2
- Matzner, E., and D. Murach. 1995. "Soil changes induced by air pollutant deposition and their implication for forests in central Europe." *Water, Air, & Soil Pollution* no. 85 (1):63-76.

Reid, J. L. 2007. *Investigating the long-term effects of air pollution on soil properties in the vicinity of the Arnot power station*. Master of Science, School of Animal Plant and Environmental Sciences University of the Witwatersrand, Johannesburg.

Rodhe, H., P. Grennfelt, J. Wisniewski, C. Agren, G. Bengtsson, K. Johansson, P. Kauppi, Kucera V, L. Rasmussen, B. Rasseland, L. Scholte, and G. Sellden. 1995. "Acid Reign '95? - Conference Summary Statement." *Water, Air and Soil Pollution* no. 85 (1):1-14.

Scire, J.S., D.G. Strimaitis, and R.J. Yamartino (2000a). A User's Guide for the CALPUFF Dispersion Model (Version 5), Earth Tech, Inc. Report, Concord, MA, January 2000.

Scire, J.S., F.R. Robe, M.E. Fernau, and R.J. Yamartino (2000b). A User's Guide for the CALMET Dispersion Model (Version 5), Earth Tech, Inc. Report, Concord, MA, January 2000.

Scire, J. and Borissova M (2011). *An Empirical Method for Modeling Short-Term and Annual NO₂ Concentrations in Regulatory Models*, TRC Energy & Environment Conference (EUPEC), Phoenix, Arizona.

Scorgie, Y., and G. Kornelius. 2009. Investigation into the effects of atmospheric pollutants on the soil-water-ecosystem continuum. Phase 0 - concept design. Atmospheric work - literature review and modelling of acid deposition over the Highveld. Airshed Planning Professionals.

Seinfeld, J.H. and S. N. Pandis, 1998: *Atmospheric Chemistry and Physics*. John Wiley & Sons, New York.

Stevens, Carly J., Nancy B. Dise, J. Owen Mountford, and David J. Gowing. 2004. "Impact of nitrogen deposition on the species richness of grasslands." *Science* no. 303 (5665):1876-1879. doi: 10.1126/science.1094678.

Tiwary, A., and Colls, J. (2010). *Air pollution: measurement, monitoring and mitigation* (3rd Edition ed.). Oxon: Routledge.

Tyson, P. D., M. Garstang, and R. Swap. 1996. "Large-scale recirculation of air over Southern Africa." *Journal of Applied Meteorology* no. 35:2218-2236.

Tyson, P. D., F. J. Kruger, and C. W. Louw. 1988. Atmospheric pollution and its implications in the Eastern Transvaal Highveld. In *South African National Scientific Programmes*. Pretoria, South Africa: CSIR, South African National Scientific Programmes.

U.S. EPA (1992). *Protocol for Determining the Best Performing Model*. U.S. Environmental Protection Agency. Research Triangle Park, 2 NC. EPA-454/R-92-025.

US EPA (1998). Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long-Range Transport Impacts, U.S. Environmental Protection Agency EPA-454/R-98-019, Research Triangle Park, NC.

US EPA (2005). Revision to the Guideline on Air Quality Models: Adoption of a Preferred General Purpose (Flat and Complex Terrain) Dispersion Model and Other Revisions. North Carolina, U.S. Environmental Protection Agency, 2005. Federal Register / Vol. 70, No. 216 / Rules and Regulations. Appendix W of 40 CFR Part 51.

Van Tienhoven, A. M., K. A. Olbrich, R. Skoroszewski, J. Taljaard, and M. Zunckel. 1995. "Application of the critical loads approach in South Africa." *Water, Air and Soil Pollution* no. 85:2577-2582.

WHO. 2000. Air Quality Guidelines for Europe, Second Edition. World Health Organization. Regional Office for Europe, Copenhagen. WHO Regional Publications, European Series, No.91. http://www.euro.who.int/data/assets/pdf_file/0005/74732/E71922.pdf.

Zunckel, M., C. R. Turner, and R.B. Wells. 1996. "Dry deposition of sulfur on the Mpumalanga highveld: a pilot study using the interential method." *South African Journal of Science* no. 92 (October):485-491.

APPENDIX A: COMPETENCIES FOR PERFORMING AIR DISPERSION MODELLING

All modelling tasks were performed by competent personnel. Table A-1 is a summary of competency requirements. Apart from the necessary technical skills required for the calculations, personnel competency also include the correct attitude, behaviour, motive and other personal characteristic that are essential to perform the assigned job on time and with the required diligence as deemed necessary for the successful completion of the project.

The project team included two principal engineers, both with relevant experience of more than 25 years each and one principal scientist with 12 years relevant experience. One of the principal scientists managed and directed the project.

Verification of modelling results was also conducted by one of the principal engineers. The latter function requires a thorough knowledge of the

- meteorological parameters that influence the atmospheric dispersion processes and
- atmospheric chemical transformations that some pollutants may undergo during the dispersion process.

In addition, the project team included one senior and one junior staff member.

Table A-1: Competencies for Performing Air Dispersion Modelling

| Competency | Task, Knowledge and Experience |
|------------|---|
| Context | Communication with field workers, technicians, laboratories, engineers and scientists and project managers during the process is important to the success of the model |
| | Familiar with terminology, principles and interactions |
| | Record keeping is important to support the accountability of the model - Understanding of data collection methods and technologies |
| Knowledge | Meteorology: <ul style="list-style-type: none"> • Obtain, review and interpret meteorological data • Understanding of meteorological impacts on pollutants • Ability to identify and describe soil, water, drainage and terrain conditions <ul style="list-style-type: none"> ○ Understanding of their interaction ○ Familiarity with surface roughness • Ability to identify good and bad data points/sets • Understanding of how to deal with incomplete/missing meteorological data |
| | Atmospheric Dispersion models <ul style="list-style-type: none"> • Select appropriate dispersion model • Prepare and execute dispersion model • Understanding of model input parameters • Interpret results of model |
| | Chemical and physical interactions of atmospheric pollutants <ul style="list-style-type: none"> • Familiarity with fate and transport of pollutants in air • Interaction of primary pollutants with other substances (natural or industrial) to form secondary pollutants |
| | Information relevant to the model <ul style="list-style-type: none"> • Identify potential pollution (emission) sources and rates • Gather physical information on sources such as location, stack height and diameter • Gather operating information on sources such as mass flow rates, stack top temperature, velocity or volumetric flow rate • Calculate emission rates based on collected information • Identify land use (urban/rural) • Identify land cover/terrain characteristics • Identify the receptor grid/site |
| | Legislation, regulations and guidelines in regards to National Environment Management: Air Quality Act (Act No 39 of 2004), including <ul style="list-style-type: none"> • Minimum Emissions Standards (Section 21 of Act) • National Ambient Air Quality Standards |

| Competency | Task, Knowledge and Experience |
|------------|---|
| | <ul style="list-style-type: none"> • Regulations Regarding Air Dispersion Modelling • Atmospheric Impact Report (AIR) |
| Abilities | Ability to read and understand map information |
| | Ability to prepare reports and documents as necessary |
| | Ability to review reports to ensure accuracy, clarity and completeness |
| | Communication skills |
| | Team skills |

APPENDIX B: COMPARISON OF STUDY APPROACH WITH THE REGULATIONS PRESCRIBING THE FORMAT OF THE ATMOSPHERIC IMPACT REPORT AND THE REGULATIONS REGARDING AIR DISPERSION MODELLING (GAZETTE NO 37804 PUBLISHED 11 JULY 2014)

The Regulations prescribing the format of the Atmospheric Impact Report (AIR) (Government Gazette No 36094; published 11 October 2013) were referenced for the air dispersion modelling approach used in this study. Table B-1 compares the AIR Regulations with the approach used in Section 5.

The draft regulations regarding Air Dispersion Modelling (Gazette No 35981 published 14 December 2012) were referenced for the air dispersion modelling approach used in this study. The promulgated Regulations regarding Air Dispersion Modelling (Gazette No. 37804, vol 589; 11 July 2014) were consulted to ensure that the dispersion modelling process used in this assessment was in agreement with the updated regulations. Table B-2 compares the Regulations Regarding Air Dispersion Modelling with the approach used in Section 5. The only updates applied, following stakeholder comment, was to the receptors to include schools and clinics, as indicated on the isopleth plots in Section 5.1.8.

Table B-1: Comparison of Regulations for the AIR with study approach

| Chapter | Name | AIR regulations requirement | Status in AIR (April 2014) | Status in AIR (updated in response to stakeholder comment) |
|---------|-----------------------|---|---|--|
| 1 | Enterprise details | <ul style="list-style-type: none"> Enterprise Details Location and Extent of the Plant Atmospheric Emission License and other Authorisations | Enterprise details included. Location of plant included. AEL numbers included. | (unchanged) |
| 2 | Nature of process | <ul style="list-style-type: none"> Listed Activities Process Description Unit Processes | All detail included in the regulated format | Updated to include all sources at the Synfuel Complex operations (Section 2). |
| 3 | Technical Information | <ul style="list-style-type: none"> Raw Materials Used and Production Rates Appliances and Abatement Equipment Control Technology | All raw material information included. Information on abatement equipment is confined to the listed activities seeking postponement | Updated to include all raw materials information that is not confidential and proprietary information. Sensitive information will be made available to the Licensing Authorities upon request (Section 3.1 and 3.2). |
| 4 | Atmospheric Emissions | <ul style="list-style-type: none"> Point Source Emissions <ul style="list-style-type: none"> Point Source Parameters Point Source Maximum Emission Rates during Normal Operating Conditions Point Source Maximum Emission Rates during Start-up, Maintenance and/or Shut-down Fugitive Emissions Emergency Incidents | There is no information available regarding the maximum rates available, because these are not measured, and are impractical to measure; therefore only emissions rates during normal operating conditions are available. Information regarding fugitive sources has not been included, as the modelling only considers the sources for which Sasol are requesting postponements. Information regarding emergency incidents was not included as the applications deal with normal operating conditions. | <ul style="list-style-type: none"> Point Source Parameters and Emissions for MES compliant point sources have been included (Appendix C-1 of the AIR). Emissions released during start-up, maintenance and/or Shut-down have been discussed (Section 4.3). Management of fugitive emissions across the Synfuels complex has been described (Section 4.4) and dust fall out reported for seven sites between May 2012 and April 2013. The history of Emergency Incidents during the period of assessment and planned management of future Emergency Incidents has been described (Section 4.5). |

| Chapter | Name | AIR regulations requirement | Status in AIR (April 2014) | Status in AIR (updated in response to stakeholder comment) |
|---------|---|--|--|--|
| 5 | Impact of enterprise on receiving environment | | | |
| 5.1 | Analysis of emissions impact on human health | Must conduct dispersion modelling, must be done in accordance with Regulations; must use NAAQS | Completed as set out by the Regulations. For VOC's the total measured values were used in the analysis and not the modelling of only sources applying for postponement. | <ul style="list-style-type: none"> Section 5.1.1.1 updated to include revision of AIR in response to stakeholder comments Section 5.1.1.2 updated to clarify the emission scenario modelled and how to interpret the bar chart figures in the results Section 5.1.2 updated to include appropriate cross-references. Section 5.1.3 updated to reflect the promulgated Regulations regarding Air Dispersion Modelling (also applicable throughout document) Section 5.1.8 receptor map to include schools and clinics as well as indicate distance away from the major point sources The description of the process to identify sensitive receptors (Section 5.1.8) has been updated for clarity. Section 5.1.8 updated with isopleth plots that show: schools and clinics in the modelling domain; multiple predicted pollutant concentration levels; the point of maximum predicted concentration; and, a more detailed legend to assist interpretation of the plots. Section 5.1.8.2 updated to include a table of the most stringent health-effect screening levels against which predicted non-criteria pollutant concentrations were assessed. |
| 5.2 | Analysis of emissions impact on environment | Must be undertaken at discretion of Air Quality Officer. | Literature review included in AIR, further information also provided in the motivation reports | (unchanged) |
| 6 | Complaints | Details on complaints received for last two years | Included | (unchanged) |
| 7 | Current or planned air quality management interventions | Interventions currently being implemented and scheduled and approved for next 5 years. | Information on air quality interventions are included in detail in the motivation reports | Update to correct the chapter reference in the, supporting, Motivation report and the time period for planned interventions. |
| 8 | Compliance and enforcement history | Must set out all air quality compliance and enforcement actions undertaken against the enterprise in the last 5 years. Includes directives, compliance notices, interdicts, prosecution, fines | Included | (unchanged) |
| 9 | Additional | | Included polar plots as an | Updated with list and explanation |

| Chapter | Name | AIR regulations requirement | Status in AIR (April 2014) | Status in AIR (updated in response to stakeholder comment) |
|---------|-------------|-----------------------------|---|--|
| | information | | additional visualisation means of ambient air quality as monitored. Independent peer review of dispersion modelling methodology by international expert consultant. | of information included in, or annexed to, the AIR beyond the requirements, in order to support the decision-making process. |

Table B-2: Comparison of Regulations regarding Air Dispersion Modelling with study approach

| AIR Regulations | Compliance with Regulations | Comment |
|--|----------------------------------|--|
| <p>Levels of assessment</p> <ul style="list-style-type: none"> Level 1: where worst-case air quality impacts are assessed using simpler screening models Level 2: for assessment of air quality impacts as part of license application or amendment processes, where impacts are the greatest within a few kilometers downwind (less than 50km) Level 3: requires more sophisticated dispersion models (and corresponding input data, resources and model operator expertise) in situations: <ul style="list-style-type: none"> where a detailed understanding of air quality impacts, in time and space, is required; where it is important to account for causality effects, calms, non-linear plume trajectories, spatial variations in turbulent mixing, multiple source types, and chemical transformations; when conducting permitting and/or environmental assessment process for large industrial developments that have considerable social, economic and environmental consequences; when evaluating air quality management approaches involving multi-source, multi-sector contributions from permitted and non-permitted sources in an airshed; or, when assessing contaminants resulting from non-linear processes (e.g. deposition, ground-level ozone (O₃), particulate formation, visibility) | Level 3 assessment using CALPUFF | <p>This Lagrangian Gaussian Puff model is well suited to simulate low or calm wind speed conditions. Alternative regulatory models such as the US EPA AERMOD model treats all plumes as straight-line trajectories, which under calm wind conditions grossly over-estimates the plume travel distance.</p> <p>CALPUFF is able to perform chemical transformations. In this study the conversion of NO to NO₂ and the secondary formation of particulate matter were concerns.</p> |
| <p>Model Input</p> <p>Source characterisation</p> <p>Emission rates: For new or modified existing sources the maximum allowed amount, volume, emission rates and concentration of pollutants that may be discharged to the atmosphere should be used</p> | <p>Yes</p> <p>Yes</p> | <p>Only Point sources, characterised as per the Draft Regulations in Table 5-21</p> <p>Baseline emission rates used in this investigation were based on an hourly average mass flow and concentration. The maximum allowable emission rates were used in the scenarios for 2015 and 2020 standards.</p> <p>The emission rates for the Alternative Emission Standards (i.e. the emission reductions as proposed by Sasol), used maximum emission rates</p> <p>Emission rates used for each scenario are provided in Table 5-22.</p> |

| AIR Regulations | Compliance with Regulations | Comment |
|---|--|---|
| <p>Meteorological data</p> <p>Full meteorological conditions are recommended for regulatory applications.</p> <p>Data period</p> <p>Geographical Information</p> <p>Topography and land-use</p> | <p>Yes</p> <p>Yes</p> | <p>MM5 modelled meteorology (including upper air) corrected with on-site observed meteorology (surface meteorology) (Sections 5.1.4.6.1 and 5.1.5).</p> <p>3 years (2010 to 2012)</p> <p>Required for CALMET 3D meteorological file preparation (Section 5.1.4.6.2)</p> |
| <p>Domain and co-ordinate system</p> | <p>Yes</p> | <ul style="list-style-type: none"> • Dispersion modelling domain: 50 x 50 km centred around Steam Station stacks • Flat terrain • UTM co-ordinate system (WGS84) (Section 5.1.4.6.4) |
| <p>General Modelling Considerations</p> <p>Ambient Background Concentrations, including estimating background concentrations in multi-source areas</p> <p>NAAQS analyses for new or modified sources: impact of source modification in terms of ground-level concentrations should be assessed within the context of the background concentrations and the</p> <p>Land-use classification</p> <p>Surface roughness</p> <p>Albedo</p> <p>Temporal and spatial resolution</p> <p>Receptors and spatial resolutions</p> <p>Building downwash</p> <p>Chemical transformations</p> | <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>No</p> <p>Yes</p> | <p>Section 5.1.5.4, Section 5.1.6.1, and Appendix G</p> <p>Model predicted, 99th percentile ground-level concentrations compared against current observed concentrations and assessed for contribution to ambient concentrations. Used as an indication of how modifications to the plant will impact ambient concentrations.</p> <p>Section 5.1.4.6.2</p> <p>Computed from Land-use categories in the CALMET pre-processing step (Section 5.1.4.6.2).</p> <p>Computed from Land-use categories in the CALMET pre-processing step (Section 5.1.4.6.2).</p> <p>Sections 5.1.4.6.4 and 5.1.8</p> <p>Based on screening of nearby buildings and due to the height of release from the largest pollutant emitting sources (Steam Stations), it is unlikely that building downwash would significantly influence the plume.</p> <p>Sections 5.1.4.3, Section 5.1.4.4, Section 5.1.4.5 and Appendix F.</p> |
| <p>General Reporting Requirements</p> <p>Model accuracy and uncertainty</p> <p>Plan of study</p> <p>Air Dispersion Modelling Study Reporting Requirements</p> | <p>Yes</p> <p>Yes</p> <p>Yes</p> | <p>Section 5.1.6, Section 5.1.9, and Appendix J</p> <p>Section 5.1.1.1</p> <p>As per the Regulations Prescribing the Format of the Atmospheric Impact Report, Government Gazette No. 36904, Notice Number 747 of 2013 (11 October 2013) and as per the draft Regulations</p> |

| AIR Regulations | Compliance with Regulations | Comment |
|-----------------------------|-----------------------------|---|
| Plotted dispersion contours | Yes | Regarding Air Dispersion Modelling (Government Gazette No. 35981 Notice 1035 of 2012, 14 December 2012). Section 5.1.8. |

APPENDIX C: RAW MATERIALS, ABATEMENT EQUIPMENT AND ATMOSPHERIC EMISSIONS AT SASOL SECUNDA

C1: Raw Materials

Table C1-1: Raw materials used at Sasol Secunda

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|--|---|--|
| Utilities | | |
| <i>Boilers</i> | | |
| Coal | 84 | tonnes/h per boiler |
| Boiler feed water | 610 | tonnes/h per boiler |
| Fuel oil | 48 | m ³ /cold start up |
| Tar sludge East | 0.066 | tonnes/h per boiler |
| Tar sludge West | 0.37 | tonnes/h per boiler |
| Ammonia | 90 (East) and 40 (West) | kg/precipitator/h (90%NH ₃ East and 99% NH ₃ West) |
| Air (total) | 540 | kNm ³ /h per boiler |
| Low pressure (LP) steam (400kPag) | 34 | tonnes/h per boiler |
| <i>Gas Turbines</i> | | |
| Natural Gas or Methane Rich Gas (MRG) | 11 190 | kJ/kWh (per gas turbine) |
| | 27756 | kg/h per gas turbine |
| Boiler feed water (condensate) | 155.9 | tonnes/h per HRSG |
| Low pressure (LP) steam (400kPag @ 174°C) | 21.25 | tonnes/h per boiler (de-aerator) |
| Gas Production | | |
| <i>Coal Processing</i> | | |
| Run-of-mine coal | 60 000 | tonnes/day (per unit) |
| <i>Gasification and Raw Gas Cooling</i> | | |
| Coarse coal | 1700 | tonnes/day (per unit) |
| 98.6* vol% pure oxygen | 370 | kNm ³ /h |
| HP superheated steam | 1550 | tonnes/h |
| <i>Rectisol</i> | | |
| Raw Gas | 2430 | kNm ³ /h per unit |
| Gas Circuit | | |
| <i>Benfield</i> | | |
| Tail Gas into Benfield | 405 | kNm ³ /h |
| Potassium carbonate recirculation rate | 2100 | m ³ /h |
| Carbonate system steam consumption | 135 | tonnes/h |
| DEA solution recirculation rate | 270 | m ³ /h |
| DEA system steam consumption | 35 | tonnes/h |
| <i>Catalyst Manufacturing & Catalyst Reduction</i> | | |
| IP sensitivities | | |
| Refining | | |
| <i>Tar Distillation (Unit 14 / 214)</i> | | |
| Crude Tar/ Depitched Tar (all 4 trains combined) | 88 | m ³ /h |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|---|---|-------------------------|
| <u>Unit 27A</u> | | |
| HNO-DTA | 11.5 | m ³ /h |
| <u>Unit 74</u> | | |
| Phenolic pitch | 5.2 | m ³ /h |
| <u>Coal Tar Naphtha Hydrogenation (Unit 15 / 215)</u> | | |
| Rectisol, Light and Heavy (containing coker naphtha and raffinate from Merisol) naphtha | 21 (East) | m ³ /h |
| | 24 (West) | |
| | (Rectisol naphtha not less than 40% of the feed) | |
| Naphtha (containing coker naphtha and raffinate from Merisol) from Tar Distillation | Depends on the naphtha tank levels | m ³ /h |
| Naphtha from Tar Distillation | Depends on the naphtha tank levels | m ³ /h |
| <u>Creosote Hydrogenation (Unit 228)</u> | | |
| Creosote from Tar Distillation including coker gas oil | 45 | m ³ /h |
| | (Coker gas oil not to be more than 22% of the feed) | |
| <u>Naphtha Hydrotreater, Platformer and CCR (Unit 30/230, 31/231)</u> | | |
| NHT hydrotreater | 110 (East) | m ³ /h |
| | 105 (West) | |
| Platformer | 85 at 95 RON | m ³ /h |
| CCR | 140 | |
| <u>Catalytic Distillation Hydrotreater (Unit 78)</u> | | |
| C5/C6 Hydrocarbons (From Co-monomers) | 127 | m ³ /h |
| C5 Hydrocarbons from U229/29 | 95 | m ³ /h |
| C6/C7 Hydrocarbons | 21 | m ³ /h |
| <u>CD Tame (Unit 79)</u> | | |
| C5/C6 Hydrocarbons from Co-monomers | 76 | m ³ /h |
| Methanol | 18 | m ³ /h |
| <u>C5 Isomerisation (Unit 90)</u> | | |
| C5 Hydrocarbons from Co-monomers | 90 | m ³ /h |
| <u>Vacuum Distillation (Unit 34 / 234)</u> | | |
| Decanted Oil | 52 | m ³ /h |
| <u>Distillate Hydrotreater (Unit 35 / 235)</u> | | |
| DHT feed from U29/229/34/234 | 107 (West) | m ³ /h |
| | 85 (East) | |
| <u>Distillate Selective Cracker (Unit 35DSC)</u> | | |
| DHT distillate feed from U35 / 235 | 18 | m ³ /h |
| <u>Light Oil Fractionation (Unit 29 / 229)</u> | | |
| Synthol light oil | 255 (West) | m ³ /h |
| | 190 (East) | |
| <u>Catalytic polymerisation and LPG recovery (Unit 32 / 232)</u> | | |
| Condensates | 168 (West) (7 Reactors on line) | m ³ /h |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|--|---|--|
| | 168 (East) (7 Reactors on line) | |
| <u>Polymer Hydrotreater (Unit 33 / 233)</u> | | |
| Unhydrogenated petrol / diesel feed from unit 32/232 | 100 | m ³ /h |
| <u>Total Refinery West</u> | | |
| Hydrogen | 36 800 | Nm ³ /h |
| <u>Total Refinery East</u> | | |
| Hydrogen | 67 200 | Nm ³ /h |
| <u>Sasol Catalytic Converter</u> | | |
| Fresh C6/C7 Feed | 94.5 | tonnes/h |
| C2 Rich Gas | 16 | tonnes/h |
| U24 Cracked Gas | 16 | tonnes/h |
| FT Feed to VL7001 | 70 | tonnes/h |
| Rerun Gasoline | 10 | tonnes/h |
| 99% Hydrogen to reactor | 0.52 | tonnes/h |
| Hydrogen to CD Hydro Columns | 3000 | Nm ³ /h |
| PPU3 Vent Gas | 3.5 | tonnes/h |
| PP2 Carrier Gas | 5 | tonnes/h |
| HVGO | 7 | m ³ /h |
| Caustic | 3 | tonnes/h |
| Tar, Phenosolvan and sulfur | | |
| <u>Gas Liquor Separation</u> | | |
| Dusty Gas Liquor | 906 000 | kg/h per factory |
| Tarry Gas Liquor | 352 000 | kg/h per factory |
| Oily Gas Liquor | 726 000 | kg/h per factory |
| Trim and Final Cooler Return | 234 000 | kg/h per factory |
| Rectisol Return | 4 600 | kg/h per factory |
| <u>Phenosolvan</u> | | |
| Gas Liquor | 1760 | m ³ /h per factory |
| <u>Sulfur Recovery</u> | | |
| Offgas from Rectisol & Phenosolvan | 200 | kNm ³ /h per absorber (8 absorbers) |
| Caustic soda | 12 | m ³ /day per phase |
| SAV | 8 | tonnes/week (only when required) |
| ADA | 8 | tonnes/week (only when required) |
| NaSCN | 40 | tonnes/day (only when required) |
| <u>Wet Sulfuric Acid</u> | | |
| Off gas from Rectisol & Phenosolvan | 55 | kNm ³ /h |
| Potable water (Rand Water) | 125 | m ³ /h supply to Proxa |
| Ammonia | 15 | Nm ³ /h |
| <u>Carbo Tar and Coal Tar Filtration</u> | | |
| Unit 039 MTP | 51 | m ³ /h |
| Unit 039 Waxy Oil | 43 | m ³ /h |
| Unit 039 FCC Slurry | 45 | m ³ /h |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|--|---|-----------------------------|
| Unit 075 Green coke | 112000 | tonnes/year |
| Unit 075 Green coke Hybrid | 17000 | tonnes/year |
| Unit 076 Green Coke | 60000 | tonnes/year |
| Unit 096 Coal Tar | 1327 | m ³ /day |
| Unit 096 Oil | 484 | m ³ /day |
| Unit 086 Waxy Oil Train 1 API Oil | 18 | m ³ /h per train |
| Unit 086 Train 1 Waxy Oil API Oil | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Dam Tar | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Raw Tar | 18 | m ³ /h per train |
| Unit 086 Tar Train 2 Tank Sludge's | 18 | m ³ /h per train |
| Unit 086 OBF Waxy Oil 12 | 18 | m ³ /h per train |
| Unit 086 OBF HFO 150 | 18 | m ³ /h per train |
| Water and Ash | | |
| <i>Multi hearth sludge incinerator</i> | | |
| Thickened waste activated sludge | 508 | m ³ /day |
| <i>HOW Incinerator</i> | | |
| High organic waste | 48 | m ³ /day |
| <i>Sewage Incinerator</i> | | |
| Raw sewage and Domestic waste Screenings | 440 | kg/day |
| <i>WRF TO</i> | | |
| Vent gas, Nitrogen and Air | 1578 | Nm ³ /h |
| Market and Process Integration | | |
| <i>Central Corridor Flares</i> | | |
| The flares are safety devices that need to flare gasses to protect equipment during process upset conditions | | |
| Solvents | | |
| <i>Solvents West</i> | | |
| Reaction water ex Synthol | | tonnes/h |
| Propanol plus | | tonnes/h |
| Heavy aldehydes (C3 aldehydes) | | tonnes/h |
| Ethanol 95% | | tonnes/h |
| 93 % ethanol for HPE (from EA) | | tonnes/h |
| <i>Solvents East</i> | | |
| Reaction water | | tonnes/h |
| Aldehydes ex West | | tonnes/h |
| Ethanol Effluent | | tonnes/h |
| <i>Ethyl acetate</i> | | |
| Ethanol 95 (E/A) | | tonnes/h |
| <i>Hexene</i> | | |
| Feed (C5- C7) | | tonnes/h |
| NMP | | tonnes/year |
| Methanol | | tonnes/h |
| <i>Octene</i> | | |
| Sweetened feed (total) | | tonnes/h |
| Ethanol | | m ³ /year |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|---|---|-------------------------|
| NMP | | tonnes/year |
| Potassium Carbonate | | tonnes/year |
| <u>Regenerator</u> | | |
| Potassium salt | | kg/h |
| Stripper off gases | | kg/h |
| Fuel gas | | kg/h |
| Atomising steam | | kg/h |
| <u>Safol</u> | | |
| 29VL106 Overheads | | kg/h |
| 229VL104 Sidedraw | | kg/h |
| Acetonitrile | | |
| HP Hydrogen | | kg/h |
| Pure Gas | | kg/h |
| Instrument air | | kg/h |
| <u>Octene Train 3</u> | | |
| 1-Heptene feed from Hexene and Octene 1 (acid free) | | |
| 1-Heptene feed from Octene 2 (acidic) | | |
| Syngas | | |
| Hydrogen | | |
| Polymers | | |
| <u>Polypropylene</u> | | |
| <u>PP1</u> | | |
| Propylene | | tonnes/year |
| Ethylene | | tonnes/year |
| Hydrogen | | tonnes/year |
| Nitrogen | | tonnes/year |
| Heptane | | tonnes/year |
| Catalyst | | tonnes/year |
| Co- catalyst | | tonnes/year |
| Silane | | tonnes/year |
| Iso propanol | | tonnes/year |
| 1-Pentene | | tonnes/year |
| <u>PP2</u> | | |
| Propylene | | tonnes/year |
| Ethylene | | tonnes/year |
| Hydrogen | | tonnes/year |
| Gas bleed from reactors and propylene recovery unit | | kg/h |
| 20 Caustic solution | | kg – once per year |
| <u>Monomers</u> | | |
| <u>Monomers West</u> | | |
| C ₂ Rich Gas (from Syngas) | | tonnes/h |
| 60% C ₂ H ₄ | | tonnes/h |
| 40% C ₂ H ₆ | | tonnes/h |
| Propane | | kNm ³ /h |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|---|---|-------------------------|
| Low Pressure Gas | | m ³ /h |
| C ₃ Condensate | | m ³ /h |
| Carrier gas | | kNm ³ /h |
| Ethane from SCC | | tonnes/h |
| Ethane from U280 | | tonnes/h |
| <u>Monomers East</u> | | |
| Condensate 2 to U288 | | tonnes/year |
| Condensate 3 to U288 | | tonnes/year |
| Condensate 3 to U285 | | tonnes/year |
| C2's to U280 | | tonnes/year |
| Oil | | |
| <u>Main flares</u> | | |
| Feed gas (off-gases, off specification gases and emergency venting) | Varying as and when required for safety purposes | tonnes/h |
| | Varying as and when required for safety purposes | tonnes/h |
| <u>Ground level flares</u> | | |
| <u>First flare burner</u> | | |
| Alcohols or off spec products | Varying as and when required for safety purposes | m ³ /h |
| <u>Ammonia flares</u> | | |
| Ammonia | Varying as and when required for safety purposes | kg/h |
| Propane | Varying as and when required for safety purposes | kg/h |
| Ethane | Varying as and when required for safety purposes | kg/h |
| <u>Storage of hydrocarbons</u> | | |
| Various intermediate liquid material | Varying as and when required for safety purposes | |
| LOC | | |
| Various products in road loading (Central road loading facility) | VOC containing products loaded in quantities exceeding 50 000 m ³ /a | m ³ /year |
| Various products in rail loading (Central rail loading facility) | VOC containing products loaded in quantities less than 50 000 m ³ /a | m ³ /year |
| Nitro | | |
| <u>Fertilisers</u> | | |
| <u>Granulation Plant</u> | | |
| Ammonia | | tonnes/year |
| Ammonium nitrate | | tonnes/year |
| Ammonium sulfate | | tonnes/year |
| Limestone | | tonnes/year |
| <u>Nitric Acid Plant</u> | | |

| Raw Material Type | Maximum Permitted Consumption Rate (Volume) | Units (quantity/period) |
|--|---|-------------------------|
| Ammonia | | tonnes/day |
| Air | | Nm ³ /day |
| Water | | m ³ /day |
| <u>Ammonium Nitrate Plant</u> | | |
| Ammonia | | tonnes/year |
| Nitric Acid | | tonnes/year |
| <u>Liquid Fertilizer Plant</u> | | |
| Water | | tonnes/year |
| Ammonia | | tonnes/year |
| Potassium Chloride | | tonnes/year |
| Urea | | tonnes/year |
| Phosphoric Acid | | tonnes/year |
| Ammonium Nitrate | | tonnes/year |
| Zinc | | tonnes/year |
| <u>Ammonium Sulfate Plant</u> | | |
| Ammonia | | kg/h |
| Sulfuric Acid | | tonnes/year |
| <u>Explosives (open burning grounds)</u> | | |
| Waste | | kg/day |

Some raw materials and/or consumption rates were excluded for proprietary or competition law sensitivities

Table C1-2: All appliances and abatement equipment used on unit processes at the Sasol Secunda complex

| Appliance name | Appliance type/description | Appliance function/purpose |
|----------------------------|--------------------------------|--|
| Not available | Electrostatic Precipitators | Reduce particulate emissions |
| Not available | Stainless Steel Filters | Reduce particulate emissions |
| Venturi Scrubber | Venturi Scrubber | Reduce particulate and gaseous emissions |
| Electrostatic precipitator | Wet Electrostatic precipitator | Reduce particulate and gaseous emissions |
| Reactor | DeNOx converter | Reduce NOx emissions |
| Flares | Flares | Combust organic gasses to CO ₂ and H ₂ O |
| Bag house | Bag filters | Reduce particulate emissions |
| Cyclones | Cyclones | Reduce particulate emissions |

C2: Point Source Emissions

Table C2-3: Point source parameters

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|-------------------------------|--|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| Utilities | | | | | | | | | | | |
| B1 | West stack | 26.5575 | 29.14993 | 250 | 230 | 13.6 | 185 | 10 025 400 | 23-27 | 24 | Continuous |
| B2 | East stack | 26.56014 | 29.16841 | 301 | 281 | 14.4 | 185 | 11 278 580 | 23-27 | 24 | Continuous |
| GT1 | Gas Turbine stack | 26.564167 | 29.165 | 40 | 37 | 5.3 | 548 | 3 176 904 | 40 | 24 | Continuous |
| GT2 | Gas Turbine stack | 26.564167 | 29.164444 | 40 | 37 | 5.3 | 548 | 3 176 904 | 40 | 24 | Continuous |
| Gas Production | | | | | | | | | | | |
| Rectisol East | Off gas to main stack | 26.56014 | 29.16841 | 301 | 281 | 13.6 | 20 - 25 | 830 370 | 20-30 | 24 | Continuous |
| Rectisol West | Off gas to main stack | 26.5575 | 29.14993 | 250 | 230 | 14.4 | 20 - 25 | 830 370 | 20-30 | 24 | Continuous |
| Gas Circuit | | | | | | | | | | | |
| <i>Catalyst Manufacturing</i> | | | | | | | | | | | |
| CM1 | West Kiln Stack | 26.55496 | 29.15655 | 25 | -5 | 0.91 | 170 | 81 163 | 28.7 | 24 | Batch |
| CM2 | West Arc Furnace Stack | 26.55509 | 29.15655 | 25 | -5 | 1.6 | 35 | 190 211 | 34.3 | 24 | Batch |
| CM3 | East A Kiln Stack | 26.55735 | 29.17548 | 25 | -5 | 0.76 | 205 | 33 917 | 12 | 24 | Batch |
| CM4 | East Arc Furnace Stack | 26.55773 | 29.17531 | 25 | -5 | 1.6 | 73 | 43 720 | 5.35 | 24 | Batch |
| CM5 | East B Kiln Stack | 26.55692 | 29.17537 | 25 | -5 | 0.77 | 192 | 19 970 | 11.9 | 24 | Batch |
| Refining | | | | | | | | | | | |
| <i>Tar Distillation</i> | | | | | | | | | | | |
| R1 (14HT101) | Tar Distillation Reboiler Stack Outlet | 26.549167 | 29.183056 | 51.876 | 46.876 | 0.894 | 440 | 7 390 | 3.27 | 24 | Continuous |
| R2 (14HT201) | Tar Distillation Reboiler Stack Outlet | 26.549167 | 29.150833 | 51.876 | 46.876 | 0.894 | 440 | 7 390 | 3.27 | 24 | Continuous |

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|---|--|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| R3 (214HT101) | Tar Distillation Reboiler Stack Outlet | 26.549167 | 29.134167 | 51.876 | 46.876 | 0.894 | 440 | 7 390 | 3.27 | 24 | Continuous |
| R4 (214HT201) | Tar Distillation Reboiler Stack Outlet | 26.549167 | 29.1175 | 51.876 | 46.876 | 0.894 | 440 | 7 390 | 3.27 | 24 | Continuous |
| <i>Creosote Hydrogenation</i> | | | | | | | | | | | |
| R5 (228HT101) | Heater stack outlet | 26.919722 | 29.282778 | 41.274 | 36.274 | 0.914 | 318 | 9 220 | 3.9 | 24 | Continuous |
| <i>Naphtha Hydrotreater, Platformer and CCR</i> | | | | | | | | | | | |
| R6 (30HT101) | NHT charge heater stack outlet | 26.550278 | 29.149722 | 51.876 | 46.876 | 1.22 | 298 | 6216 | 1.48 | 24 | Continuous |
| R7 (30HT102) | Stripper Reboiler heater stack outlet | 26.550278 | 29.149722 | 38.4 | 33.4 | 0.99 | 304 | 11527 | 4.16 | 24 | Continuous |
| R8 (30HT103) | Platformer charge heater stack outlet | 26.550278 | 29.149722 | 51.7 | 46.7 | 2.362 | 177 | 37722 | 2.39 | 24 | Continuous |
| R9 (30HT104) | Debutanizer Reboiler heater stack outlet | 26.550278 | 29.149722 | 43 | 38 | 1.28 | 360 | 8313 | 1.79 | 24 | Continuous |
| R10 (30HT105) | Splitter Reboiler heater stack outlet | 26.550278 | 29.149722 | 38.4 | 33.4 | 0.99 | 313 | 6856 | 2.47 | 24 | Continuous |
| R11 (230HT101) | NHT charge heater stack outlet | 26.924167 | 29.282778 | 51.9 | 46.9 | 1.22 | 298 | 9696 | 2.3 | 24 | Continuous |
| R12 (230HT102) | Stripper reboiler stack outlet | 26.923611 | 29.282778 | 38.4 | 33.4 | 0.99 | 304 | 8576 | 3.09 | 24 | Continuous |
| R13 (230HT103) | Platformer Charge Heater stack outlet | 26.922222 | 29.283056 | 51.7 | 46.7 | 2.362 | 177 | 40816 | 2.59 | 24 | Continuous |
| R14 (230HT104) | Debutanizer reboiler stack outlet | 26.923056 | 29.283056 | 43 | 38 | 1.28 | 360 | 3312 | 0.79 | 24 | Continuous |
| R15 (230HT105) | Splitter reboiler stack outlet | 26.923611 | 29.283056 | 38.4 | 33.4 | 0.99 | 313 | 7115 | 2.57 | 24 | Continuous |
| <i>Vacuum Distillation</i> | | | | | | | | | | | |
| R17 (34HT101) | Vacuum heater stack outlet | 26.550556 | 29.150278 | 32 | 27 | 1.27 | 321 | 10727 | 2.35 | 24 | Continuous |
| R18 | Vacuum heater stack outlet | 26.924722 | 29.283056 | 32 | 27 | 1.27 | 321 | 10727 | 2.35 | 24 | Continuous |

Atmospheric Impact Report: Sasol Secunda Facility

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|-------------------------------------|--|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| (234HT101) | | | | | | | | | | | |
| <i>Distillate Hydroteater</i> | | | | | | | | | | | |
| R19 (35HT101) | Reactor Charge Heater stack outlet | 26.3825 | 29.143056 | 41.3 | 36.3 | 0.99 | 299 | 7865 | 1.916 | 24 | Continuous |
| R20 (35HT102) | Fractionator Charge Heater stack outlet | 26.3825 | 29.143056 | 44.2 | 39.2 | 1.35 | 345 | 11112 | 1.76 | 24 | Continuous |
| R22 (235HT101) | Reactor Charge Heater stack outlet | 26.921111 | 29.282778 | 41.3 | 36.3 | 1.308 | 299 | 6806 | 1.31 | 24 | Continuous |
| R23 (235HT102) | Fractionator Charge Heater stack outlet | 26.921111 | 29.282778 | 44.2 | 39.2 | 1.35 | 310 | 12641 | 2.45 | 24 | Continuous |
| <i>Distillate Selective Cracker</i> | | | | | | | | | | | |
| R24 (35HT103) | Reactor Charge Heater stack outlet | 26.3825 | 29.143056 | 31.4 | 26.4 | 0.87 | 388 | 3495 | 1.63 | 24 | Continuous |
| R25 (35HT104) | Fractionator Charge Heater stack outlet | 26.3825 | 29.143056 | 35 | 30 | 0.99 | 221 | 3135 | 1.13 | 24 | Continuous |
| R26 (35HT105) | Vacuum Charge Heater stack outlet | 26.3825 | 29.143056 | 31 | 26 | 0.684 | 340 | 3728 | 2.82 | 24 | Continuous |
| <i>Light Oil Fractionation</i> | | | | | | | | | | | |
| R27 (29HT101) | Light Oil Splitter Reboiler stack outlet | 26.550833 | 29.150556 | 48 | 43 | 1.808 | 280 | 21349 | 2.31 | 24 | Continuous |
| R28 (29HT102) | Diesel Splitter Reboiler stack outlet | 26.551389 | 29.151111 | 42.6 | 37.6 | 1.2 | 267 | 13708 | 3.37 | 24 | Continuous |
| R29 (229HT101) | Light Oil Splitter Reboiler stack outlet | 26.924722 | 29.283056 | 47.7 | 42.7 | 1.727 | 367 | 36129 | 4.28 | 24 | Continuous |
| <i>Polymer Hydrotreating</i> | | | | | | | | | | | |
| R30 (33HT101) | Stripper Reboiler stack outlet | 26.551111 | 29.149722 | 34.9 | 29.9 | 1.53 | 300 | 15260 | 8300 | 24 | Continuous |
| R31 (33HT102) | Charge Heater stack outlet | 26.550833 | 29.149722 | 38.68 | 33.68 | 1.4 | 274 | 16055 | 10429 | 24 | Continuous |
| R32 (33HT105) | Splitter Reboiler stack outlet | 26.550833 | 29.149722 | 46 | 41 | 1.37 | 320 | 26830 | 18200 | 24 | Continuous |

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|--|---|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| R33 (233HT101) | Stripper Reboiler stack outlet | 26.925556 | 29.2825 | 34.9 | 29.9 | 1.53 | 300 | 15260 | 8300 | 24 | Continuous |
| R34 (233HT102) | Charge Heater stack outlet | 26.925556 | 29.2825 | 38.68 | 33.68 | 1.4 | 274 | 16055 | 10429 | 24 | Continuous |
| R35 (233HT105) | Splitter Reboiler stack outlet | 26.925556 | 29.2825 | 46 | 41 | 1.37 | 320 | 26830 | 18200 | 24 | Continuous |
| <i>Catalytic Polymerisation and LPG recovery</i> | | | | | | | | | | | |
| R36 (32HT101) | Poly Debutanizer Reboiler stack outlet. | 26.550556 | 29.150278 | 37.2 | 32.2 | 1.24 | 267 | 16520 | 13679 | 24 | Continuous |
| R37 (32HT201) | Poly Debutanizer Reboiler stack outlet. | 26.551667 | 29.150278 | 37.2 | 32.2 | 1.24 | 226 | 15266 | 12641 | 24 | Continuous |
| R38 (32HT102) | Recycle Column Reboiler stack outlet. | 26.551667 | 29.150278 | 51.5 | 46.5 | 2.13 | 309 | 86588 | 24300 | 24 | Continuous |
| R39 (232HT101) | Poly Debutanizer Reboiler stack outlet. | 26.928056 | 29.281667 | 37.2 | 32.2 | 1.24 | 267 | 17530 | 14516 | 24 | Continuous |
| R40 (232HT201) | Poly Debutanizer Reboiler stack outlet. | 26.928056 | 29.281667 | 37.2 | 32.2 | 1.24 | 226 | 18754 | 15529 | 24 | Continuous |
| R41 (232HT102) | Recycle Column Reboiler stack outlet. | 26.928056 | 29.281667 | 51.5 | 46.5 | 2.13 | 309 | 84654 | 23757 | 24 | Continuous |
| <i>Sasol Catalytic Converter</i> | | | | | | | | | | | |
| SCC1 Stack | Main stack | 26.55599 | 29.1639 | 80 | 76 | 1.067 | 232 | 410 000 | 12.5 | 24 | Continuous |
| SCC2 (TK 1001) | Slurry Storage Tank – N ₂ blanketing | 26.55599 | 29.1639 | 11 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| SCC3 (TK 1002) | Fuel Oil Storage Tank – N ₂ blanketing | 26.55599 | 29.1639 | 11 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| SCC4 (TK 1003) | Fuel Oil Make-up Tank – N ₂ blanketing | 26.55599 | 29.1639 | 7 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| SCC5 (TK 3201) | DEA – Storage Tank – N ₂ blanketing | 26.55599 | 29.1639 | 9 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| SCC6 (TK 3202) | Slop Oil tank – N ₂ blanketing | 26.55599 | 29.1639 | 5.7 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| SCC7 (TK | Caustic Storage Tank – N ₂ | 26.55599 | 29.1639 | 5.5 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |

Atmospheric Impact Report: Sasol Secunda Facility

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|--|--|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| 3401) | blanketing | | | | | | | | | | |
| SCC8 (TK 3402) | Spent Caustic Tank – N ₂ blanketing | 26.55599 | 29.1639 | 5.5 | N/A | N/A | N/A | N/A | N/A | 24 | Intermittent |
| Tar, Phenosolvan and Sulfur: | | | | | | | | | | | |
| <i>Phenosolvan</i> | | | | | | | | | | | |
| P1 | Ammonia vent line at west stack | 26.5575 | 29.14993 | 250 | 230 | 0.6 | 33 | 30 | 0.114 | | Intermittent |
| P2 | Ammonia vent line at east stack | 26.56014 | 29.16841 | 301 | 281 | 0.6 | 31 | 30 | 0.114 | | Intermittent |
| <i>Wet Sulfuric Acid</i> | | | | | | | | | | | |
| WSA1 (518ME-1003) | Wet Sulfuric Acid stack | 26.559278 | 29.167642 | 75 | 65 | 2.75 | 41 | 206 600 | 9.73 | 24 | Continuous |
| <i>Carbo Tar and Coal Tar Filtration</i> | | | | | | | | | | | |
| FPP1 (U86 TK201) | Storage and mixing Tank | 26.54895 | 29.14649 | 18 | 12 | N/A | N/A | N/A | N/A | 24 | Batch |
| FPP2 (U86 TK202) | Storage and mixing Tank | 26.54887 | 29.14697 | 18 | 12 | N/A | N/A | N/A | N/A | 24 | Batch |
| FPP3 (U86 TK203) | Storage and mixing Tank | 26.54882 | 29.14697 | 18 | 12 | N/A | N/A | N/A | N/A | 24 | Batch |
| FPP4 (U86 TK204) | Storage and mixing Tank | 26.54876 | 29.14697 | 18 | 12 | N/A | N/A | N/A | N/A | 24 | Batch |
| FPP5 (U86 ME514) | Stack | 26.5487 | 29.14879 | 18 | 14 | 0.609 | 17.86 | 20 000 | 24 | 24 | Batch |
| CT1 (39 TK101) | Waxy Oil 30 tank | 26.54887 | 29.1483 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT 2 (39 TK102) | Waxy Oil 30 tank | 26.54896 | 29.14816 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT3 (39 TK103) | Pitch tank | 26.54899 | 29.14762 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT4 (39 TK104) | Pitch tank | 26.54887 | 29.14746 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |

Atmospheric Impact Report: Sasol Secunda Facility

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|---|---------------------------|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| CT5 (39 TK105) | Pitch tank | 26.54875 | 29.14714 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT6 (39 TK112) | FCC Slurry tank | 26.54887 | 29.14746 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT7 (39 TK 113) | FCC Slurry tank | 26.54875 | 29.14714 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT8 (39 TK 114) | FCC Slurry tank | 26.54904 | 29.1472 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT9 (39 TK 115) | FCC Slurry tank | 26.54907 | 29.14731 | 10 | 6 | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT10 (39TK 201) | Fuel Oil 10 | 26.5487 | 29.14711 | 8 | N/A | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT11 (39TK 202) | Low Sulfur Heavy Fuel Oil | 26.54877 | 29.14711 | 8 | N/A | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT12 (39TK 203) | Low Sulfur Heavy Fuel Oil | 26.54884 | 29.14709 | 8 | N/A | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT13 (39TK 204) | Heavy Tar Oil | 26.54891 | 29.14709 | 8 | N/A | N/A | N/A | N/A | N/A | 24 | Continuous |
| CT14 (39 H101) | Stack | 26.55026 | 29.14843 | 60 | 56 | 1.53 | 320 | 5.74 | 3.1 | 24 | Continuous |
| Water and Ash: | | | | | | | | | | | |
| <i>Multi Hearth Sludge Incinerators</i> | | | | | | | | | | | |
| WA1 (52WK-2102) | Stack | 26.54617 | 29.1422 | 30 | 10 | 1.2 | 80 | 41 063 | 10.08 | 24 | Continuous |
| WA2 (52WK-2202) | Stack | 26.54598 | 29.14155 | 30 | 10 | 1.2 | 80 | 41 063 | 10.08 | 24 | Continuous |
| WA3 (252WK-2102) | Stack | 26.54096 | 29.14283 | 30 | 10 | 1.2 | 80 | 40 298 | 9.89 | 24 | Continuous |
| WA4 (252WK-2202) | Stack | 26.54111 | 29.14226 | 30 | 10 | 1.2 | 80 | 40 298 | 9.89 | 24 | Continuous |

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|---------------------------|----------------------------------|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| <u>HOW Incinerators</u> | | | | | | | | | | | |
| HOW1 (052CI-101) | Chimney | 26.5481 | 29.14257 | 15 | 7 | 1.8 | 600 (max) | 74 731 | 8.15 | 24 | Continuous |
| HOW2 (252CI-101) | Chimney | 26.5432 | 29.14331 | 15 | 7 | 1.8 | 600 (max) | 60 055 | 6.55 | 24 | Continuous |
| <u>Sewage Incinerator</u> | | | | | | | | | | | |
| SW1 (353IN101) | Chimney | 26.53883 | 29.14611 | 10 | 5 | 0.8 | 231 | 4485 | 4.4 | 24 | Batch |
| <u>WRF RTO</u> | | | | | | | | | | | |
| WRF | Thermal oxidiser | 26.55089 | 29.1434 | 20 | 15 | 1.25 | 815 | 1940 | 0.44 | 24 | Continuous |
| Solvents | | | | | | | | | | | |
| 1 | Regenerator Stack (Octene) | 26.5534028 | 29.1788083 | 66 | 63 | Approx 1.2m | 88.04 | 66654 | 16.93 | | |
| 2 | Stack for heater and regenerator | 26.554425 | 29.180619 | 58 | 52 | 1 | 350 | 27000 | 9.6 | | |
| Polymers | | | | | | | | | | | |
| <u>Monomers West</u> | | | | | | | | | | | |
| 1 | Furnace A stack | 26.54283 | 29.154 | 34 | 30 | 0.7 | 300 | 43000 | 31 | | |
| 2 | Furnace B stack | 26.54283 | 29.154 | 34 | 30 | 0.7 | 300 | 43000 | 31 | | |
| 3 | Furnace C stack | 26.54283 | 29.154 | 34 | 30 | 0.7 | 300 | 43000 | 31 | | |
| 4 | Furnace D stack | 26.54283 | 29.154 | 34 | 30 | 0.7 | 300 | 43000 | 31 | | |
| 5 | Furnace E stack | 26.54283 | 29.154 | 34 | 30 | 0.7 | 300 | 43000 | 31 | | |
| LOC | | | | | | | | | | | |
| 1 | Central road loading | -29.1648 | 26.5487 | 2 -3 m | Not Applicable | Not | Fugitive emissions | | | | |
| 2 | Central road loading | 29.1608 | 26.5488 | 2 -3 m | Not Applicable | Not | Fugitive emissions | | | | |
| Nitro | | | | | | | | | | | |
| 1 | Nitric Acid Stack | 26.5918 | 29.18227 | 61 | 20.5 | 1.52 | 100 | 120 000 | 18.36 | | |

Atmospheric Impact Report: Sasol Secunda Facility

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Height Above Nearby Building (m) | Diameter at Stack Tip / Vent Exit (m) | Actual Gas Exit Temperature (°C) | Actual Gas Volumetric Flow (m³/hr) | Actual Gas Exit Velocity (m/s) | Emission Hours | Type of Emission (Continuous / Batch / Intermittent) |
|-------------------|---|----------------------------|-----------------------------|------------------------------------|----------------------------------|---------------------------------------|----------------------------------|------------------------------------|--------------------------------|----------------|--|
| 2 | Ammonium Nitrate Production Plant Stack | 26.58996 | 29.18286 | 45.3 | 38.8 | 0.8 | 76.5 | 20413 | 11.28 | | |
| 3 | Granular Fertilizer Production Plant Stack (LAN) | 26.9775 | 29.4086 | 64 | 42 | 3 | 40 | 420000 | 12.38 | | |
| 4 | Ammonium Sulfate Stack | 26.7142 | 29.4147 | 21 | | 0.91 | 22.1 | 40 401 | 17.25 | | |

Table C2-4: Tank sources for the Sasol Oil business unit

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Vapour Pressure (kPa) |
|-------------------|-------------|----------------------------|-----------------------------|------------------------------------|-----------------------|
| Oil | | | | | |
| 1 | 56 TK-1402 | | | 10.74 | 60 |
| 2 | 256 TK-9301 | | | 20.45 | 33 |
| 3 | 56TK-0107 | | | 14.25 | 45 |
| 4 | 56TK-0216 | | | 7.25 | 16 |
| 5 | 256TK-3812 | | | 7.25 | >14 |
| 6 | 256 TK 3301 | | | 14.85 | 29 |
| 7 | 56TK-3301 | | | 14.85 | 32 |
| 8 | 56TK-3721 | | | 7.25 | >14 |
| 9 | 256TK-3721 | | | 7.25 | 36 |
| 10 | 256TK-0148 | | | 11.87 | 23 |
| 11 | 256TK-3601 | | | 11.87 | 20 |
| 12 | 256TK-3602 | | | 9.6 | >14 |
| 13 | 256TK-3706 | | | 7.25 | >14 |
| 14 | 256TK-3811 | | | 7.25 | >14 |
| 15 | 256TK-3705 | | | 7.22 | >14 |
| 16 | 256TK-3851 | | | 6.4 | >14 |
| 17 | 56TK-7301 | | | 7.5 | >14 |
| 18 | 56TK-3706 | | | 7.25 | >14 |
| 19 | 56TK-7302 | | | 7.5 | >14 |
| 20 | 56TK-3601 | | | 11.89 | 40 |
| 21 | 56TK-3603 | | | 11.87 | 19 |
| 22 | 256TK-3850 | | | 6.4 | >14 |
| 23 | 56TK-3602 | | | 9.6 | 46 |
| 24 | 56TK-3201 | | | 14.63 | 105 |
| 25 | 56TK-7303 | | | 12.8 | >14 |
| 26 | 56TK-3811 | | | 7.25 | 20 |
| 27 | 56TK-3705 | | | 7.25 | >14 |
| 28 | 56TK-3812 | | | 7.25 | >14 |
| 29 | 56TK-3811 | | | 7.25 | >14 |
| 30 | 256TK-0143 | | | 11.97 | >14 |
| 31 | 256TK-3202 | | | 14.63 | 79 |
| 32 | 256TK-3201 | | | 14.63 | 80 |
| 33 | 56TK -0130 | | | 10 | <14 |
| 34 | 56TK-0143 | | | 11.97 | <14 |
| 35 | 56TK-0146 | | | 11.97 | <14 |
| 36 | 56TK-0203 | | | 11.97 | <14 |
| 37 | 56TK-3709 | | | 4.85 | <14 |
| 38 | 56TK-3710 | | | 4.85 | <14 |
| 39 | 56TK-3713 | | | 4.85 | <14 |
| 40 | 56TK-3714 | | | 4.85 | <14 |
| 41 | 56TK-3721 | | | 7.22 | <14 |
| 42 | 56TK-3835 | | | 11.97 | <14 |

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Vapour Pressure (kPa) |
|-------------------|-------------|----------------------------|-----------------------------|------------------------------------|-----------------------|
| 43 | 256TK-3713 | | | 4.85 | >14 |
| 44 | 256TK-3714 | | | 4.85 | >14 |
| 45 | 256TK-3835 | | | 11.97 | >14 |
| 46 | 256TK-1401 | | | 10.7 | 60 |
| 47 | 256TK-1402 | | | 10.7 | 60 |
| 48 | 256TK-2902 | | | 14.8 | 55 |
| 49 | 256TK-3401 | | | 11.8 | <14 |
| 50 | 256TK-3402 | | | 11.8 | <14 |
| 51 | 256TK-9302 | | | 20.4 | 33 |
| 52 | 56TK-0113 | | | 14.35 | >14 |
| 53 | 56TK-0121 | | | 9 | <14 |
| 54 | 56TK-0122 | | | 9 | <14 |
| 55 | 56TK-0214 | | | 8 | >14 |
| 56 | 56TK-1401 | | | 10.7 | <14 |
| 57 | 56TK-1601 | | | 9.6 | 35 |
| 58 | 56TK-2901 | | | 14.8 | 21 |
| 59 | 56TK-2902 | | | 14.8 | 21 |
| 60 | 56TK-3202 | | | 14.6 | 80.2 |
| 61 | 56TK-3401 | | | 11.8 | >14 |
| 62 | 56TK-3402 | | | 11.8 | <14 |
| 63 | 56TK-3901 | | | 12.8 | >14 |
| 64 | 56TK-3902 | | | 12.8 | <14 |
| 65 | 56TK-2903 | | | 26 | <14 |
| 66 | 56TK-3501 | | | 14.35 | <14 |
| 67 | 256TK-3301 | | | 14.35 | 32 |
| 68 | 256TK-3001 | | | 14.75 | <14 |
| 69 | 256TK-2811 | | | 11.12 | >14 |
| 70 | 256TK-2812 | | | 11.12 | >14 |
| 71 | 56TK-3305 | | | 9.5 | <14 |
| 72 | 256TK-3320 | | | 12.19 | >14 |
| 73 | 56TK-3321 | | | 12.17 | <14 |
| 74 | 56TK-3322 | | | 12.17 | <14 |
| 75 | 56TK-3308 | | | 9.5 | <14 |
| 76 | 56TK-3309 | | | 9.5 | <14 |
| 77 | 56TK-1508 | | | 9 | <14 |
| 78 | 256TK-1508 | | | 9 | >14 |
| 79 | 56TK-1505 | | | 8.38 | >14 |
| 80 | 256TK-1505 | | | 8 | <14 |
| 81 | 56TK-1414 | | | 7 | <14 |
| 82 | 56TK-1501 | | | 11.2 | <14 |
| 83 | 56TK-1502 | | | 11.2 | >14 |
| 84 | 256TK-1501 | | | 11.88 | >14 |
| 85 | 256TK-1502 | | | 11.88 | <14 |
| 86 | 56TK-3005 | | | 14.25 | <14 |

| Point Source code | Source name | Latitude (decimal degrees) | Longitude (decimal degrees) | Height of Release Above Ground (m) | Vapour Pressure (kPa) |
|-------------------|-------------------------------------|----------------------------|-----------------------------|------------------------------------|-----------------------|
| 87 | 56TK-3006 | | | 14.25 | <14 |
| 88 | 256TK-3005 | | | 15.66 | <14 |
| 89 | 256TK-3006 | | | 15.66 | <14 |
| 90 | 56TK-3521 | | | 9.56 | >14 |
| 91 | 256TK-2801 | | | 11.87 | <14 |
| 92 | 256TK-2901 | | | 14.85 | <14 |
| 93 | 256TK-2904 | | | 14.75 | <14 |
| 94 | 56TK-3304 | | | 20.1 | <14 |
| 95 | 256TK-3852 | | | 20.1 | <14 |
| 96 | 256TK-3002 | | | 9.6 | <14 |
| 97 | 56TK-0101 | | | 11.87 | <14 |
| 98 | 56TK-0102 | | | 11.87 | <14 |
| 99 | 56TK-0103 | | | 11.87 | <14 |
| 100 | 56TK-0105 | | | 21.44 | <14 |
| 101 | 56TK-0106 | | | 14.25 | <14 |
| 102 | 256TK-0106 | | | 11.87 | <14 |
| 103 | 256TK-0106 | | | 14.72 | <14 |
| 104 | 56TK-0106 | | | | <14 |
| 105 | 56TK-0106 | | | 12.22 | <14 |
| 106 | 56TK-0106 | | | 12.22 | <14 |
| 107 | 256TK-0106 | | | 7.25 | <14 |
| 108 | 56TK-0106 | | | 14.35 | <14 |
| 109 | 258TK-0106 | | | 11 | <14 |
| 110 | 258TK-0106 | | | 9.5 | <14 |
| 111 | Rail point 7 and 10 (to 2/56TK0216) | | | 1 | <14 |

The geographical co-ordinates have been excluded for security reasons but will be made available to the DEA under confidentiality arrangements.

Table C2-5: Point source emission rates during normal operating conditions

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|---------------------------------------|--|---|----------------|-----------------------|
| Utilities | | | | |
| B1 (U43) | Particulate matter | 130 | Daily | Continuous |
| | SO ₂ | 2000 | Daily | Continuous |
| | NO _x | 1400 | Daily | Continuous |
| B2 (2U43) | Particulate matter | 130 | Daily | Continuous |
| | SO ₂ | 2000 | Daily | Continuous |
| | NO _x | 1400 | Daily | Continuous |
| GT1 | Particulate matter | 10 | Daily | Continuous |
| | SO ₂ | 500 | Daily | Continuous |
| | NO _x | 300 | Daily | Continuous |
| GT2 | Particulate matter | 10 | Daily | Continuous |
| | SO ₂ | 500 | Daily | Continuous |
| | NO _x | 300 | Daily | Continuous |
| Gas Production | | | | |
| Rectisol East (Off gas to main stack) | H ₂ S (measured as S) | 13.5 t/hr (combined with West) | Daily | Continuous |
| | Total VOC's | 300 | Hourly | Continuous |
| | H ₂ S | 12 500 | Daily | Continuous |
| Rectisol West (Off gas to main stack) | H ₂ S (measured as S) | 13.5 t/hr (combined with East) | Daily | Continuous |
| | Total VOC's | 300 | Hourly | Continuous |
| | H ₂ S | 12 500 | Daily | Continuous |
| Gas Circuit | | | | |
| CM1 (West Kiln Stack) | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 500 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 2000 | Hourly | Continuous |
| CM2 (West Arc Furnace stack) | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 500 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 500 | Hourly | Continuous |
| CM3 (East Kiln A Stack) | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 500 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 2000 | Hourly | Continuous |
| CM4 (East Arc Furnace stack) | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 500 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 500 | Hourly | Continuous |
| CM5 (East Kiln B Stack) | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 500 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 2000 | Hourly | Continuous |
| Refining | | | | |
| R1 (14HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R2 (14HT201) | Particulate matter | 120 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|-------------------|--|---|----------------|-----------------------|
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R3 (214HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R4 (214HT201) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R5 (228HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R6 (30HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R7 (30HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R8 (30HT103) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R9 (30HT104) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R10 (30HT105) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R11 (230HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R12 (230HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R13 (230HT103) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R14 (230HT104) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R15 (230HT105) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R17 (34HT101) | Particulate matter | 120 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|-------------------|--|---|----------------|-----------------------|
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R18 (234HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R19 (35HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R20 (35HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R22 (235HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R23 (235HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R24 (35HT103) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R25 (35HT104) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R26 (35HT105) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R27 (29HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R28 (29HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R29 (229HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R30 (33HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R31 (33HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R32 (33HT105) | Particulate matter | 120 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|--|--|---|----------------|-----------------------|
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R33 (233HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R34 (233HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R35 (233HT105) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R36 (32HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R37 (32HT201) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R38 (32HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R39 (232HT101) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R40 (232HT201) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| R41 (232HT102) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| SCC5 Stack | Particulate matter | 330 | Hourly | Continuous |
| | SO ₂ | 3000 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 550 | Hourly | Continuous |
| Tar, Phenosolvan and Sulfur (TPS) | | | | |
| WSA1 (518ME-1003) | F as HF | 30 | Hourly | Continuous |
| | HCl (from primary production of hydrochloric acid) | 25 | Hourly | Continuous |
| | HCl (from primary production of hydrochloric acid) | 100 | Hourly | Continuous |
| | SO ₂ | 2800 | Hourly | Continuous |
| | SO ₃ | 100 | Hourly | Continuous |
| | NO _x | 2000 | Hourly | Continuous |
| Water and Ash | | | | |
| WA1 (052WK-2102) | Particulate matter | 890 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|--------------------|--|---|----------------|-----------------------|
| | CO | 5000 | Hourly | Continuous |
| | SO ₂ | 150 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 640 | Hourly | Continuous |
| | HCl | 20 | Hourly | Continuous |
| | HF | 28 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 2.4 | Hourly | Continuous |
| | Hg | 0.85 | Hourly | Continuous |
| | Cd+Tl | 0.05 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 47 | Hourly | Continuous |
| | Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous |
| WA2 (052WK-2202) | Particulate matter | 890 | Hourly | Continuous |
| | CO | 5000 | Hourly | Continuous |
| | SO ₂ | 150 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 640 | Hourly | Continuous |
| | HCl | 20 | Hourly | Continuous |
| | HF | 28 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 2.4 | Hourly | Continuous |
| | Hg | 0.85 | Hourly | Continuous |
| | Cd+Tl | 0.05 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 47 | Hourly | Continuous |
| Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous | |
| WA3 (252WK-2102) | Particulate matter | 890 | Hourly | Continuous |
| | CO | 5000 | Hourly | Continuous |
| | SO ₂ | 150 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 640 | Hourly | Continuous |
| | HCl | 20 | Hourly | Continuous |
| | HF | 28 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 2.4 | Hourly | Continuous |
| | Hg | 0.85 | Hourly | Continuous |
| | Cd+Tl | 0.05 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 47 | Hourly | Continuous |
| Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous | |
| WA4 (252WK-2202) | Particulate matter | 890 | Hourly | Continuous |
| | CO | 5000 | Hourly | Continuous |
| | SO ₂ | 150 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 640 | Hourly | Continuous |
| | HCl | 20 | Hourly | Continuous |
| | HF | 28 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 2.4 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|-------------------|--|---|----------------|-----------------------|
| | Hg | 0.85 | Hourly | Continuous |
| | Cd+Tl | 0.05 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 47 | Hourly | Continuous |
| | Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous |
| SW1 (353IN101) | Particulate matter | 25 | Hourly | Continuous |
| | CO | 75 | Hourly | Continuous |
| | SO ₂ | 50 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| | HCl | 10 | Hourly | Continuous |
| | HF | 1 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 0.5 | Hourly | Continuous |
| | Hg | 0.05 | Hourly | Continuous |
| | Cd+Tl | 0.05 | Hourly | Continuous |
| | TOC | 10 | Hourly | Continuous |
| | NH ₃ | 10 | Hourly | Continuous |
| | Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous |
| HOW1 (052CI-101) | Particulate matter | 25 | Hourly | Continuous |
| | CO | 75 | Hourly | Continuous |
| | SO ₂ | 50 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| | HCl | 10 | Hourly | Continuous |
| | HF | 7 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 21 | Hourly | Continuous |
| | Hg | 0.27 | Hourly | Continuous |
| | Cd+Tl | 0.12 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 10 | Hourly | Continuous |
| | Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous |
| HOW2 (252CI-101) | Particulate matter | 25 | Hourly | Continuous |
| | CO | 75 | Hourly | Continuous |
| | SO ₂ | 50 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| | HCl | 10 | Hourly | Continuous |
| | HF | 7 | Hourly | Continuous |
| | Pb+As+Sb+Cr+Co+Cu+Mn+Ni+V | 21 | Hourly | Continuous |
| | Hg | 0.27 | Hourly | Continuous |
| | Cd+Tl | 0.12 | Hourly | Continuous |
| | TOC | 50 | Hourly | Continuous |
| | NH ₃ | 10 | Hourly | Continuous |
| | Dioxins and furans | 0.1 (ng I-TEQ/Nm ³) | Hourly | Continuous |
| Solvents | | | | |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|-------------------------------|--|---|----------------|-----------------------|
| 1 (Regenerator Stack, Octene) | Particulate matter | 120 | Hourly | Continuous |
| | Particulate matter | 180 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| 2 (HT 1901/HT1902) | Particulate matter | 120 | Hourly | Continuous |
| | Particulate matter | 180 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 200 | Hourly | Continuous |
| Polymers | | | | |
| 1 (Furnace A stack) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 243 t/a | Hourly | Continuous |
| 2 (Furnace B stack) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 243 t/a | Hourly | Continuous |
| 3 (Furnace C stack) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 243 t/a | Hourly | Continuous |
| 4 (Furnace D stack) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 243 t/a | Hourly | Continuous |
| 5 (Furnace Estack) | Particulate matter | 120 | Hourly | Continuous |
| | SO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 1700 | Hourly | Continuous |
| | NO _x expressed as NO ₂ | 243 t/a | Hourly | Continuous |
| Oil | | | | |
| All sources | VOCs (non-thermal) | 40000 | 24 hours | Continuous |
| LOC | | | | |
| Not Applicable | Not Applicable | Not Applicable | Not Applicable | Not Applicable |
| Nitro | | | | |
| 1 Nitric Acid Stack | NO | 150 (actual temperature @ 6 % oxygen) | Hourly | Continuous |
| | NO _x | 2000 | Hourly | Continuous |
| | NH ₃ | 100 | Hourly | Continuous |
| 2 Ammonium Nitrate Stack | NH ₃ | 300 mg N/Nm ³ | Hourly | Continuous |
| | NH ₃ | 100 | Hourly | Continuous |

| Point Source Code | Pollutant Name | Maximum Release Rate (mg/Nm ³) ^(a) | Average Period | Duration of Emissions |
|-----------------------------------|-------------------------------|---|----------------|-----------------------|
| | Particulate matter | 100 | Hourly | Continuous |
| 3 Granular Fertilizer (LAN) stack | NH ₃ | 180 mg/Nm ³ on a wet basis | Hourly | Continuous |
| | NH ₃ | 100 | Hourly | Continuous |
| | Particulate matter | 100 | Hourly | Continuous |
| | Particulate matter | 100 | Hourly | Continuous |
| 4 (Ammonium Sulfate Stack) | NH ₃ | 100 | Hourly | Continuous |
| | NH ₃ | 100 | Hourly | Continuous |
| | Particulate matter | 100 | Hourly | Continuous |
| | Particulate matter | 100 | Hourly | Continuous |
| | SO ₂ | 2800 | Hourly | Continuous |
| | SO ₃ | 100 | Hourly | Continuous |
| | F as HF | 30 | Hourly | Continuous |
| | HCl (from primary production) | 25 | Hourly | Continuous |
| HCl (from primary production) | 100 | Hourly | Continuous | |

(a) units are mg/Nm³ unless otherwise specified

C3: Fugitive emissions




Figure C3-1: Dustfall rates at Site 5 (Game Park) between May 2012 and Apr 2013




Figure C3-2: Dustfall rates at Site 6 (Halwe Pan Dam) between May 2012 and Apr 2013




Figure C3-3: Dustfall rates at Site 7 (RESM 3) between May 2012 and Apr 2013




Figure C3-4: Dustfall rates at Site 8 (Langverwacht) between May 2012 and Apr 2013




Figure C3-5: Dustfall rates at Site 9 (RESM 9) between May 2012 and Apr 2013




Figure C3-6: Dustfall rates at Site 10 (Pump Station) between May 2012 and Apr 2013




Figure C3-7: Dustfall rates at Site 11 (SCS) between May 2012 and Apr 2013

APPENDIX D: CALMET MODEL CONTROL OPTIONS

Table D-1: CALMET model control options

| Run Type | Description of Run Type | Ease of Use and Representativeness | Data availability | Advantages | Disadvantages |
|----------------------|---|---|---|--|---|
| No Observations | <ul style="list-style-type: none"> •Prognostic model data, such as MM5 to drive CALMET. •No surface or upper air observations input at all. | <ul style="list-style-type: none"> •Relatively simple to implement in model •Representative of regional meteorological conditions | MM5 data (Lakes Environmental) for 2010, 2011 and 2012 at 12km resolution for 300km by 300km study area (Secunda + Sasolburg) | <ul style="list-style-type: none"> •Simple to implement •Full spatial and temporal variability •No overwater data required •Cloud cover has spatial distribution •Eliminates need for complicated 7 user-input site-specific variables •Ideal as screening run as gives very good estimate | Resolution of prognostic data may potentially be too coarse to be representative of local conditions |
| Partial Observations | <ul style="list-style-type: none"> •Prognostic model data, such as MM5 to drive CALMET <p>PLUS</p> <ul style="list-style-type: none"> •One or more surface stations | <ul style="list-style-type: none"> •More difficult to implement than only prognostic (MM5) data. •Require 7 site-specific model parameters to be specified. •Difficulty in dealing with missing data. •Potential disagreement between prognostic and surface observations. •Very representative and considered 'refined modelling' | <ul style="list-style-type: none"> •MM5 data (Lakes Environmental) for 2010, 2011 and 2012 at 12km resolution for 300km by 300km study area (Secunda + Sasolburg) •Sasol operated surface meteorological weather stations (3 Sasolburg⁴ and 3 Secunda⁵) | <ul style="list-style-type: none"> •Full spatial and temporal variability •No overwater data required •Refined model run as using combined approach of numerical model and observations. •Ability to incorporate surface representative observation data when MM5 data is too coarse to fully pick up local effects. | <ul style="list-style-type: none"> •Surface data, especially winds may be different to that in the MM5 data file •User must include 7 site-specific variables •Data preparation and missing data |
| Observations Only | CALMET driven solely by surface, upper air and optional overwater and precipitation stations | <ul style="list-style-type: none"> •Require 7 site-specific model parameters to be specified. <p>Difficulty in dealing with missing data.</p> <ul style="list-style-type: none"> •Considered representative if sufficient observation stations and site specific choice of parameters by the modeller. | <ul style="list-style-type: none"> •Sasol operated surface meteorological weather stations (3 Sasolburg and 3 Secunda) •Closest upper air monitoring station is at OR Tambo International Airport (twice-daily soundings only) | Very good if upper air and surface stations are located close to the facility and if upper air data are recorded at sunrise and sunset. | <ul style="list-style-type: none"> •Upper air data typically 12 hourly, poor spatial and temporal resolution •Model has to interpolate between 12 hour soundings •Soundings at incorrect time of the day. •User has to deal with missing surface and upper air data |

⁴ Steam Station 1 (WS, WD, TEMP, RH, AMB PRESS, SOL RAD, RAIN); AJ Jacobs (WS, WD, SO₂, NO₂, PM₁₀) and Leitrum (WS, WD, SO₂, NO₂, PM₁₀)

⁵ Club House (WS, WD, TEMP, RH, AMB PRESS, NO_x, NO₂, SO₂, PM₁₀); Bosjespruit (WS, WD, TEMP, SOL RAD, NO₂, SO₂) and Langverwagt (WS, WD, TEMP, RH, SOL RAD, NO_x, NO₂, SO₂, PM₁₀)

APPENDIX E: CALPUFF MODEL CONTROL OPTIONS

Table E-1: CALPUFF model control options

| Run Type | Description of Run Type | Ease of Use and Representativeness | Data availability | Advantages | Disadvantages |
|-----------------------------------|---|---|---|---|--|
| Sampling Function Puff | This sampling scheme employs radically symmetric Gaussian puffs and is suitable for far field. | | | | |
| Sampling Function Slug | This sampling scheme uses a non-circular puff (a "slug), elongated in the direction of the wind during release, to eliminate the need for frequent releases of puffs. Used for near field during rapidly-varying meteorological conditions. | | | | Takes a very long time to run. |
| Dispersion coefficients MDISP = 1 | <ul style="list-style-type: none"> Dispersion coefficients are computed from measured values of turbulence, sigma-v and sigma-w. | <ul style="list-style-type: none"> The user must provide an external PROFILE.DAT file containing these parameters, and select a backup method out of options 2, 3 and 4 below in case of missing data. | <ul style="list-style-type: none"> This measured data is not available in South Africa | <ul style="list-style-type: none"> Very good if data is available. | <ul style="list-style-type: none"> These measured parameters are not readily available in South Africa. |
| Dispersion coefficients MDISP = 2 | <ul style="list-style-type: none"> Dispersion coefficients are computed from internally-calculated sigma-v, sigma-w using micrometeorological variables (u^*, w^*, L, etc.). | <ul style="list-style-type: none"> This option can simulate AERMOD-type dispersion when the user also selects the use of PDF method for dispersion in the convective boundary layer (MPDF = 1). Note that when simulating AERMOD-type dispersion, the input meteorological data must be from CALMET and cannot be ISC-type ASCII format data. The user should also be aware that under this option | <ul style="list-style-type: none"> The data is obtained from MM5 input information. | <ul style="list-style-type: none"> Based on improved theoretical work and is an improvement over Pasquill-Gifford. | <ul style="list-style-type: none"> The coefficients are derived from other parameters. |

| Run Type | Description of Run Type | Ease of Use and Representativeness | Data availability | Advantages | Disadvantages |
|--------------------------------------|--|--|--|---|--|
| | | the CALPUFF model will be more sensitive to the appropriateness of the land use characterization. | | | |
| Dispersion coefficients MDISP = 3 | <ul style="list-style-type: none"> Pasquill-Gifford (PG) dispersion coefficients for rural areas (computed using the ISCST3 multi-segment approximation) and McElroy-Pooler (MP) coefficients in urban areas. | <ul style="list-style-type: none"> The current default selection is MDISP = 3, which is ISC-type dispersion. Given the demonstrated improved characterization of dispersion provided by AERMOD, and EPA's intention to replace ISC with AERMOD, use of AERMOD-like dispersion (MDISP = 2, and MPDF = 1) is also acceptable, but likely will be of most benefit for short-range complex flow applications. | | <ul style="list-style-type: none"> Simple to use if you don't have detailed meteorological information. This option can be run using fairly basic meteorological data. | <ul style="list-style-type: none"> Based on discreet classification scheme (not continuous function). Based on field experiments done elsewhere, may or may not be representative of Highveld area. Previous projects done using this scheme however have provided good correlation over this area. |
| Dispersion coefficients MDISP = 4 | <ul style="list-style-type: none"> Same as MDISP = 3, except PG coefficients are computed using the MESOPUFF II equations | | | | |
| Dispersion coefficients MDISP = 5 | <ul style="list-style-type: none"> CTDM sigmas are used for stable and neutral conditions. For unstable conditions, sigmas are computed as in MDISP=3 described above. | <ul style="list-style-type: none"> When selecting this option, the user must provide an external PROFILE.DAT file, and select a backup method out of options 2, 3 and 4 above in case of missing data. | | | |
| Chemical transformation RIVAD | <ul style="list-style-type: none"> Pseudo-first-order chemical mechanism for SO₂, SO₄²⁻, NO, NO₂, HNO₃, and NO₃ - (RIVAD/ARM3 method) | <ul style="list-style-type: none"> RIVAD is a 6-species scheme wherein NO and NO₂ are treated separately. In the RIVAD scheme the conversion of SO₂ to sulfates is not RH-dependent. The conversion of NO_x to nitrates is | <ul style="list-style-type: none"> In order to use the RIVAD scheme, the user must divide the NO_x emissions into NO and NO₂ for each source. Two options are specified for the ozone concentrations: (1) hourly ozone concentrations | <ul style="list-style-type: none"> In several tests conducted to date, the results have shown no significant differences between the RIVAD and MESOPUFF II options. | <ul style="list-style-type: none"> User has to input the NO and NO₂ emissions which are not always known for all sources. User has to input the ozone concentrations which are not always known. |

| Run Type | Description of Run Type | Ease of Use and Representativeness | Data availability | Advantages | Disadvantages |
|---|---|--|---|---|---|
| | | RH-dependent. | from a network of stations, or (2) a single user defined ozone value. • The background ammonia concentrations required for the HNO ₃ /NH ₄ NO ₃ equilibrium calculation can be user-specified or a default value will be used. | | • The model is restricted to rural conditions. |
| Chemical transformation MESOPUFF II | • Pseudo-first-order chemical mechanism for SO ₂ , SO ₄ ²⁻ , NO _x , HNO ₃ , and NO ₃ - (MESOPUFF II method) | • MESOPUFF II is a 5-species scheme in which all emissions of nitrogen oxides are simply input as NO _x . • In the MESOPUFF II scheme, the conversion of SO ₂ to sulfates is dependent on relative humidity (RH), with an enhanced conversion rate at high RH. • The conversion of NO _x to nitrates is RH-dependent. | • The MESOPUFF II scheme assumes an immediate conversion of all NO to NO ₂ . • Two options are specified for the ozone concentrations: (1) hourly ozone concentrations from a network of stations, or (2) a single user defined ozone value. • The background ammonia concentrations required for the HNO ₃ /NH ₄ NO ₃ equilibrium calculation can be user-specified or a default value will be used. | • In several tests conducted to date, the results have shown no significant differences between the RIVAD and MESOPUFF II options for sulfate and nitrate formation. • The model is applicable to both urban and rural conditions. | • User has to input the ozone concentrations which are not always known. • NO to NO ₂ conversion is not included. In model. |
| User-specified diurnal cycles of transformation rates | | | | | |
| No chemical conversion | | | | | |

APPENDIX F: THE NO₂/NO_x CONVERSION RATIOS FOR NO₂ FORMATION

Scire and Borissova (2011) analysed hourly monitored NO₂ and NO_x data for 2006 at 325 monitoring sites throughout USA (approximately 2.8 million data points for each species). These observations were grouped into a number of concentration bins and were used to compute bin maximums and bin average curves. Short-term (1-hr) NO₂/NO_x ratios were developed on bin-maximum data, whereas the long-term (annual average) NO₂/NO_x ratios were based on bin-averaged data. The method was subsequently tested using the NO₂/NO_x ratios applied to the observed NO_x at selected stations to predict NO₂, and then compared to observed NO₂ concentrations at that station. As illustrated in the examples, Figure F-1 and Figure F-2, using these empirical curves provide a reasonable estimate of the observed NO₂ can be obtained, albeit mostly more conservative. In Figure F-3, the method is compared to the assumption of 100% conversion over the short-term, which clearly illustrates the extreme conservatism, especially at elevated concentrations.




Figure F-1: Comparison of observed with predicted NO₂ concentrations (Long Island, NY) using the derived short-term NO₂/NO_x ratios (Scire and Borissova, 2011)




Figure F-2: Comparison of observed with predicted NO₂ concentrations (Chicago, IL) using the derived short-term NO₂/NO_x ratios (Scire and Borissova, 2011)




Figure F-3: Observed versus predicted NO₂ concentrations (Bahrain) using the derived short-term NO₂/NO_x ratios (Scire and Borissova, 2011)

It was decided that the NO₂/NO_x conversion factors described by Scire and Borissova (2011) and as given in Table F-1, will be employed in this study. Observed NO₂/NO_x ratios at the Sasolburg monitoring stations were also analysed and compared to the factors in the table (Figure F-4). It is shown in the table and Figure F-4 that the Scire and Borissova ratios would also be applicable in the current study since it would produce estimates similar or more conservative than if the actual NO₂/NO_x ratios at the site would have been used instead.

Table F-1: NO₂/NO_x conversion ratios for NO₂ formation

| Bin | Concentration (µg/m ³) | | | NO ₂ /NO _x Ratios | | | |
|-----|------------------------------------|------|--------|---|------------------------|--------------------------|------------|
| | | | | Secunda | | Scire and Borissova 2011 | |
| | Min | Max | Centre | Club 2010-2012 | Langverwacht 2010-2012 | Bin Average | 1-Hour Max |
| 1 | 0 | 19 | 9 | 0.796 | 0.720 | 0.7980 | 0.9938 |
| 2 | 19 | 38 | 28 | 0.731 | 0.678 | 0.8130 | 0.9922 |
| 3 | 38 | 75 | 56 | 0.663 | 0.597 | 0.7306 | 0.9844 |
| 4 | 75 | 113 | 94 | 0.563 | 0.466 | 0.5544 | 0.9094 |
| 5 | 113 | 150 | 132 | 0.503 | 0.370 | 0.4370 | 0.7477 |
| 6 | 150 | 188 | 169 | 0.464 | 0.277 | 0.3553 | 0.6085 |
| 7 | 188 | 235 | 212 | 0.405 | 0.182 | 0.3013 | 0.4976 |
| 8 | 235 | 282 | 259 | 0.378 | 0.122 | 0.2559 | 0.4173 |
| 9 | 282 | 329 | 306 | 0.329 | 0.110 | 0.2276 | 0.3543 |
| 10 | 329 | 376 | 353 | 0.229 | 0.127 | 0.2081 | 0.3056 |
| 11 | 376 | 423 | 400 | 0.300 | 0.128 | 0.1852 | 0.2684 |
| 12 | 423 | 470 | 447 | 0.203 | 0.110 | 0.1809 | 0.2404 |
| 13 | 470 | 517 | 494 | 0.145 | 0.124 | 0.1767 | 0.2194 |
| 14 | 517 | 564 | 541 | | 0.110 | 0.1546 | 0.2035 |
| 15 | 564 | 611 | 588 | 0.176 | 0.077 | 0.1524 | 0.1912 |
| 16 | 611 | 658 | 635 | | 0.085 | 0.1476 | 0.1813 |
| 17 | 658 | 705 | 682 | | 0.077 | 0.1402 | 0.1726 |
| 18 | 705 | 752 | 729 | | 0.089 | 0.1363 | 0.1645 |
| 19 | 752 | 846 | 799 | | | 0.1422 | 0.1527 |
| 20 | 846 | 940 | 893 | | | 0.1223 | 0.1506 |
| 21 | 940 | 1128 | 1034 | | | 0.1087 | 0.1474 |
| 22 | 1128 | 1316 | 1222 | | | 0.1110 | 0.1432 |
| 23 | 1316 | 1504 | 1410 | | | 0.1112 | 0.139 |
| 24 | 1504 | 1786 | 1645 | | | 0.1165 | 0.1337 |




Figure F-4: NO₂/NO_x conversion ratios for Secunda monitoring stations

APPENDIX G: TIME SERIES PLOTS FOR THE MEASURED AMBIENT AIR QUALITY IN THE STUDY AREA

A summary of the time series plots for the measured data as provided by Sasol is given in the following section.




Figure G-1: Summary of meteorological data received for Bosjesspruit (2010-2012)




Figure G-3: Summary of meteorological data received for Secunda Club (2010-2012)




Figure G-4: Summary of ambient data received for Secunda Club (2010-2012)




Figure G-5: Summary of daily PM data received for Secunda Club (2010-2012)




Figure G-6: Summary of meteorological data received for Langverwacht (2010-2012)




Figure G-7: Summary of ambient data received for Langverwacht (2010-2012)




Figure G-8: Summary of daily PM data received for Langverwacht (2010-2012)

APPENDIX H: PREDICTED BASELINE AND OBSERVED AIR CONCENTRATIONS

The following tables summarise the predicted baseline SO₂, NO₂ and H₂S concentrations at the Bosjesspruit, Secunda Club and Langverwacht monitoring site locations, respectively. The peak (maximum), 99th, 90th, 50th and annual average values are given for each of the simulated years, 2010, 2011 and 2012. The corresponding observed concentration values are also summarised in the tables for comparison. Estimates of long-term background concentrations were obtained from the observed values at the ranked position when no contributions from the simulated sources were predicted.

Table H-1: Predicted and observed SO₂ concentration statistics

| | Year | SO ₂ Concentration (µg/m ³) | | | | | |
|--|---------|--|----------|--------------|----------|--------------|----------|
| | | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | | Predicted | Observed | Predicted | Observed | Predicted | Observed |
| Maximum | 2010 | 511.53 | 510.62 | 423.63 | 462.05 | 627.65 | 485.45 |
| | 2011 | 488.22 | 499.51 | 440.39 | 474.68 | 450.17 | 455.27 |
| | 2012 | 559.34 | 631.30 | 494.30 | 598.42 | 652.07 | 539.07 |
| | Average | 519.70 | 547.14 | 452.77 | 511.72 | 576.63 | 493.26 |
| 99th Percentile | 2010 | 139.7 | 175.5 | 62.5 | 173.0 | 71.3 | 152.45 |
| | 2011 | 118.7 | 216.0 | 76.9 | 172.8 | 84.2 | 165.48 |
| | 2012 | 115.6 | 222.0 | 87.6 | 174.9 | 83.7 | 176.59 |
| | Average | 124.7 | 204.5 | 75.7 | 173.6 | 79.8 | 164.84 |
| 90th Percentile | 2010 | 3.5 | 57.9 | 0.2 | 46.6 | 0.3 | 40.79 |
| | 2011 | 2.2 | 72.7 | 0.4 | 42.9 | 0.3 | 43.93 |
| | 2012 | 2.7 | 64.2 | 1.3 | 47.1 | 0.6 | 48.39 |
| | Average | 2.8 | 65.0 | 0.6 | 45.5 | 0.4 | 44.37 |
| 50th Percentile | 2010 | 0.0 | 8.3 | 0.0 | 7.5 | 0.0 | 7.73 |
| | 2011 | 0.0 | 7.0 | 0.0 | 4.2 | 0.0 | 6.07 |
| | 2012 | 0.0 | 9.2 | 0.0 | 8.7 | 0.0 | 7.48 |
| | Average | 0.0 | 8.1 | 0.0 | 6.8 | 0.0 | 7.09 |
| Annual Average | 2010 | 6.1 | 21.8 | 2.1 | 18.9 | 2.5 | 17.35 |
| | 2011 | 4.5 | 25.1 | 2.5 | 16.2 | 2.9 | 17.48 |
| | 2012 | 4.6 | 24.7 | 3.4 | 20.1 | 3.2 | 19.35 |
| | Average | 5.1 | 23.9 | 2.7 | 18.4 | 2.8 | 18.06 |
| Background (observed value when prediction indicated no contribution) | 2010 | | 15.5 | | 21.4 | | 17.06 |
| | 2011 | | 19.0 | | 15.1 | | 14.86 |
| | 2012 | | 17.9 | | 17.6 | | 17.54 |
| | Average | | 17.5 | | 18.0 | | 16.49 |

Table H-2: Predicted and observed NO₂ concentration statistics

| | | NO ₂ Concentration (µg/m ³) | | | | | |
|--|----------------|--|--------------|--------------|--------------|--------------|--------------|
| | | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | | Predicted | Observed | Predicted | Observed | Predicted | Observed |
| Maximum | 2010 | 126.3 | 514.9 | 110.6 | 485.3 | 163.8 | 137.1 |
| | 2011 | 130.5 | 408.9 | 115.6 | 375.8 | 117.2 | 216.6 |
| | 2012 | 142.5 | 274.5 | 126.4 | 193.1 | 167.2 | 181.9 |
| | <i>Average</i> | <i>133.1</i> | <i>399.4</i> | <i>117.5</i> | <i>351.4</i> | <i>149.4</i> | <i>178.5</i> |
| 99 th Percentile | 2010 | 80.1 | 124.0 | 37.4 | 94.4 | 37.1 | 75.1 |
| | 2011 | 71.3 | 139.7 | 45.7 | 100.6 | 48.7 | 83.9 |
| | 2012 | 70.2 | 83.9 | 51.2 | 78.7 | 47.5 | 72.4 |
| | <i>Average</i> | <i>73.9</i> | <i>115.9</i> | <i>44.8</i> | <i>91.2</i> | <i>44.4</i> | <i>77.1</i> |
| 90 th Percentile | 2010 | 4.9 | 44.5 | 0.5 | 44.8 | 1.7 | 40.0 |
| | 2011 | 2.8 | 29.4 | 0.8 | 45.3 | 1.7 | 48.1 |
| | 2012 | 2.5 | 34.8 | 1.6 | 40.5 | 1.6 | 40.5 |
| | <i>Average</i> | <i>3.4</i> | <i>36.2</i> | <i>0.9</i> | <i>43.5</i> | <i>1.7</i> | <i>42.9</i> |
| 50 th Percentile | 2010 | 0.0 | 12.9 | 0.0 | 13.0 | 0.0 | 14.4 |
| | 2011 | 0.0 | 1.1 | 0.0 | 13.2 | 0.0 | 15.9 |
| | 2012 | 0.0 | 9.8 | 0.0 | 14.0 | 0.0 | 13.5 |
| | <i>Average</i> | <i>0.0</i> | <i>7.9</i> | <i>0.0</i> | <i>13.4</i> | <i>0.0</i> | <i>14.6</i> |
| Annual Average | 2010 | 3.6 | 20.3 | 1.2 | 19.3 | 1.5 | 18.8 |
| | 2011 | 2.7 | 11.2 | 1.4 | 19.7 | 1.7 | 21.3 |
| | 2012 | 2.7 | 15.0 | 1.9 | 18.6 | 1.7 | 18.0 |
| | <i>Average</i> | <i>3.0</i> | <i>15.5</i> | <i>104.8</i> | <i>19.2</i> | <i>1.6</i> | <i>19.4</i> |
| Background (observed value when prediction indicated no contribution) | 2010 | | 16.7 | | 23.3 | | 22.1 |
| | 2011 | | 5.1 | | 0.0 | | 24.0 |
| | 2012 | | 12.5 | | 19.7 | | 21.6 |
| | <i>Average</i> | | <i>11.4</i> | | <i>14.4</i> | | <i>22.6</i> |

Table H-3: Predicted and observed H₂S concentration statistics

| | | H ₂ S Concentration (µg/m ³) | | | | | |
|--|----------------|---|----------|--------------|----------|--------------|----------|
| | | Bosjesspruit | | Secunda Club | | Langverwacht | |
| | | Predicted | Observed | Predicted | Observed | Predicted | Observed |
| Maximum | 2010 | 253.6 | 750.0 | 207.4 | 613.9 | 305.5 | 750.0 |
| | 2011 | 238.4 | 312.4 | 214.6 | 172.9 | 224.4 | 511.7 |
| | 2012 | 273.9 | 166.8 | 241.4 | 245.5 | 318.4 | 455.8 |
| | <i>Average</i> | 255.3 | 409.7 | 221.1 | 344.1 | 282.8 | 572.5 |
| 99th Percentile | 2010 | 68.9 | 64.6 | 31.7 | 35.9 | 36.2 | 72.3 |
| | 2011 | 58.2 | 104.0 | 38.4 | 54.5 | 43.9 | 85.3 |
| | 2012 | 56.7 | | 43.8 | 41.0 | 42.6 | 65.6 |
| | <i>Average</i> | 61.2 | 84.3 | 38.0 | 43.8 | 40.9 | 74.4 |
| 90th Percentile | 2010 | 0.0 | 0.0 | 0.0 | 2.0 | 0.0 | 5.5 |
| | 2011 | 0.0 | 1.7 | 0.0 | 3.5 | 0.0 | 1.3 |
| | 2012 | 0.0 | | 0.0 | 2.4 | 0.0 | 2.5 |
| | <i>Average</i> | 0.0 | 0.9 | 0.0 | 2.6 | 0.0 | 3.1 |
| 50th Percentile | 2010 | 0.0 | 0.0 | 0.0 | 2.0 | 0.0 | 5.5 |
| | 2011 | 0.0 | 1.7 | 0.0 | 3.5 | 0.0 | 1.3 |
| | 2012 | 0.0 | | 0.0 | 2.4 | 0.0 | 2.5 |
| | <i>Average</i> | 0.0 | 0.9 | 0.0 | 2.6 | 0.0 | 3.1 |
| Annual Average | 2010 | 3.0 | 3.9 | 1.1 | 4.3 | 1.2 | 10.1 |
| | 2011 | 2.3 | 7.7 | 1.3 | 5.9 | 1.4 | 8.6 |
| | 2012 | 2.3 | | 1.8 | 5.2 | 1.6 | 8.7 |
| | <i>Average</i> | 2.5 | 5.8 | 1.4 | 5.1 | 1.4 | 9.1 |
| Background (observed value when prediction indicated no contribution) | 2010 | | 2.0 | | 7.1 | | 17.0 |
| | 2011 | | 6.4 | | 6.4 | | 15.2 |
| | 2012 | | | | 7.4 | | 16.0 |
| | <i>Average</i> | | 4.2 | | 7.0 | | 16.1 |

APPENDIX I: DAILY AND ANNUAL AMBIENT CONCENTRATIONS

Sulfur dioxide (SO₂)

Daily

Daily SO₂ concentrations (99th percentile) were not predicted to exceed the daily NAAQS at any of the identified receptors (Figure I-2, Figure I-6, Figure I-8, and Figure I-10) where the highest concentrations are predicted as a result of emissions from Steam Stations (Figure I-2). Daily average SO₂ concentrations were also predicted to decrease under theoretical compliance with New Plant Standards at the Steam Stations (Figure I-3). The Alternative Emission Limits was predicted to result in increases in daily SO₂ concentrations of less than 10% relative to the airshed baseline, at all 15 receptors. Minor changes are expected as a result of Existing and New Plant Standards from Biosludge and HOW Incinerators and the Wet Sulfuric Acid Plant (Figure I-7, Figure I-9, and Figure I-11).




Figure I-1: Predicted 99th percentile daily SO₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-2: Predicted 99th percentile daily SO₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-3: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (change calculated using Equation 1)




Figure I-4: Predicted 99th percentile daily SO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure I-5: Predicted 99th percentile daily SO₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations




Figure I-6: Predicted 99th percentile daily SO₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-7: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (change calculated using Equation 1)




Figure I-8: Predicted 99th percentile daily SO₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-9: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1)




Figure I-10: Predicted 99th percentile daily SO₂ concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-11: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (calculated using Equation 1)

Annual

Predicted annual ambient SO₂ concentrations (Figure I-12) show similar trends as for hourly (Section 5.1.8.1.1) and daily average concentrations (above). The source with the largest impact is Steam Stations (Figure I-13). Improvements in annual ambient SO₂ concentrations reach a maximum of 11.3% at near Bosjesspruit (GR3) as a result of the Steam Stations theoretically complying with New Plant Standards (Figure I-14). Alternative Emission Limits were predicted to result in an increase in annual SO₂ by less than 5% relative to the airshed baseline, at all receptors (Figure I-14).




Figure I-12: Predicted annual SO₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-13: Predicted annual SO₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-14: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (calculated using Equation 1)




Figure I-15: Predicted annual SO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure I-16: Predicted annual SO₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations




Figure I-17: Predicted annual SO₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-18: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1)




Figure I-19: Predicted annual SO₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-20: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1)




Figure I-21: Predicted annual SO₂ concentrations at identified receptors for Synfuels Wet Sulfuric Acid Plant (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-22: Theoretical change in SO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Wet Sulfuric Acid Plant (calculated using Equation 1)

Nitrogen dioxide (NO₂)

Annual

Predicted annual average ambient NO₂ concentrations fell below NAAQS for all sources assessed for all scenarios (Figure I-23, Figure I-24, Figure I-28, and, Figure I-30). The maximum improvement was predicted (0.7%) at Bosjesspruit as a result of Steam Stations theoretically complying with Existing Plant Standards (Figure I-25). Theoretical compliance with New Plant Standards and the Alternative Emission Limits scenarios both predicted increases in annual NO₂ at some receptors – mostly those closer to the plant – where the maximum increase predicted was 9.1% at Bosjesspruit for the Alternative Emission Limit scenario (Figure I-25).




Figure I-23: Predicted annual NO₂ concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-24: Predicted annual NO₂ concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-25: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Secunda Steam Stations (calculated using Equation 1)




Figure I-26: Predicted annual NO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure I-27: Predicted annual NO₂ concentrations as a result of Alternative Emission Limit emissions from the Steam Stations




Figure I-28: Predicted annual NO₂ concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-29: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1)




Figure I-30: Predicted annual NO₂ concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-31: Theoretical change in NO₂ concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1)

Particulate matter (PM)

Annual

Annual ambient PM concentrations were predicted to be less than $4 \mu\text{g}/\text{m}^3$ at all receptors for all sources and scenarios assessed (Figure I-32); below the NAAQS for annual average PM (Figure I-33, Figure I-37, Figure I-39, and Figure I-41). Theoretical compliance with Existing Plant Standards would result in increased ambient annual PM concentrations as a result of the Steam Stations (Figure I-34). Improvements in ambient PM concentrations as a result of the Steam Stations and Incinerators theoretically meeting New Plant Standards are less than 2.5% in all cases (Figure I-38, and, Figure I-40). Increases in annual PM concentrations were predicted to be less than 10% at all receptors as a result of the Alternative Emission Limits (Figure I-34, Figure I-38, Figure I-40, and, Figure I-42).




Figure I-32: Predicted annual PM concentrations at identified receptors for all modelled Synfuels sources (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-33: Predicted annual PM concentrations at identified receptors for Synfuels Steam Stations (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-34: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Steam Stations (calculated using Equation 1)




Figure I-35: Predicted annual NO₂ concentrations as a result of Baseline emissions from the Steam Stations




Figure I-36: Predicted annual NO₂ concentrations as a result of Alternative Emission Limits emissions from the Steam Stations




Figure I-37: Predicted annual PM concentrations at identified receptors for Synfuels Biosludge Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-38: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels Biosludge Incinerators (calculated using Equation 1)




Figure I-39: Predicted annual PM concentrations at identified receptors for Synfuels HOW Incinerators (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-40: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels HOW Incinerators (calculated using Equation 1)




Figure I-41: Predicted PM concentrations at identified receptors for Synfuels SCC (receptor code names as detailed in Table 5-23, where locations are shown in Figure 5-49)




Figure I-42: Theoretical change in PM concentrations between scenarios and the airshed baseline at the identified receptors for Synfuels SCC (calculated using Equation 1)

APPENDIX J: MANAGEMENT OF UNCERTAINTIES

Dispersion Model Uncertainties

In the US EPA Guideline on Air Quality Models (U.S. EPA, 2005), the need to address the uncertainties associated with dispersion modelling is acknowledged as an important issue that should be considered. The US Guideline divides the uncertainty associated with dispersion model predictions into two main types (U.S. EPA, 2005), as follows:

- Reducible uncertainty, which results from uncertainties associated with the input values and with the limitations of the model physics and formulations. Reducible uncertainty can be minimized by improved (i.e., more accurate and representative) measurements and improved model physics.
- Inherent uncertainty is associated with the stochastic (turbulent) nature of the atmosphere and its representation (approximation) by numerical models. Models predict concentrations that represent an ensemble average of numerous repetitions for the same nominal event. An individual observed value can deviate significantly from the ensemble value. This uncertainty may be responsible for a $\pm 50\%$ deviation from the measured value.

Atmospheric dispersion models are often criticised for being inadequate since “...it is only a model approximating reality”, and therefore include inherent uncertainty. Both reducible and inherent uncertainties mean that dispersion modelling results may over- or under-estimate measured ground-level concentrations at any specific time or place. However, the US EPA Guideline on Air Quality Models (U.S. EPA, 2005) also states that:

“Models are reasonably reliable in estimating the magnitude of highest concentrations occurring sometime, somewhere within an area. For example, errors in highest estimated concentrations of +/- 10 to 40 per cent are found to be typical, i.e., certainly well within the often-quoted factor of two accuracy that has long been recognized for these models. However, estimates of concentrations that occur at a specific time and site are poorly correlated with actually observed concentrations and are much less reliable.”

To minimise the overall uncertainty, but specifically the “reducible uncertainty”, the following simple principles were followed in the investigation:

- Understanding the objectives of the investigation;
- Demonstrating that the model inputs are as correct as possible;
- Understanding and stating the model performance limitations;
- Demonstrating that the modelling process has been conducted appropriately and in line with both local DEA requirements and international practice;
- Including any validating information from monitoring that might be available; and
- To be conservative in cases where there is greater uncertainty (e.g. conversion of NO to NO₂).

Although the existence of model uncertainty is well-accepted, it does not exclude the use of dispersion modelling results in making important air quality impact decisions. The uncertainties should simply be acknowledged and understood that, given their inherent uncertainty, current dispersion models are a “best-case” approximation of what are otherwise very complex physical processes in the atmosphere. An accepted dispersion model (i.e., CALPUFF) was selected for the analysis to minimize some of these uncertainties. The US EPA states that when dispersion models such as CALPUFF are used to assess ground-level concentration and when a sufficiently large number of meteorological conditions are considered, the

modelling results should ideally fall well within the often quoted "factor of two" accuracy for these modelled (U.S. EPA, 2005).

Validation of Predictions

Model verification and validation (V&V) are the primary processes for quantifying and building credibility in numerical models. There are distinct differences between the two processes, as described below:

- Verification is the process of determining that a model implementation accurately represents the developer's conceptual description of the model and its solution.
- Validation is the process of determining the degree to which a model is an accurate representation of the real world from the perspective of the intended uses of the model.

Whilst V&V cannot prove that a model is correct and accurate for all possible scenarios, it can provide evidence that the model is sufficiently accurate for its intended use.

A rigorous V&V programme was not completed as part of the study; however, regular sanity checks on model results and comparisons with observations were done, as discussed in Section 5.1.6. An attempt was also made to quantify the level of agreement between observed data and model prediction, as well as the predictive accuracy of the model once the necessary adjustments have been made (such as including the estimated background concentrations). In this regard, the CALPUFF model's performance was evaluated by comparing the modelling results for the years 2010, 2011 and 2012 to the Sasol monitoring data collected over the same time period. In particular, the predicted SO₂ and NO₂ concentrations arising from the Secunda operations were included in the comparison.

The performance evaluation was completed using the fractional bias method, since this statistical technique is one of the evaluation methods recommended by the U.S. EPA for determining dispersion model performance (U.S. EPA 1992). Both short- and long-term fractional biases were computed for SO₂ and NO₂ as predicted and observed at the three monitoring stations; Bosjesspruit, Secunda Club, and, Langverwacht. The fractional biases of the means were shown to be well within a factor of two, which the U.S. EPA consider to be a reasonable performance target for a dispersion model before it is used for refined regulatory analysis (U.S. EPA 1992).

Scenario Simulations

Since the focus of the study has been to illustrate the relative changes with the introduction of different emission conditions (i.e. emission rates, exit gas temperatures and velocities), whilst maintaining the same stack heights and diameters, it is expected that the model errors would mostly be similar in magnitude between the different modelling scenarios. Therefore, expressing the changes as incremental and relative to the baseline scenario, it is expected that these errors would mostly cancel each other out.

It should also be noted that the average long-term background concentrations (Table 5-24) were used in this expression rather than the short-term value, which offers a more conservative approach.

Ambient Monitoring Uncertainty

Sasol operates a total of three ambient air quality monitoring stations in and around Secunda, namely at Bosjesspruit, Secunda Club and Langverwacht. Data for 2010, 2011 and 2012 all three stations were included in this investigation.

All of the abovementioned monitoring stations are ISO/IEC17025 accredited, to ensure data integrity and data quality as well as to ensure that the data obtained from the monitoring stations are representative of the ambient air when measured. Data availability and credibility is maximised through:

- Regular (at least on a weekly basis) visits of the monitoring stations to ensure the stations are functioning properly.
- Dynamic calibrations are conducted on at a quarterly basis, however where possible more frequent calibrations have been done.
- Certified calibration gas is used and obtained from reputable vendors
- Inter-laboratory comparisons are done between Sasol's Sasolburg and Secunda monitoring stations as well as between Sasolburg, Secunda and a third party calibration laboratory.
- Participation in the National Metrological Laboratory's national inter-laboratory comparisons to ensure that the system is in line with the rest of the accredited laboratories in South Africa.

Although the ISO/IEC 17025 System requires a quarterly data availability of 80%, Sasol's internal data availability, tracked on a monthly Scorecard, is a monthly data availability of 90%.

Based on the uncertainty calculations completed as per the ISO/IEC17025 requirements, Sasol's uncertainty in measurements on its ambient air quality monitoring stations is between 3% and 5% with a level of confidence of 95%. This has been confirmed through inter-laboratory comparisons and is confirmed on a regular basis.

Upper Air Meteorological Data

Although meteorological data from the monitoring stations described in the previous section are available for input into the CALPUFF dispersion model, there is a lack of upper air meteorology. The lack of appropriate meteorological information is often the single most important limiting factor in modelling accuracy. It is also the most subjective in deciding just how many data are needed, from which location and how accurate they must be.

The CALMET wind field model requires, as a minimum, meteorological data from at least one surface and an upper air station. This information is then used to "seed" the three-dimensional wind field with an initial solution of a relatively simple mass conservation model. CALMET does not include momentum, energy, or moisture conservation equations, and is therefore classified as a diagnostic model.

It is expected, that a wind field developed using all the parameters that could influence the flow, thermal and turbulence mechanisms should improve the accuracy of the dispersion predictions. MM5 is a three-dimensional, non-hydrostatic prognostic mesoscale models. MM5 is the fifth generation NCAR/Penn State Mesoscale model. The model includes a multiple-nesting capability, non-hydrostatic dynamics and four-dimensional data assimilation (Dudhia et al., 1999). The MM5 model uses all the conservation equations and has more refined parameterisations for processes that cannot be simulated directly. The main advantages and disadvantages of these models are detailed below.

Advantages of MM5:

- has the ability to assimilate local meteorological data;
- has realistic dynamical and physical formulations, suitable for simulations in South Africa's environment;
- can produce realistic meteorological fields in data-sparse regions; and

- is flexible enough to couple output meteorological fields to dispersion model runs at any resolution.

Disadvantages of MM5:

- has relatively high computational demands;
- requires a large amount of user knowledge and expertise to produce reliable and convincing results; and
- do not themselves include dispersion models, and the associated dispersion models do not necessarily comprise all of the features required for regulatory assessments (e.g. building effects).

MM5 data for the study domain was purchased from Lake Environmental that has proven record of generating MM5 data ready for use in the US EPA's AERMOD and CALPUFF dispersion modelling suites. The dataset included the years 2010, 2011 and 2012 at 12km resolution for a 300km by 300km study area.

The MM5 prognostic model together with the meteorological observations provide a 'first-guess field', which is then modified by the CALMET diagnostic model to take account of terrain and land-use features that are at a smaller spatial scale than the terrain used by the prognostic model. The main purpose of this approach is to increase the horizontal resolution of the meteorological fields.

Emission Inventory Uncertainty

In addition to meteorological input data, the uncertainty associated with the emissions inventory needs to be accommodated in the results. All emissions used in the simulations of the baseline scenario were based on either iso-kinetic measurement campaigns or continuous emissions monitoring (CEM).

Sasol makes use of reputable sampling companies for its third party measurement campaign and also operates CEM devices in certain of its plants. Although there is currently no quality accredited system for online monitoring devices within a stack, Sasol is using the same principles as for its ambient air quality monitoring stations, i.e. the ISO/IEC17025 principles to manage the quality of the data received from its online monitoring network.

All third party (and *ad hoc*) sampling requests (or requirements) within the Sasol Group have to comply with AQA Section 21, Schedule 2 of the Listed Activities and Minimum Emission Standard. Furthermore, Sasol has, as far as possible, standardised on US EPA sampling methodologies. Analyses of the samples are also done by an ISO/IEC17025 accredited laboratory to further control the quality of the results.

Where *ad hoc* sampling is done, Sasol's philosophy is aligned with the requirements of the AQA Section 21, namely that all point sources must be sampled at least once a year.

Continuous Emission Monitoring

Due to the lack of a National Accreditation system for CEM, uncertainty in measurements cannot be confirmed at this stage, however based on the uncertainty associated with sampling, Sasol has

- a 10% uncertainty factor associated with its online particulate measurements; and
- an uncertainty below 10% for gases, the based on the accuracy of the completed calibrations, as well as the accuracy of the calibration gases (this uncertainty ranges between 5% and 10%).

These uncertainties are with a level of confidence of 95%.

Third-Party Emission Monitoring

The uncertainty associated with third-party emission's measurements is considered to be up to 10% with a level of confidence of 95%. This uncertainty is based on the isokineticity of the isokinetic sampling, as well as the uncertainty associated with the sample taking and chemical analysis of gaseous components.

According to the Sasol quality control system, all third-party contractors for isokinetic sampling need to comply with the following control criteria:

- Their entire sampling staffs undergo the training associated with the UK-based Monitoring Certification Scheme (MCERTS): Manual Stack emissions monitoring program (MCERTS 2011);
- An electronic automated sampler is used for all isokinetic sampling;
- The pitot tubes used for sampling is calibrated at least on a quarterly basis;
- The pneumatic pressure sensors on the sampler is also calibrated on at least a quarterly basis; and
- The dry gas meters are checked on a regular basis and replaced every 6 months.

The CEM data is logged per second, and then averaged. In this way, all process upsets are captured within the database. The CEM data used in this investigation were based on an hourly average mass flow and concentration.

Ad-Hoc Emissions Sampling

SANAS is compiling an accreditation system for *ad hoc* sampling and as soon as this system is in place, the uncertainty of the measurements will be confirmed; however it is not expected to be higher than 10%.

Sasol is also in the process of conducting an international peer review on its third party contractors to determine whether there is a potential higher uncertainty in its measurements.

The Minimum Emissions Standards requires that sampling be conducted at normal operating conditions; therefore the emissions information included in the dispersion model is aligned with normal operating conditions on site. The sampling schedule is communicated to the plant managers with the aim of having process conditions as representative as possible to normal operations. Sampling upset conditions often poses a challenge from both a logistical and safety point of view, since safety requirements require as few people as possible on the plant during severe upset conditions and therefore sampling cannot be done during such conditions.

PM_{2.5} and PM₁₀ Air Emissions

All particulate matter was assumed to be PM_{2.5} since it was not possible to establish the PM_{2.5}/PM₁₀ split.

Non-Sasol Air Emissions

No attempt was made to estimate the emissions from non-industrial activities within regional communities. Instead, the community contribution (and other sources) of a particular compound was discussed in Section 5.1.6.1.

APPENDIX K: GUIDANCE NOTE ON TREATMENT OF UNCERTAINTIES

The Intergovernmental Panel on Climate Change (IPCC) produced a Guidance Note for lead authors of the IPCC Fifth Assessment Report on consistent treatment of uncertainties. These notes define a common approach and calibrated language that can be used broadly for developing expert judgments and for evaluating and communicating the degree of certainty in findings of the assessment process. Communicating the degree of certainty in key findings relies on expressing the:

- Confidence in the validity of a finding, based on the type, amount, quality, and consistency of evidence (e.g., mechanistic understanding, theory, data, models, expert judgment) and the degree of agreement. Confidence is expressed qualitatively.
- Quantified measures of uncertainty in a finding expressed probabilistically (based on statistical analysis of observations or model results, or expert judgment).

The Guidance Note proposes the use of the following dimensions to evaluate the validity of a finding: the type, amount, quality, and consistency of evidence (summary terms: “limited,” “medium,” or “robust”), and the degree of agreement (summary terms: “low,” “medium,” or “high”), as summarised in the figure below.




Figure K-1: A depiction of evidence and agreement statements and their relationship to confidence. Confidence increases towards the top-right corner as suggested by the increasing strength of shading. Generally, evidence is most robust when there are multiple, consistent independent lines of high-quality evidence.

Generally, evidence is most robust when there are multiple, consistent independent lines of high-quality evidence. The guide further provides advice for a traceable account describing the evaluation of evidence and agreement, as follows:

- For findings with high agreement and robust evidence, present a level of confidence or a quantified measure of uncertainty.
- For findings with high agreement or robust evidence, but not both, assign confidence or quantify uncertainty when possible. Otherwise, assign the appropriate combination of summary terms for your evaluation of evidence and agreement (e.g., robust evidence, medium agreement).
- For findings with low agreement and limited evidence, assign summary terms for your evaluation of evidence and agreement.
- In any of these cases, the degree of certainty in findings that are conditional on other findings should be evaluated and reported separately.

A level of confidence is expressed using five qualifiers: “very low,” “low,” “medium,” “high,” and “very high.” It synthesizes the author teams’ judgments about the validity of findings as determined through evaluation of evidence and agreement. Figure K-1 depicts summary statements for evidence and agreement and their relationship to confidence. There is flexibility in this relationship; for a given evidence and agreement statement, different confidence levels could be assigned, but increasing levels of evidence and degrees of agreement are correlated with increasing confidence. Confidence cannot necessarily be assigned for all combinations of evidence and agreement in Figure H-1. Presentation of findings with “low” and “very low” confidence should be reserved for areas of major concern, and the reasons for their presentation should be carefully explained. Confidence should not be interpreted probabilistically, and it is distinct from “statistical confidence.” Additionally, a finding that includes a probabilistic measure of uncertainty does not require explicit mention of the level of confidence associated with that finding if the level of confidence is “high” or “very high.”

Likelihood, as defined in Table K-1, provides calibrated language for describing quantified uncertainty. It can be used to express a probabilistic estimate of the occurrence of a single event or of an outcome (e.g., a climate parameter, observed trend, or projected change lying in a given range). Likelihood may be based on statistical or modelling analyses, elicitation of expert views, or other quantitative analyses.

Table K-1: Likelihood scale

| Term | Likelihood of the Outcome |
|------------------------|---------------------------|
| Virtually certain | 99-100% probability |
| Very likely | 90-100% probability |
| Likely | 66-100% probability |
| About as likely as not | 33 to 66% probability |
| Unlikely | 0-33% probability |
| Very unlikely | 0-10% probability |
| Exceptionally unlikely | 0-1% probability |

The categories defined in this table can be considered to have “fuzzy” boundaries. A statement that an outcome is “likely” means that the probability of this outcome can range from $\geq 66\%$ (fuzzy boundaries implied) to 100% probability. This implies that all alternative outcomes are “unlikely” (0-33% probability). When there is sufficient information, it is preferable to specify the full probability distribution or a probability range (e.g., 90-95%) without using the terms in Table K-1. “About as likely as not” should not be used to express a lack of knowledge.